


Asbestos Register

(Hazardous Materials and Risk Assessment)



School : Awabakal Environmental Education Centre (5682)
Region : Hunter/Central Coast
State Electorate : Charlestown
Local Government Area : Lake Macquarie

Initial Survey : Noel Arnold & Associates : 22 - Apr - 2008
Register Issue Date : 23 - Mar - 2017



2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00A - Special Purpose - 1950 - Timber (Timber)**Exterior**

Ceiling Voids	Requires Inspection
Underfloor Voids	Requires Inspection

Interior**B00A - R0001 - Seminar/Study**

Floor Coverings Res/Textile	Vinyl Tiles					
	5682/B00A/R0002/Floor Coverings Res/Textile/S4					No Asbestos Detected

B00A - R0002 - General Storeroom

Wall Linings Internal	Flat AC Sheeting	4m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	5682/B00A/R0002/Wall Linings Internal/S3					Chrysotile (white asbestos)

Floor Coverings Res/Textile	Vinyl Tiles					
	5682/B00A/R0002/Floor Coverings Res/Textile/S4					No Asbestos Detected

B00A - R0003 - Staff Study

Floor Coverings Res/Textile	Vinyl Tiles					
	5682/B00A/R0002/Floor Coverings Res/Textile/S4					No Asbestos Detected

B00A - R9001 - General Storeroom

No Asbestos

B00A - R9002 - No Access

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No				Test Result		

B00B - Pupil Facilities - 1950 - Brick/Block (Brick/Block)**Exterior**

Eaves Linings	Flat AC Sheeting	23m2	North, South, East, West	Good Condition (1)	Low (1)	Low Priority (2-3)
	Assumed Asbestos					
Ceiling Voids	Requires Inspection					
Underfloor Voids	Requires Inspection					

Interior**B00B - R0001 - Staff Toilet**

Ceiling Structures/Linings	Flat AC Sheeting	4m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	5682/B00B/R0001/Ceiling Structures/Linings/S1					Chrysotile (white asbestos)

B00B - R0002 - Movement

Ceiling Structures/Linings	Flat AC Sheeting	14m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	5682/B00B/R0001/Ceiling Structures/Linings/S1					Chrysotile (white asbestos)

B00B - R0003 - Movement

Ceiling Structures/Linings	Flat AC Sheeting	5m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	5682/B00B/R0001/Ceiling Structures/Linings/S1					Chrysotile (white asbestos)

B00B - R0004 - Toilets-Girls

Ceiling Structures/Linings	Flat AC Sheeting	5m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	5682/B00B/R0001/Ceiling Structures/Linings/S1					Chrysotile (white asbestos)

Partition Walls (Cubicles)	Compressed AC Sheet	2m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	5682/B00B/R0006/Partition Walls (Cubicles)/S2					Chrysotile (white asbestos)

B00B - R0005 - Movement

Ceiling Structures/Linings	Flat AC Sheeting	6m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	5682/B00B/R0001/Ceiling Structures/Linings/S1					Chrysotile (white asbestos)

B00B - R0006 - Toilets-Boys

Ceiling Structures/Linings	Flat AC Sheeting	6m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	5682/B00B/R0001/Ceiling Structures/Linings/S1					Chrysotile (white asbestos)

Partition Walls (Cubicles)	Compressed AC Sheet	2m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	5682/B00B/R0006/Partition Walls (Cubicles)/S2					Chrysotile (white asbestos)

B00B - R0007 - Staff Toilet

Ceiling Structures/Linings	Flat AC Sheeting	4m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	5682/B00B/R0001/Ceiling Structures/Linings/S1					Chrysotile (white asbestos)

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

Demountables

Demountable details as per the AMS records as of 15 Feb 2017.

OS 532 - D16089 - Library : Placement Date - 3/05/2005

Exterior

Step Treads	Compressed AC Sheet	Assumed Asbestos		1.08 m2
Landing	Compressed AC Sheet	Assumed Asbestos		1.2 m2
Eave Lining	Flat AC Sheet	Assumed Asbestos		17.28 m2

Interior

R1 - Reading Area

End wall panel	Flat AC Sheet	Assumed Asbestos		18 m2
Ceiling	Flat AC Sheet	Assumed Asbestos		90 m2

R2 - Library Office/Workroom

End wall panel	Flat AC Sheet	Assumed Asbestos		18 m2
Ceiling	Flat AC Sheet	Assumed Asbestos		10 m2

R3 - Communications Room

Ceiling	Flat AC Sheet	Assumed Asbestos		8 m2
---------	---------------	------------------	--	------

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

Listing of Electronic Attachments as of 22/03/2017

There are no asbestos related file attachment(s) for this school.

2017