


Asbestos Register

(Hazardous Materials and Risk Assessment)

School : Blairmount Public School (4535)
Region : South Western Sydney
State Electorate : Campbelltown
Local Government Area : Campbelltown

Initial Survey : Noel Arnold & Associates : 19 - May - 2008
Reviewed By : Parsons Brinckerhoff : 12 - Dec - 2016



2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00A - General Learning/Pupil Facilities - 1983 - Brick/Veneer (Brick/Veneer)

Exterior

Ceiling Voids - Raked Ceiling	No Asbestos Found
Underfloor Voids - Slab on Ground	No Asbestos Found

Interior

B00A - R0001 - Handwashing Facilities

No Asbestos

B00A - R0002 - Toilets - Girls

Partition Walls (Cubicles)	Compressed AC Sheet	12m2	North	Good Condition (1)	Low (1)	Low Priority (2-3)
4535/B00C/R0047/Partition Walls (Cubicles)/S1					Chrysotile (white asbestos)	

B00A - R0003 - External Movement

No Asbestos

B00A - R0004 - Drinking Facilities

No Asbestos

B00A - R0005 - Disabled Toilet

No Asbestos

B00A - R0006 - Handwashing Facilities

No Asbestos

B00A - R0007 - Toilets - Boys

Partition Walls (Cubicles)	Compressed AC Sheet	4m2	East	Good Condition (1)	Low (1)	Low Priority (2-3)
4535/B00C/R0047/Partition Walls (Cubicles)/S1					Chrysotile (white asbestos)	

B00A - R0008 - Distribution Board

Note: No inspection of live electrical installation.

No Asbestos

B00A - R0009 - Craft Store

No Asbestos

B00A - R0010 - Practical Activities - 1hb

No Asbestos

B00A - R0011 - Home Base

No Asbestos

B00A - R0012 - External Movement

No Asbestos

B00A - R0013 - Withdrawal Space - 1hb

No Asbestos

B00A - R0014 - Home Base Store

No Asbestos

B00A - R0015 - Home Base

No Asbestos

B00A - R0016 - External Movement

No Asbestos

B00A - R0017 - External Movement

No Asbestos

B00A - R0018 - Practical Activities - 1hb

No Asbestos

B00A - R0019 - Home Base

No Asbestos

B00A - R0020 - Home Base Store

No Asbestos

B00A - R0021 - External Movement

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
	Sample No					Test Result

No Asbestos						
B00A - R0022 - Withdrawal Space - 1hb						
No Asbestos						
B00A - R0023 - Home Base						
No Asbestos						
B00A - R0024 - External Movement						
No Asbestos						
B00A - R0025 - Home Base Store						
No Asbestos						
B00A - R0026 - External Movement						
No Asbestos						
B00A - R0027 - Craft Store						
No Asbestos						
B00A - R0028 - Movement						
No Asbestos						
B00A - R0029 - Practical Activities - 1hb						
No Asbestos						
B00A - R0030 - Home Base						
No Asbestos						
B00A - R0031 - Home Base Store						
No Asbestos						
B00A - R0032 - Withdrawal Space - 1hb						
No Asbestos						
B00A - R0033 - External Movement						
No Asbestos						
B00A - R0034 - Home Base Store						
No Asbestos						
B00A - R0035 - Home Base						
No Asbestos						
B00A - R0036 - External Movement						
No Asbestos						
B00A - R0037 - Movement						
No Asbestos						
B00A - R0038 - External Movement						
No Asbestos						
B00A - R0039 - Practical Activities - 1hb						
No Asbestos						
B00A - R0040 - Home Base						
No Asbestos						
B00A - R0041 - Home Base Store						
No Asbestos						
B00A - R0042 - External Movement						
No Asbestos						
B00A - R0043 - Withdrawal Space - 1hb						
No Asbestos						
B00A - R0044 - Home Base						
No Asbestos						
B00A - R0045 - Home Base Store						
No Asbestos						
B00A - R0046 - External Movement						
No Asbestos						

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
B00A - R0047 - Staff Room Annexe						
No Asbestos						
B00A - R0048 - Movement						
No Asbestos						
B00A - R0049 - Home Base Store						
No Asbestos						
B00A - R0050 - External Movement						
No Asbestos						
B00A - R0051 - Movement						
No Asbestos						

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00B - General Learning/Library - 1983 - Brick/Veneer (Brick/Veneer)

Exterior

Ceiling Voids - Raked Ceiling	No Asbestos Found
Underfloor Voids - Slab on Ground	No Asbestos Found

Interior

B00B - R0001 - Reading Area

No Asbestos

B00B - R0004 - Library Office/Workroom

No Asbestos

B00B - R0005 - Security Store

No Asbestos

B00B - R0006 - Staff Room Annexe

No Asbestos

B00B - R0007 - Home Base Store

No Asbestos

B00B - R0008 - Home Base

No Asbestos

B00B - R0009 - External Movement

No Asbestos

B00B - R0010 - Withdrawal Space - 1hb

No Asbestos

B00B - R0011 - External Movement

No Asbestos

B00B - R0012 - Home Base

No Asbestos

B00B - R0013 - Home Base Store

No Asbestos

B00B - R0014 - Practical Activities - 1hb

No Asbestos

B00B - R0015 - Practical Activities - 1hb

No Asbestos

B00B - R0016 - Craft Store

No Asbestos

B00B - R0017 - Home Base Store

No Asbestos

B00B - R0018 - Home Base

No Asbestos

B00B - R0019 - Distribution Board

Note: No inspection of live electrical installation.

No Asbestos

B00B - R0020 - External Movement

No Asbestos

B00B - R0021 - Plant

No Asbestos

B00B - R0022 - Withdrawal Space - 1hb

No Asbestos

B00B - R0023 - Home Base Store

No Asbestos

B00B - R0024 - External Movement

No Asbestos

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
B00B - R0025 - Home Base						
No Asbestos						
B00B - R0026 - Security Store						
No Asbestos						
B00B - R0027 - Special Programs Room						
No Asbestos						
B00B - R0028 - Special Programs Store						
No Asbestos						
B00B - R0029 - Cleaning Distributed Store						
No Asbestos						
B00B - R0030 - Security Store						
No Asbestos						
B00B - R0031 - Movement						
No Asbestos						
B00B - R0032 - External Movement						
No Asbestos						
B00B - R0033 - Kiln Room						
No Asbestos						
B00B - R0034 - Practical Activities - 1hb						
No Asbestos						
B00B - R0035 - Movement						
No Asbestos						
B00B - R0036 - Home Base						
No Asbestos						
B00B - R0037 - Home Base Store						
No Asbestos						
B00B - R0038 - External Movement						
No Asbestos						
B00B - R0039 - Withdrawal Space - 1hb						
No Asbestos						
B00B - R0040 - External Movement						
No Asbestos						
B00B - R0041 - Home Base						
No Asbestos						
B00B - R0042 - Home Base Store						
No Asbestos						
B00B - R0043 - General Storeroom						
No Asbestos						
B00B - R0044 - Staff Room Annexe						
No Asbestos						
B00B - R0045 - Hall Chair Store						
No Asbestos						
B00B - R0046 - Sports Store						
No Asbestos						
B00B - R0047 - Distribution Board					Note: No inspection of live electrical installation.	
No Asbestos						
B00B - R0048 - Distribution Board					Note: No inspection of live electrical installation.	
No Asbestos						
B00B - R0049 - Cleaning Distributed Store						
No Asbestos						
B00B - R0050 - Movement						

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

No Asbestos

B00B - R0051 - Drinking Facilities

No Asbestos

B00B - R0052 - Handwashing Facilities

No Asbestos

B00B - R0053 - Toilets - Girls

Partition Walls (Cubicles)	Compressed AC Sheet	16m2	East	Good Condition (1)	Low (1)	Low Priority (2-3)
----------------------------	---------------------	------	------	--------------------	---------	--------------------

4535/B00C/R0047/Partition Walls (Cubicles)/S1 Chrysotile (white asbestos)

B00B - R0054 - External Movement

No Asbestos

B00B - R0055 - Toilets - Boys

Partition Walls (Cubicles)	Compressed AC Sheet	8m2	West	Good Condition (1)	Low (1)	Low Priority (2-3)
----------------------------	---------------------	-----	------	--------------------	---------	--------------------

4535/B00C/R0047/Partition Walls (Cubicles)/S1 Chrysotile (white asbestos)

B00B - R0056 - Handwashing Facilities

No Asbestos

B00B - R0057 - Craft Store

No Asbestos

B00B - R0058 - Home Base Store

No Asbestos

B00B - R0059 - Home Base

No Asbestos

B00B - R0060 - External Movement

No Asbestos

B00B - R0061 - Withdrawal Space - 1hb

No Asbestos

B00B - R0062 - External Movement

No Asbestos

B00B - R0063 - Home Base

No Asbestos

B00B - R0064 - Home Base Store

No Asbestos

B00B - R0065 - Practical Activities - 1hb

No Asbestos

B00B - R0066 - Movement

No Asbestos

B00B - R0067 - Movement

No Asbestos

B00B - R0068 - Special Programs Room

No Asbestos



Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00C - Administration/General Learning - 1983 - Brick/Veneer (Brick/Veneer)

Exterior

Underfloor Voids - Slab on Ground	No Asbestos Found
Ceiling Voids - Raked Ceiling	No Asbestos Found

Interior

B00C - R0001 - Security Store

No Asbestos

B00C - R0002 - General Assistant/Bulk Store

No Asbestos

B00C - R0003 - Garden Store

No Asbestos

B00C - R0004 - External Movement

No Asbestos

B00C - R0005 - Movement

No Asbestos

B00C - R0006 - Staff Toilet

No Asbestos

B00C - R0007 - Community Clinic

No Asbestos

B00C - R0008 - Movement

No Asbestos

B00C - R0009 - Principal

No Asbestos

B00C - R0010 - Interview

No Asbestos

B00C - R0011 - Staff Room Annexe

No Asbestos

B00C - R0012 - Deputy Principal

No Asbestos

B00C - R0013 - Sick Bay

No Asbestos

B00C - R0014 - External Movement

No Asbestos

B00C - R0015 - Entry Vestibule

No Asbestos

B00C - R0016 - Clerical Office

No Asbestos

B00C - R0017 - Duplicating Workroom

No Asbestos

B00C - R0018 - Cleaning Distributed Store

No Asbestos

B00C - R0019 - Craft Store

No Asbestos

B00C - R0020 - Home Base Store

No Asbestos

B00C - R0021 - Home Base

No Asbestos

B00C - R0022 - External Movement

No Asbestos

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No						Test Result
B00C - R0023 - Withdrawal Space - 1hb						
No Asbestos						
B00C - R0024 - Home Base Store						
No Asbestos						
B00C - R0025 - External Movement						
No Asbestos						
B00C - R0026 - Home Base						
No Asbestos						
B00C - R0027 - Practical Activities - 1hb						
No Asbestos						
B00C - R0028 - External Movement						
No Asbestos						
B00C - R0029 - Cleaning Supplies						
No Asbestos						
B00C - R0030 - Main Switch Board						
No Asbestos						
B00C - R0031 - Cleaning Distributed Store						
No Asbestos						
B00C - R0032 - Practical Activities - 1hb						
No Asbestos						
B00C - R0033 - General Storeroom						
No Asbestos						
B00C - R0034 - Home Base						
No Asbestos						
B00C - R0035 - Withdrawal Space - 1hb						
No Asbestos						
B00C - R0036 - Home Base Store						
No Asbestos						
B00C - R0037 - External Movement						
No Asbestos						
B00C - R0038 - Home Base Store						
No Asbestos						
B00C - R0039 - Home Base						
No Asbestos						
B00C - R0040 - Withdrawal Space - 1hb						
No Asbestos						
B00C - R0041 - External Movement						
No Asbestos						
B00C - R0042 - Home Base						
No Asbestos						
B00C - R0043 - Home Base Store						
No Asbestos						
B00C - R0044 - Staff Room Annexe						
No Asbestos						
B00C - R0045 - Staff Room						
No Asbestos						
B00C - R0046 - Staff Toilet						
Partition Walls (Cubicles)	Compressed AC Sheet	4m2	West	Good Condition (1)	Low (1)	Low Priority (2-3)
4535/B00C/R0047/Partition Walls (Cubicles)/S1						Chrysotile (white asbestos)
B00C - R0047 - Staff Toilet						

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
Partition Walls (Cubicles)	Compressed AC Sheet	4m2	West	Good Condition (1)	Low (1)	Low Priority (2-3)
4535/B00C/R0047/Partition Walls (Cubicles)/S1					Chrysotile (white asbestos)	
B00C - R0048 - Security Store						
No Asbestos						
B00C - R0049 - Distribution Board					Note: No inspection of live electrical installation.	
No Asbestos						
B00C - R0050 - Canteen Office/Store						
No Asbestos						
B00C - R0051 - Canteen Office/Store						
No Asbestos						
B00C - R0052 - Staff Toilet						
No Asbestos						
B00C - R0053 - Canteen						
No Asbestos						
B00C - R0054 - External Movement						
No Asbestos						
B00C - R0055 - Movement						
No Asbestos						
B00C - R0056 - External Movement						
No Asbestos						
B00C - R0057 - Plant						
No Asbestos						
B00C - R0058 - Movement						
No Asbestos						
B00C - R0059 - Special Programs Room						
No Asbestos						
B00C - R0060 - Raised Platform						
No Asbestos						
B00C - R0061 - Communal Space						
No Asbestos						
B00C - R0062 - Toilets - Girls						
Partition Walls (Cubicles)	Compressed AC Sheet	4m2	North	Good Condition (1)	Low (1)	Low Priority (2-3)
4535/B00C/R0047/Partition Walls (Cubicles)/S1					Chrysotile (white asbestos)	
B00C - R0063 - Handwashing Facilities						
No Asbestos						
B00C - R0064 - External Movement						
No Asbestos						
B00C - R0065 - Handwashing Facilities						
No Asbestos						
B00C - R0066 - Toilets - Boys						
Partition Walls (Cubicles)	Compressed AC Sheet	8m2	East	Good Condition (1)	Low (1)	Low Priority (2-3)
4535/B00C/R0047/Partition Walls (Cubicles)/S1					Chrysotile (white asbestos)	

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

Demountables

Demountable details as per the AMS records as of 15 Feb 2017.

OS 602 - D14015 - Learning Unit - Standard With P.A.A. : Placement Date - 5/11/2014

Exterior

No Asbestos Found.

Interior

R1 - Learning space/withdrawal/entry

No Asbestos Found.

R2 - Home Base Store

No Asbestos Found.

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

Listing of Electronic Attachments as of 22/03/2017

There are no asbestos related file attachment(s) for this school.

2017