


# Asbestos Register

(Hazardous Materials and Risk Assessment)

**School :** Bowen Public School (4538)  
**Region :** Western NSW  
**State Electorate :** Orange  
**Local Government Area :** Orange

**Initial Survey :** Noel Arnold & Associates : 21 - May - 2008  
**Register Issue Date :** 23 - Mar - 2017



2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B00A - Administration - 1970 - Brick/Block (Brick/Block)**

**Exterior**

In-fill-panel	Flat AC Sheeting	20m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00A/R0032/In-fill-panel/S1				<b>Chrysotile (white asbestos)</b>	
Eaves Linings	Flat AC Sheeting	20m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00D/R0002/Ceiling Structures/Linings/S7				<b>Chrysotile (white asbestos)</b>	
Ceiling Voids	Requires Inspection					
Underfloor Voids	Requires Inspection					

**Interior**

**B00A - R0004 - Cleaning Distributed Store**

No Asbestos

**B00A - R0005 - Interview**

No Asbestos

**B00A - R0006 - Staff Toilet**

No Asbestos

**B00A - R0007 - Staff Toilet**

Partition Walls (Cubicles)	Compressed AC Sheet	4m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00A/R0007/Partition Walls (Cubicles)/S2				<b>Chrysotile (white asbestos)</b>	

**B00A - R0008 - Deputy Principal**

No Asbestos

**B00A - R0009 - Staff Room Annexe**

No Asbestos

**B00A - R0010 - Principal**

No Asbestos

**B00A - R0012 - Staff Toilet**

No Asbestos

**B00A - R0015 - Security Store**

No Asbestos

**B00A - R0016 - Main Switch Board**

No Asbestos

**B00A - R0018 - Staff Toilet**

No Asbestos

**B00A - R0019 - Withdrawal Space - 1hb**

No Asbestos

**B00A - R0020 - Movement**

No Asbestos

**B00A - R0021 - Movement**

No Asbestos

**B00A - R0024 - External Movement**

No Asbestos

**B00A - R0025 - Staff Room Annexe**

No Asbestos

**B00A - R0026 - Home Base Store**

Floor Coverings Res/Textile	Vinyl Tiles					
	4538/B00A/R0026/Floor Coverings Res/Textile/S3				<b>No Asbestos Detected</b>	

**B00A - R0027 - Entry Vestibule**

No Asbestos

**B00A - R0028 - Movement**

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

No Asbestos

**B00A - R0029 - Clerical Office**

No Asbestos

**B00A - R0030 - Staff Room**

In-fill-panel	Flat AC Sheeting	2m	North, Lower portion	Good Condition (1)	Low (1)	Low Priority (2-3)
4538/B00A/R0032/In-fill-panel/S1					<b>Chrysotile (white asbestos)</b>	

**B00A - R0031 - Movement**

No Asbestos

**B00A - R0032 - Sick Bay**

In-fill-panel	Flat AC Sheeting	2m	North, Lower portion	Good Condition (1)	Low (1)	Low Priority (2-3)
4538/B00A/R0032/In-fill-panel/S1					<b>Chrysotile (white asbestos)</b>	

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B00B - General Learning - 1970 - Brick/Block (Brick/Block)****Exterior**

In-fill-panel	Flat AC Sheeting	20m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00B/In-fill-panel/S5					<b>Chrysotile (white asbestos)</b>
Eaves Linings	Flat AC Sheeting	20m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00D/R0002/Ceiling Structures/Linings/S7					<b>Chrysotile (white asbestos)</b>
Ceiling Voids	Requires Inspection					
Underfloor Voids	Requires Inspection					

**Interior****B00B - R0001 - Distribution Board** Note: No inspection of live electrical installation.

Non Accessible

**B00B - R0002 - Cleaning Distributed Store**

Non Accessible

**B00B - R0003 - Toilets - Boys/Girls**

No Asbestos

**B00B - R0004 - Toilets - Boys**

Partition Walls (Cubicles)	Compressed AC Sheet	2m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00A/R0007/Partition Walls (Cubicles)/S2					<b>Chrysotile (white asbestos)</b>

**B00B - R0005 - Toilets - Girls**

Partition Walls (Cubicles)	Compressed AC Sheet	8m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00A/R0007/Partition Walls (Cubicles)/S2					<b>Chrysotile (white asbestos)</b>

**B00B - R0006 - Home Base**

No Asbestos

**B00B - R0007 - Home Base Store**

Floor Coverings Res/Textile	Vinyl Tiles	7m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00B/R0009/Floor Coverings Res/Textile/S4					<b>Chrysotile (white asbestos)</b>

**B00B - R0008 - Home Base Store**

Floor Coverings Res/Textile	Vinyl Tiles	7m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00B/R0009/Floor Coverings Res/Textile/S4					<b>Chrysotile (white asbestos)</b>

**B00B - R0009 - Practical Activities - 1hb**

Floor Coverings Res/Textile	Vinyl Tiles	7m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00B/R0009/Floor Coverings Res/Textile/S4					<b>Chrysotile (white asbestos)</b>

**B00B - R0010 - Practical Activities - 1hb**

Floor Coverings Res/Textile	Vinyl Tiles	7m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00B/R0009/Floor Coverings Res/Textile/S4					<b>Chrysotile (white asbestos)</b>

**B00B - R0011 - Home Base**

No Asbestos

**B00B - R0012 - Home Base**

No Asbestos

**B00B - R0013 - Home Base Store**

Floor Coverings Res/Textile	Vinyl Tiles	7m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00B/R0009/Floor Coverings Res/Textile/S4					<b>Chrysotile (white asbestos)</b>

**B00B - R0014 - Practical Activities - 1hb**

Floor Coverings Res/Textile	Vinyl Tiles	7m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00B/R0009/Floor Coverings Res/Textile/S4					<b>Chrysotile (white asbestos)</b>

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
<b>B00B - R0015 - External Movement</b>						
In-fill-panel	Flat AC Sheeting 4538/B00B/In-fill-panel/S5	20m	Throughout, Lower portion	Good Condition (1)	Low (1)	Low Priority (2-3) <b>Chrysotile (white asbestos)</b>

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B00C - General Learning - 1970 - Brick/Block (Brick/Block)****Exterior**

In-fill-panel	Flat AC Sheeting	20m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00A/R0032/In-fill-panel/S1					<b>Chrysotile (white asbestos)</b>
Eaves Linings	Flat AC Sheeting	20m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00D/R0002/Ceiling Structures/Linings/S7					<b>Chrysotile (white asbestos)</b>
Ceiling Voids	Requires Inspection					
Underfloor Voids	Requires Inspection					

**Interior****B00C - R0001 - Cleaning Distributed Store**

Non Accessible

**B00C - R0002 - No Access**

Non Accessible

**B00C - R0003 - Toilets - Boys/Girls**

No Asbestos

**B00C - R0004 - Toilets - Boys**

Partition Walls (Cubicles)	Compressed AC Sheet	4m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00C/R0003/Partition Walls (Cubicles)/S6					<b>Chrysotile (white asbestos)</b>

**B00C - R0005 - Toilets - Girls**

Partition Walls (Cubicles)	Compressed AC Sheet	4m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00C/R0003/Partition Walls (Cubicles)/S6					<b>Chrysotile (white asbestos)</b>

**B00C - R0006 - Home Base**

No Asbestos

**B00C - R0007 - Practical Activities - 1hb**

Floor Coverings Res/Textile	Vinyl Tiles	7m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00B/R0009/Floor Coverings Res/Textile/S4					<b>Chrysotile (white asbestos)</b>

**B00C - R0008 - Home Base Store**

Floor Coverings Res/Textile	Vinyl Tiles	7m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00B/R0009/Floor Coverings Res/Textile/S4					<b>Chrysotile (white asbestos)</b>

**B00C - R0009 - Home Base Store**

Floor Coverings Res/Textile	Vinyl Tiles	7m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00B/R0009/Floor Coverings Res/Textile/S4					<b>Chrysotile (white asbestos)</b>

**B00C - R0010 - Practical Activities - 1hb**

Floor Coverings Res/Textile	Vinyl Tiles	7m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00B/R0009/Floor Coverings Res/Textile/S4					<b>Chrysotile (white asbestos)</b>

**B00C - R0011 - Home Base**

No Asbestos

**B00C - R0012 - Home Base**

No Asbestos

**B00C - R0013 - Home Base Store**

Floor Coverings Res/Textile	Vinyl Tiles	7m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00B/R0009/Floor Coverings Res/Textile/S4					<b>Chrysotile (white asbestos)</b>

**B00C - R0014 - Practical Activities - 1hb**

Floor Coverings Res/Textile	Vinyl Tiles	7m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00B/R0009/Floor Coverings Res/Textile/S4					<b>Chrysotile (white asbestos)</b>

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
<b>B00C - R0015 - External Movement</b>						
In-fill-panel	Flat AC Sheeting	20m	Throughout, Lower portion	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00A/R0032/In-fill-panel/S1					<b>Chrysotile (white asbestos)</b>

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B00D - Building Services - 1970 - Brick/Block (Brick/Block)**

**Exterior**

Eaves Linings	Flat AC Sheeting	20m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00D/R0002/Ceiling Structures/Linings/S7				Chrysotile (white asbestos)	
Ceiling Voids	Requires Inspection					
Underfloor Voids	Requires Inspection					

**Interior**

**B00D - R0002 - Sports Store**

Ceiling Structures/Linings	Flat AC Sheeting	23m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00D/R0002/Ceiling Structures/Linings/S7				Chrysotile (white asbestos)	

**B00D - R0003 - General Assistant/Bulk Store**

Ceiling Structures/Linings	Flat AC Sheeting	10m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00D/R0002/Ceiling Structures/Linings/S7				Chrysotile (white asbestos)	

**B00D - R0004 - Security Store**

Ceiling Structures/Linings	Flat AC Sheeting	13m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00D/R0002/Ceiling Structures/Linings/S7				Chrysotile (white asbestos)	

**B00D - R0005 - External Movement**

Ceiling Structures/Linings	Flat AC Sheeting	77m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00D/R0002/Ceiling Structures/Linings/S7				Chrysotile (white asbestos)	

**B00D - R0006 - Kiln Room**

Ceiling Structures/Linings	Flat AC Sheeting	5m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00D/R0002/Ceiling Structures/Linings/S7				Chrysotile (white asbestos)	

**B00D - R0007 - General Storeroom**

Ceiling Structures/Linings	Flat AC Sheeting	40m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00D/R0002/Ceiling Structures/Linings/S7				Chrysotile (white asbestos)	

2017



Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B00E - General Learning - 1970 - Brick/Block (Brick/Block)****Exterior**

Ceiling Voids	Requires Inspection
Underfloor Voids	Requires Inspection

**Interior****B00E - R0001 - Practical Activities - 1hb**

Floor Coverings Res/Textile	Vinyl Tiles	7m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
4538/B00E/R0010/Floor Coverings Res/Textile/S8					<b>Chrysotile (white asbestos)</b>	

**B00E - R0002 - Home Base Store**

Floor Coverings Res/Textile	Vinyl Tiles	7m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
4538/B00E/R0010/Floor Coverings Res/Textile/S8					<b>Chrysotile (white asbestos)</b>	

**B00E - R0003 - Home Base**

No Asbestos

**B00E - R0004 - Toilets - Boys/Girls**

No Asbestos

**B00E - R0005 - Cleaning Distributed Store**

No Asbestos

**B00E - R0006 - Distribution Board**

Note: No inspection of live electrical installation.

Non Accessible

**B00E - R0009 - Staff Kitchen**

Floor Coverings Res/Textile	Vinyl Tiles	5m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
4538/B00E/R0010/Floor Coverings Res/Textile/S8					<b>Chrysotile (white asbestos)</b>	

**B00E - R0010 - Practical Activities - 1hb**

Floor Coverings Res/Textile	Vinyl Tiles	7m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
4538/B00E/R0010/Floor Coverings Res/Textile/S8					<b>Chrysotile (white asbestos)</b>	

**B00E - R0011 - Home Base**

No Asbestos

**B00E - R0012 - Home Base**

No Asbestos

**B00E - R0013 - Home Base Store**

No Asbestos

**B00E - R0014 - Personal Effects Storage**

No Asbestos

**B00E - R0015 - External Movement**

In-fill-panel	Flat AC Sheeting	20m	Throughout, Lower portion	Good Condition (1)	Low (1)	Low Priority (2-3)
4538/B00A/R0032/In-fill-panel/S1					<b>Chrysotile (white asbestos)</b>	
Ceiling Structures/Linings	Flat AC Sheeting	40m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
4538/B00D/R0002/Ceiling Structures/Linings/S7					<b>Chrysotile (white asbestos)</b>	

**B00E - R0016 - Disabled Toilet**

Non Accessible

**B00E - R0017 - Disabled Toilet**

Non Accessible

**B00E - R0018 - Ramp**

No Asbestos

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B00F - General Learning/Communal Facilities - 1982 - Brick/Block (Brick/Block)****Exterior**

Eaves Linings	Flat AC Sheeting 4538/B00F/Eaves Linings/S12					<b>No Asbestos Detected</b>
Ceiling Voids	Requires Inspection					
Underfloor Voids	Requires Inspection					

**Interior****B00F - R0001 - Canteen**

No Asbestos

**B00F - R0002 - Canteen Office/Store**

No Asbestos

**B00F - R0003 - Staff Toilet**

No Asbestos

**B00F - R0004 - Canteen Office/Store**

No Asbestos

**B00F - R0005 - Main Switch Board**

No Asbestos

**B00F - R0006 - General Storeroom**

No Asbestos

**B00F - R0007 - Movement**

No Asbestos

**B00F - R0008 - Cleaning Supplies**

No Asbestos

**B00F - R0009 - General Storeroom**

No Asbestos

**B00F - R0010 - Toilets - Girls**

Partition Walls (Cubicles)	Compressed AC Sheet	4m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
4538/B00F/R0074/Partition Walls (Cubicles)/S11					<b>Chrysotile (white asbestos)</b>	

**B00F - R0011 - Toilets - Boys**

Partition Walls (Cubicles)	Compressed AC Sheet	4m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
4538/B00F/R0074/Partition Walls (Cubicles)/S11					<b>Chrysotile (white asbestos)</b>	

**B00F - R0012 - Raised Platform**

No Asbestos

**B00F - R0013 - Communal Space**

No Asbestos

**B00F - R0014 - Movement**

No Asbestos

**B00F - R0015 - Movement**

No Asbestos

**B00F - R0016 - Cleaning Distributed Store**

Non Accessible

**B00F - R0017 - Special Programs Room**

No Asbestos

**B00F - R0018 - External Movement**

No Asbestos

**B00F - R0019 - Plant**

No Asbestos

**B00F - R0020 - External Movement**

No Asbestos

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
<b>B00F - R0021 - Garden Store</b>						
No Asbestos						
<b>B00F - R0022 - Home Base Store</b>						
Floor Coverings Res/Textile	Vinyl Tiles					
4538/B00F/R0085/Floor Coverings Res/Textile/S9					<b>No Asbestos Detected</b>	
<b>B00F - R0023 - Home Base</b>						
No Asbestos						
<b>B00F - R0024 - Home Base</b>						
No Asbestos						
<b>B00F - R0025 - Withdrawal Space - 1hb</b>						
No Asbestos						
<b>B00F - R0026 - Home Base Store</b>						
No Asbestos						
<b>B00F - R0027 - Toilets - Boys</b>						
Partition Walls (Cubicles)	Compressed AC Sheet	2m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
4538/B00F/R0074/Partition Walls (Cubicles)/S11					<b>Chrysotile (white asbestos)</b>	
<b>B00F - R0028 - External Movement</b>						
No Asbestos						
<b>B00F - R0029 - Sports Store</b>						
Floor Coverings Res/Textile	Vinyl Tiles					
4538/B00F/R0085/Floor Coverings Res/Textile/S9					<b>No Asbestos Detected</b>	
<b>B00F - R0030 - Practical Activities - 1hb</b>						
No Asbestos						
<b>B00F - R0031 - Interview</b>						
No Asbestos						
<b>B00F - R0032 - Movement</b>						
No Asbestos						
<b>B00F - R0033 - General Storeroom</b>						
Floor Coverings Res/Textile	Vinyl Tiles					
4538/B00F/R0085/Floor Coverings Res/Textile/S9					<b>No Asbestos Detected</b>	
<b>B00F - R0034 - Home Base Store</b>						
Floor Coverings Res/Textile	Vinyl Tiles					
4538/B00F/R0085/Floor Coverings Res/Textile/S9					<b>No Asbestos Detected</b>	
<b>B00F - R0035 - Toilets - Girls</b>						
Partition Walls (Cubicles)	Compressed AC Sheet	4m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
4538/B00F/R0074/Partition Walls (Cubicles)/S11					<b>Chrysotile (white asbestos)</b>	
<b>B00F - R0036 - Home Base</b>						
No Asbestos						
<b>B00F - R0037 - Home Base</b>						
No Asbestos						
<b>B00F - R0038 - Withdrawal Space - 1hb</b>						
No Asbestos						
<b>B00F - R0039 - Home Base Store</b>						
Floor Coverings Res/Textile	Vinyl Tiles					
4538/B00F/R0085/Floor Coverings Res/Textile/S9					<b>No Asbestos Detected</b>	
<b>B00F - R0040 - No Access</b>						
Non Accessible						

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No						Test Result
<b>B00F - R0041 - External Movement</b>						
No Asbestos						
<b>B00F - R0042 - Personal Effects Storage</b>						
No Asbestos						
<b>B00F - R0043 - Personal Effects Storage</b>						
No Asbestos						
<b>B00F - R0044 - Personal Effects Storage</b>						
No Asbestos						
<b>B00F - R0045 - Personal Effects Storage</b>						
No Asbestos						
<b>B00F - R0046 - Personal Effects Storage</b>						
No Asbestos						
<b>B00F - R0047 - Personal Effects Storage</b>						
No Asbestos						
<b>B00F - R0048 - Personal Effects Storage</b>						
No Asbestos						
<b>B00F - R0049 - Personal Effects Storage</b>						
Floor Coverings Res/Textile	Vinyl Tiles					
4538/B00F/R0085/Floor Coverings Res/Textile/S9						<b>No Asbestos Detected</b>
<b>B00F - R0050 - Practical Activities - 1hb</b>						
No Asbestos						
<b>B00F - R0051 - Kiln Room</b>						
No Asbestos						
<b>B00F - R0052 - Distribution Board</b>						Note: No inspection of live electrical installation.
No Asbestos						
<b>B00F - R0053 - Security Store</b>						
No Asbestos						
<b>B00F - R0054 - General Storeroom</b>						
Floor Coverings Res/Textile	Vinyl Tiles					
4538/B00F/R0085/Floor Coverings Res/Textile/S9						<b>No Asbestos Detected</b>
<b>B00F - R0055 - Home Base Store</b>						
Floor Coverings Res/Textile	Vinyl Tiles					
4538/B00F/R0085/Floor Coverings Res/Textile/S9						<b>No Asbestos Detected</b>
<b>B00F - R0056 - Toilets - Girls</b>						
Partition Walls (Cubicles)	Compressed AC Sheet	8m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
4538/B00F/R0074/Partition Walls (Cubicles)/S11						<b>Chrysotile (white asbestos)</b>
<b>B00F - R0057 - Home Base</b>						
No Asbestos						
<b>B00F - R0058 - Home Base</b>						
No Asbestos						
<b>B00F - R0059 - Withdrawal Space - 1hb</b>						
No Asbestos						
<b>B00F - R0060 - Home Base Store</b>						
Floor Coverings Res/Textile	Vinyl Tiles					
4538/B00F/R0085/Floor Coverings Res/Textile/S9						<b>No Asbestos Detected</b>
<b>B00F - R0061 - Toilets - Boys</b>						
Partition Walls (Cubicles)	Compressed AC Sheet	4m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
4538/B00F/R0074/Partition Walls (Cubicles)/S11						<b>Chrysotile (white asbestos)</b>

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
<b>B00F - R0062 - External Movement</b>						
No Asbestos						
<b>B00F - R0063 - Practical Activities - 1hb</b>						
No Asbestos						
<b>B00F - R0064 - Withdrawal Space - 1hb</b>						
No Asbestos						
<b>B00F - R0065 - General Storeroom</b>						
Floor Coverings Res/Textile	Vinyl Tiles					
	4538/B00F/R0085/Floor Coverings Res/Textile/S9					<b>No Asbestos Detected</b>
<b>B00F - R0066 - Home Base Store</b>						
Floor Coverings Res/Textile	Vinyl Tiles					
	4538/B00F/R0085/Floor Coverings Res/Textile/S9					<b>No Asbestos Detected</b>
<b>B00F - R0067 - Toilets - Girls</b>						
Partition Walls (Cubicles)	Compressed AC Sheet	4m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00F/R0074/Partition Walls (Cubicles)/S11					<b>Chrysotile (white asbestos)</b>
<b>B00F - R0068 - Home Base</b>						
No Asbestos						
<b>B00F - R0069 - Home Base</b>						
No Asbestos						
<b>B00F - R0070 - Withdrawal Space - 1hb</b>						
No Asbestos						
<b>B00F - R0071 - External Movement</b>						
No Asbestos						
<b>B00F - R0072 - Practical Activities - 1hb</b>						
No Asbestos						
<b>B00F - R0073 - Toilets - Boys</b>						
Partition Walls (Cubicles)	Compressed AC Sheet	2m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00F/R0074/Partition Walls (Cubicles)/S11					<b>Chrysotile (white asbestos)</b>
<b>B00F - R0074 - Toilets - Girls</b>						
Partition Walls (Cubicles)	Compressed AC Sheet	2m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4538/B00F/R0074/Partition Walls (Cubicles)/S11					<b>Chrysotile (white asbestos)</b>
<b>B00F - R0075 - Home Base Store</b>						
Floor Coverings Res/Textile	Vinyl Tiles					
	4538/B00F/R0085/Floor Coverings Res/Textile/S9					<b>No Asbestos Detected</b>
<b>B00F - R0076 - Movement</b>						
No Asbestos						
<b>B00F - R0077 - Movement</b>						
No Asbestos						
<b>B00F - R0078 - Movement</b>						
No Asbestos						
<b>B00F - R0079 - Movement</b>						
No Asbestos						
<b>B00F - R0080 - Reading Area</b>						
No Asbestos						
<b>B00F - R0081 - Seminar/Study</b>						
No Asbestos						
<b>B00F - R0082 - Seminar/Study</b>						
No Asbestos						

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
<b>B00F - R0083 - Library Office/Workroom</b>						
No Asbestos						
<b>B00F - R0084 - Communications Room</b>						
No Asbestos						
<b>B00F - R0085 - General Storeroom</b>						
Floor Coverings Res/Textile	Vinyl Tiles					
4538/B00F/R0085/Floor Coverings Res/Textile/S9					<b>No Asbestos Detected</b>	
<b>B00F - R0086 - Distribution Board</b>				Note: No inspection of live electrical installation.		
Non Accessible						
<b>B00F - R0087 - Covered Outdoor Learning Area</b>						
No Asbestos						

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

***Demountables***

**There are no Demountable(s) located at this school as per the AMS records as of 15 Feb 2017.**

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

*Listing of Electronic Attachments as of 22/03/2017*

**There are no asbestos related file attachment(s) for this school.**

2017