


Asbestos Register

(Hazardous Materials and Risk Assessment)

School : Bates Drive School (5647)
Region : Sydney
State Electorate : Miranda
Local Government Area : Sutherland

Initial Survey : Noel Arnold & Associates : 26 - Mar - 2008
Reviewed By : Parsons Brinckerhoff : 14 - Feb - 2017



2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00A - Administration/Library - 1972 - Brick/Block (Brick/Block)

Exterior

Ceiling Voids	No Asbestos Found
Underfloor Voids	No Asbestos Found

Interior

B00A - R0001 - External Movement

Ceiling Structures/Linings	Flat AC Sheeting	24m2	All surfaces, Upper portion	Good Condition (1)	Low (1)	Low Priority (2-3)
5647/B00A/R0001/Ceiling Structures/Linings/S1					Chrysotile (white asbestos)	

B00A - R0020 - Teachers Aide Special Ed

No Asbestos

B00A - R0021 - Home Base Store - M

No Asbestos

B00A - R0022 - Withdrawal - M

No Asbestos

B00A - R0023 - Home Base - M

No Asbestos

B00A - R0024 - Toilet - M

No Asbestos

B00A - R0025 - Practical Activities - M - 2hb

No Asbestos

B00A - R0026 - Special Programs Room - Type 1

No Asbestos

B00A - R0027 - Practical Activities - P - 1hb

No Asbestos

B00A - R0028 - Special Programs Store

No Asbestos

B00A - R0029 - Distribution Board

Note: No inspection of live electrical installation.

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00B - Support Unit/Pupil Facilities - 1972 - Brick/Block (Brick/Block)

Exterior

Underfloor Voids	No Asbestos Found					
Ceiling Voids	No Asbestos Found					
Gable Verge Lining	Flat AC Sheeting					
	5647/B00B/Gable Verge Lining/S4					No Asbestos Detected

Interior

B00B - R0001 - External Movement

Ceiling Structures/Linings	Flat AC Sheeting	72m2	All surfaces, Upper portion	Good Condition (1)	Low (1)	Low Priority (2-3)
	5647/B00A/R0001/Ceiling Structures/Linings/S1					Chrysotile (white asbestos)

B00B - R0002 - Home Base - S

No Asbestos

B00B - R0003 - Cleaning Distributed Store

Wall Linings Internal	Flat AC Sheeting	1m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)
	5647/B00B/R0003/Wall Linings Internal/S3					Chrysotile (white asbestos)

B00B - R0004 - Home Base - S

No Asbestos

B00B - R0005 - Home Base - S

No Asbestos

B00B - R0006 - Home Base - S

No Asbestos

B00B - R0007 - Laundry - S

No Asbestos

B00B - R0008 - Toilet - S

No Asbestos

B00B - R0009 - Movement

No Asbestos

B00B - R0010 - Personal Effects - S

No Asbestos

B00B - R0011 - Movement

No Asbestos

B00B - R0012 - Personal Effects - S

No Asbestos

B00B - R0013 - Toilet - S

No Asbestos

B00B - R0014 - Toilets - Girls

No Asbestos

B00B - R0015 - Toilets - Boys

No Asbestos



Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00C - Building Services - 2001 - Brick/Veneer (Brick/Veneer)

Exterior

Ceiling Voids - Flat Roof No Asbestos Found

Interior

B00C - R0001 - Plant

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00G - Support Unit - 1972 - Brick/Veneer (Brick/Veneer)

Exterior

Ceiling Voids	No Asbestos Found
Underfloor Voids	No Asbestos Found

Interior

B00G - R0001 - External Movement

No Asbestos

B00G - R0002 - Cleaning Supplies

No Asbestos

B00G - R0003 - General Storeroom

No Asbestos

B00G - R0007 - Kiln Room

No Asbestos

B00G - R0008 - Home Base - S

No Asbestos

B00G - R0009 - Home Base

No Asbestos

B00G - R0010 - Laundry - P

No Asbestos

B00G - R0011 - General Storeroom

No Asbestos

B00G - R0012 - Toilets-Unisex

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00H - Pupil Facilities - 1972 - Brick/Block (Brick/Block)

Exterior

Underfloor Voids	No Asbestos Found
Ceiling Voids	No Asbestos Found

Interior

B00H - R0001 - General Storeroom

No Asbestos

B00H - R0002 - General Storeroom

No Asbestos

B00H - R0003 - General Storeroom

No Asbestos

B00H - R0005 - Covered Vehicle Area/Porte Cochere

No Asbestos

B00H - R0006 - Main Switch Board

No Asbestos

B00H - R0007 - Toilets - Boys

No Asbestos

B00H - R0008 - Disabled Toilet

Ceiling Structures/Linings	Flat AC Sheeting	7m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)
----------------------------	------------------	-----	--------------	--------------------	---------	--------------------

Assumed Asbestos - No asbestos detected

B00H - R0009 - Toilets - Girls

No Asbestos

B00H - R0010 - Sports Store

No Asbestos

B00H - R0012 - Communal Space

No Asbestos

B00H - R0013 - Plant

No Asbestos

B00H - R0014 - External Movement

No Asbestos

B00H - R0015 - Canteen Covered Area

No Asbestos

B00H - R0016 - General Assistant/Bulk Store

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00I - Administration/General Learning - 2013 - Brick/Veneer (Brick/Veneer)

Exterior

Underfloor Voids - Packing to Floor Joists No Asbestos Found

Ceiling Voids No Asbestos Found

Interior

B00I - R0001 - Staff Room Annexe

No Asbestos

B00I - R0002 - Staff Room

No Asbestos

B00I - R0003 - Principal

No Asbestos

B00I - R0004 - Movement

No Asbestos

B00I - R0005 - General Storeroom

No Asbestos

B00I - R0006 - Staff Toilet

No Asbestos

B00I - R0007 - Staff Toilet

No Asbestos

B00I - R0008 - Access Shower/Toilet/Change

No Asbestos

B00I - R0009 - Deputy Principal

No Asbestos

B00I - R0010 - Plant

No Asbestos

B00I - R0011 - Clerical Office

No Asbestos

B00I - R0012 - Clerical/Printing

No Asbestos

B00I - R0013 - General Storeroom

No Asbestos

B00I - R0014 - Entry Vestibule

No Asbestos

B00I - R0015 - Interview

No Asbestos

B00I - R0016 - Access Shower/Toilet

No Asbestos

B00I - R0017 - Home Base

No Asbestos

B00I - R0018 - Practical Activities

No Asbestos

B00I - R0019 - General Storeroom

No Asbestos

B00I - R0020 - Withdrawal - P

No Asbestos

B00I - R0021 - Breakout Area

No Asbestos

B00I - R0022 - External Movement

No Asbestos

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
B00I - R0023 - General Storeroom						
No Asbestos						
B00I - R1001 - External Movement						
No Asbestos						
B00I - R1002 - Withdrawal - P						
No Asbestos						
B00I - R1003 - Breakout Area						
No Asbestos						
B00I - R1004 - General Storeroom						
No Asbestos						
B00I - R1005 - Practical Activities						
No Asbestos						
B00I - R1006 - Access Shower/Toilet/Change						
No Asbestos						
B00I - R1007 - Breakout Area						
No Asbestos						
B00I - R1008 - Plant						
No Asbestos						
B00I - R1009 - Withdrawal - P						
No Asbestos						
B00I - R1010 - General Storeroom						
No Asbestos						
B00I - R1011 - Home Base						
No Asbestos						
B00I - R1012 - General Storeroom						
No Asbestos						
B00I - R1013 - Home Base						
No Asbestos						
B00I - R1014 - Withdrawal - P						
No Asbestos						
B00I - R1015 - Practical Activities						
No Asbestos						
B00I - R1016 - Access Shower/Toilet/Change						
No Asbestos						
B00I - R1017 - General Storeroom						
No Asbestos						
B00I - R1018 - Breakout Area						
No Asbestos						
B00I - R1019 - Breakout Area						
No Asbestos						
B00I - R1020 - Withdrawal - P						
No Asbestos						
B00I - R1021 - Home Base						
No Asbestos						
B00I - R1022 - Home Base						
No Asbestos						

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

Demountables

There are no Demountable(s) located at this school as per the AMS records as of 15 Feb 2017.

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
	Sample No					Test Result

Listing of Electronic Attachments as of 22/03/2017

There are no asbestos related file attachment(s) for this school.

2017