


Asbestos Register

(Hazardous Materials and Risk Assessment)

School : Bourke High School (8355)
Region : Western NSW
State Electorate : Barwon
Local Government Area : Bourke

Initial Survey : Noel Arnold & Associates : 03 - May - 2008
Reviewed By : Parsons Brinckerhoff : 25 - Aug - 2016



2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00A - Music/General Learning - 1965 - Brick/Veneer (Brick/Veneer)**Exterior**

Ceiling Void	No Asbestos Found
Underfloor Void	No Asbestos Found

Interior**B00A - R0001 - Music Learning Space**

No Asbestos

B00A - R0002 - Music Store

Floor Coverings Res/Textile	Vinyl Tiles	7m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00A/R0002/Floor Coverings Res/Textile/S4					Chrysotile (white asbestos)	

B00A - R0003 - General Storeroom

Floor Coverings Res/Textile	Vinyl Tiles	7m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00A/R0002/Floor Coverings Res/Textile/S4					Chrysotile (white asbestos)	

B00A - R0004 - General Learning Space

No Asbestos

B00A - R0005 - General Learning Space

Floor Coverings Res/Textile	Vinyl Tiles	63m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00A/R0002/Floor Coverings Res/Textile/S4					Chrysotile (white asbestos)	

B00A - R0006 - Shower/Change

Floor Coverings Res/Textile	Vinyl Tiles	6m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00A/R0002/Floor Coverings Res/Textile/S4					Chrysotile (white asbestos)	

B00A - R0007 - Materials Store

Floor Coverings Res/Textile	Vinyl Tiles	6m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00A/R0002/Floor Coverings Res/Textile/S4					Chrysotile (white asbestos)	

B00A - R0008 - Distribution Board Cupboard

Note: No inspection of live electrical installation.

Wall Linings Internal	Flat AC Sheeting	10m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00A/R0008/Wall Linings Internal/S5					Chrysotile (white asbestos) , Amosite (brown asbestos)	
Ceiling Structures/Linings	Flat AC Sheeting	2m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00A/R0008/Ceiling Structures/Linings/S17					Chrysotile (white asbestos) , Amosite (brown asbestos)	

B00A - R0009 - Preparation

Floor Coverings Res/Textile	Vinyl Tiles	31m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00A/R0009/Floor Coverings Res/Textile/S6					Chrysotile (white asbestos)	

B00A - R0010 - Chemical Store

Floor Coverings Res/Textile	Vinyl Tiles	10m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00A/R0009/Floor Coverings Res/Textile/S6					Chrysotile (white asbestos)	
Fume Cupboard	Flat AC Sheeting	1Unit	Upper portion	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00A/R0010/Fume Cupboard/S7					Chrysotile (white asbestos) , Amosite (brown asbestos)	

B00A - R0011 - Laboratory L.S.

Workbench	Compressed AC Sheet	2m2	North	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00A/R0011/Workbench/S8					Chrysotile (white asbestos) , Amosite (brown asbestos)	

B00A - R0012 - Movement

No Asbestos

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00B - Technological & Applied Studies - 1965 - Brick/Block (Brick/Block)**Exterior**

Ceiling Void	No Asbestos Found
Underfloor Void	No Asbestos Found

Interior**B00B - R0001 - General Storeroom**

No Asbestos

B00B - R0002 - No Access

Non Accessible

B00B - R0003 - Cleaning Store - Distributed

No Asbestos

B00B - R0004 - Interview/Office - Type 1

No Asbestos

B00B - R0008 - Senior Study

No Asbestos

B00B - R0009 - Food/Research Space

Floor Coverings Res/Textile	Vinyl Tiles	14m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00A/R0009/Floor Coverings Res/Textile/S6					Chrysotile (white asbestos)	

B00B - R0012 - Movement

No Asbestos

B00B - R0022 - Preparation

Floor Coverings Res/Textile	Vinyl Tiles	20m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00A/R0002/Floor Coverings Res/Textile/S4					Chrysotile (white asbestos)	

B00B - R0023 - General Storeroom

Floor Coverings Res/Textile	Vinyl Tiles	9m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00A/R0009/Floor Coverings Res/Textile/S6					Chrysotile (white asbestos)	

Fume Cupboard	Flat AC Sheeting	1Unit	Upper portion	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00A/R0010/Fume Cupboard/S7					Chrysotile (white asbestos) , Amosite (brown asbestos)	

B00B - R0024 - Laboratory L.S.

Floor Coverings Res/Textile	Vinyl Tiles	84m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00A/R0009/Floor Coverings Res/Textile/S6					Chrysotile (white asbestos)	

Workbench	Compressed AC Sheet	2m2	North	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00A/R0011/Workbench/S8					Chrysotile (white asbestos) , Amosite (brown asbestos)	

B00B - R0025 - Toilets-Disabled

No Asbestos

B00B - R0026 - Special Learning Space

No Asbestos

B00B - R0027 - Movement

No Asbestos

B00B - R0028 - General Learning Space

No Asbestos

B00B - R0029 - General Learning Space

No Asbestos

B00B - R0030 - Distribution Board Cupboard

Note: No inspection of live electrical installation.

No Asbestos

B00B - R0031 - General Learning Space

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
	Sample No					Test Result

No Asbestos

B00B - R0032 - Materials Store

No Asbestos

B00B - R0033 - Materials Store

No Asbestos

B00B - R0034 - Laundry

No Asbestos

B00B - R0035 - Materials Learning Space - Type 1

No Asbestos

B00B - R0036 - Materials Store

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00C - Administration/Pupil Facilities - 1965 - Brick/Block (Brick/Block)**Exterior**

Eaves Linings	Flat AC Sheeting 8355/B00C/Eaves Linings/S16					No Asbestos Detected
Ceiling Void	No Asbestos Found					
Underfloor Void	No Asbestos Found					

Interior**B00C - R0001 - Duplicating Workroom**

No Asbestos

B00C - R0002 - No Access

Wall Linings Internal	Flat AC Sheeting 8355/B00C/R0019/Wall Linings Internal/S10	3m2	South	Good Condition (1)	Low (1)	Low Priority (2-3)
						Chrysotile (white asbestos) , Amosite (brown asbestos)
Ceiling Structures/Linings	Flat AC Sheeting 8355/B00C/R0018/Ceiling Structures/Linings/S18	1m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
						Chrysotile (white asbestos) , Amosite (brown asbestos) , Crocidolite (blue asbestos)

B00C - R0003 - Staff Study

No Asbestos

B00C - R0004 - Interview/Office - Type 1

No Asbestos

B00C - R0005 - Distribution Board Cupboard

Note: No inspection of live electrical installation.

Wall Linings Internal	Flat AC Sheeting 8355/B00C/R0019/Wall Linings Internal/S10	6m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
						Chrysotile (white asbestos) , Amosite (brown asbestos)
Ceiling Structures/Linings	Flat AC Sheeting 8355/B00C/R0018/Ceiling Structures/Linings/S18	1m2	Throughout	Some Damage / Unsealed (3)	Low (1)	Low Priority (2-3)
						Chrysotile (white asbestos) , Amosite (brown asbestos) , Crocidolite (blue asbestos)

B00C - R0006 - General Storeroom

No Asbestos

B00C - R0007 - Staff - Toilet

No Asbestos

B00C - R0008 - Movement

Floor Coverings Res/Textile	Vinyl Tiles 8355/B00C/R0032/Floor Coverings Res/Textile/S9	4m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
						Chrysotile (white asbestos)

B00C - R0009 - General Storeroom

Floor Coverings Res/Textile	Vinyl Tiles 8355/B00C/R0032/Floor Coverings Res/Textile/S9	8m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
						Chrysotile (white asbestos)

B00C - R0010 - Duplicating Workroom

Ceiling Structures/Linings	Flat AC Sheeting 8355/B00C/R0013/Ceiling Structures/Linings/S12	31m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
						Chrysotile (white asbestos) , Amosite (brown asbestos)

B00C - R0011 - Toilets-Boys

Ceiling Structures/Linings	Flat AC Sheeting 8355/B00C/R0013/Ceiling Structures/Linings/S12	37m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
						Chrysotile (white asbestos) , Amosite (brown asbestos)
Partition Walls (Cubicles)	Compressed AC Sheet 8355/B00C/R0012/Partition Walls (Cubicles)/S13	12m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
						Chrysotile (white asbestos) , Amosite (brown asbestos)

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No				Test Result		
B00C - R0012 - Toilets-Girls						
Ceiling Structures/Linings	Flat AC Sheeting	37m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	8355/B00C/R0013/Ceiling Structures/Linings/S12			Chrysotile (white asbestos) , Amosite (brown asbestos)		
Partition Walls (Cubicles)	Compressed AC Sheet	40m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	8355/B00C/R0012/Partition Walls (Cubicles)/S13			Chrysotile (white asbestos) , Amosite (brown asbestos)		
B00C - R0013 - Cleaning Supplies Store						
Ceiling Structures/Linings	Flat AC Sheeting	33m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	8355/B00C/R0013/Ceiling Structures/Linings/S12			Chrysotile (white asbestos) , Amosite (brown asbestos)		
B00C - R0014 - Darkroom Space						
Floor Coverings Res/Textile	Vinyl Tiles	8m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	8355/B00C/R0032/Floor Coverings Res/Textile/S9			Chrysotile (white asbestos)		
B00C - R0015 - Movement						
Floor Coverings Res/Textile	Vinyl Tiles	4m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	8355/B00C/R0032/Floor Coverings Res/Textile/S9			Chrysotile (white asbestos)		
B00C - R0016 - Staff - Toilet						
No Asbestos						
B00C - R0017 - Movement						
Wall Linings Internal	Flat AC Sheeting					
	8355/B00C/R0017/Wall Linings Internal/S11			No Asbestos Detected		
B00C - R0018 - Distribution Board Cupboard						
Note: No inspection of live electrical installation.						
Wall Linings Internal	Flat AC Sheeting	6m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	8355/B00C/R0019/Wall Linings Internal/S10			Chrysotile (white asbestos) , Amosite (brown asbestos)		
Ceiling Structures/Linings	Flat AC Sheeting	1m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	8355/B00C/R0018/Ceiling Structures/Linings/S18			Chrysotile (white asbestos) , Amosite (brown asbestos) , Crocidolite (blue asbestos)		
B00C - R0019 - Plant						
Wall Linings Internal	Flat AC Sheeting	6m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	8355/B00C/R0019/Wall Linings Internal/S10			Chrysotile (white asbestos) , Amosite (brown asbestos)		
Ceiling Structures/Linings	Flat AC Sheeting	1m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	8355/B00C/R0018/Ceiling Structures/Linings/S18			Chrysotile (white asbestos) , Amosite (brown asbestos) , Crocidolite (blue asbestos)		
B00C - R0020 - Student Canteen						
No Asbestos						
B00C - R0021 - General Storeroom						
No Asbestos						
B00C - R0022 - Staff - Toilet						
No Asbestos						
B00C - R0023 - Senior Seminar						
No Asbestos						
B00C - R0024 - Commonroom						
No Asbestos						
B00C - R0025 - General Storeroom						
No Asbestos						
B00C - R0026 - Duplicating Workroom						

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
Floor Coverings Res/Textile	Vinyl Tiles	15m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00C/R0032/Floor Coverings Res/Textile/S9					Chrysotile (white asbestos)	
B00C - R0027 - Deputy Principal Office						
No Asbestos						
B00C - R0028 - General Storeroom						
Floor Coverings Res/Textile	Vinyl Tiles	6m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00C/R0032/Floor Coverings Res/Textile/S9					Chrysotile (white asbestos)	
B00C - R0029 - Staff - Toilet						
No Asbestos						
B00C - R0030 - Staff - Toilet						
No Asbestos						
B00C - R0031 - Distribution Board Cupboard				Note: No inspection of live electrical installation.		
No Asbestos						
B00C - R0032 - Movement						
Floor Coverings Res/Textile	Vinyl Tiles	31m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00C/R0032/Floor Coverings Res/Textile/S9					Chrysotile (white asbestos)	
B00C - R0033 - Principal Office						
No Asbestos						
B00C - R0034 - Staff - Toilet						
No Asbestos						
B00C - R0035 - General Storeroom						
No Asbestos						
B00C - R0036 - Administration - Clerical						
No Asbestos						
B00C - R0037 - Movement						
No Asbestos						
B00C - R0038 - Covered Area						
No Asbestos						
B00C - R0039 - Movement						
No Asbestos						
B00C - R0040 - Staff Study						
No Asbestos						
B00C - R0041 - Staff - Toilet						
No Asbestos						
B00C - R0042 - General Storeroom						
No Asbestos						

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00D - Technological & Applied Studies - 1965 - Brick/Block (Brick/Block)**Exterior**

Ceiling Void	No Asbestos Found
Underfloor Void	No Asbestos Found

Interior**B00D - R0004 - Materials Technology L.S.**

No Asbestos

B00D - R0005 - Resource/Project Store

No Asbestos

B00D - R0006 - Materials Store

No Asbestos

B00D - R0007 - Distribution Board Cupboard

Note: No inspection of live electrical installation.

Ceiling Structures/Linings	Flat AC Sheeting	2m2	Throughout	Some Damage / Unsealed (3)	Low (1)	Low Priority (2-3)
8355/B00C/R0018/Ceiling Structures/Linings/S18				Chrysotile (white asbestos) , Amosite (brown asbestos) , Crocidolite (blue asbestos)		

B00D - R0008 - Cleaning Store - Distributed

Floor Coverings Res/Textile	Vinyl Tiles	7m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00D/R0011/Floor Coverings Res/Textile/S14				Chrysotile (white asbestos)		

B00D - R0009 - Computer Store

Floor Coverings Res/Textile	Vinyl Tiles	7m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00D/R0011/Floor Coverings Res/Textile/S14				Chrysotile (white asbestos)		

B00D - R0010 - Computer Learning Space

No Asbestos

B00D - R0011 - Toilets-Girls

Floor Coverings Res/Textile	Vinyl Tiles	4m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00D/R0011/Floor Coverings Res/Textile/S14				Chrysotile (white asbestos)		

B00D - R0012 - Movement

Floor Coverings Res/Textile	Vinyl Tiles	4m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00D/R0011/Floor Coverings Res/Textile/S14				Chrysotile (white asbestos)		

B00D - R0013 - Toilets-Boys

No Asbestos

B00D - R0014 - Study Space

Floor Coverings Res/Textile	Vinyl Tiles	29m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00D/R0011/Floor Coverings Res/Textile/S14				Chrysotile (white asbestos)		

B00D - R0015 - Movement

No Asbestos

B00D - R0016 - Materials Technology L.S.

No Asbestos

B00D - R0017 - Welding Area

No Asbestos

B00D - R0018 - Welding Area

No Asbestos

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00E - Library - 1965 - Brick/Veneer (Brick/Veneer)

Exterior

Ceiling Void	No Asbestos Found
Underfloor Void	No Asbestos Found

Interior

B00E - R0001 - Main Area

No Asbestos

B00E - R0002 - Entry

No Asbestos

B00E - R0003 - Duplicating Workroom

No Asbestos

B00E - R0004 - Librarian

No Asbestos

B00E - R0005 - Audio Visual Workroom

No Asbestos

B00E - R0006 - Movement

No Asbestos

B00E - R0007 - Movement

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00F - Art - 1965 - Brick/Veneer (Brick/Veneer)**Exterior**

Ceiling Void	No Asbestos Found
Underfloor Void	No Asbestos Found

Interior**B00F - R0001 - Resources Store**

Floor Coverings Res/Textile	Vinyl Tiles	7m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00F/R0001/Floor Coverings Res/Textile/S15					Chrysotile (white asbestos)	

B00F - R0002 - Resources Store

Floor Coverings Res/Textile	Vinyl Tiles	7m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00F/R0001/Floor Coverings Res/Textile/S15					Chrysotile (white asbestos)	

B00F - R0003 - Art Learning Space

No Asbestos

B00F - R0004 - Resources Store

Floor Coverings Res/Textile	Vinyl Tiles	7m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00F/R0001/Floor Coverings Res/Textile/S15					Chrysotile (white asbestos)	

B00F - R0005 - Kiln Space

Floor Coverings Res/Textile	Vinyl Tiles	7m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
8355/B00F/R0001/Floor Coverings Res/Textile/S15					Chrysotile (white asbestos)	

B00F - R0006 - Movement

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00G - Multi Purpose Facilities - 1990 - Brick/Block (Brick/Block)**Exterior**

Underfloor Voids - Slab on Ground No Asbestos Found

Ceiling Voids No Asbestos Found

Interior**B00G - M0001 - General Storeroom**

No Asbestos

B00G - M0002 - Control Room

No Asbestos

B00G - R0001 - Shower/Change

Wall Linings Internal Flat AC Sheeting
8355/B00G/R0001/Wall Linings Internal/S1 **No Asbestos Detected**

B00G - R0002 - Movement

No Asbestos

B00G - R0003 - Movement

No Asbestos

B00G - R0004 - Movement

No Asbestos

B00G - R0005 - Stage

No Asbestos

B00G - R0006 - Shower/Change

Wall Linings Internal Flat AC Sheeting
8355/B00G/R0001/Wall Linings Internal/S1 **No Asbestos Detected**

B00G - R0007 - Toilets-Girls

Wall Linings Internal Flat AC Sheeting
8355/B00G/R0001/Wall Linings Internal/S1 **No Asbestos Detected**

Ceiling Structures/Linings Flat AC Sheeting
8355/B00G/R0019/Ceiling Structures/Linings/S3 **No Asbestos Detected**

B00G - R0008 - Cleaning Store - Distributed

No Asbestos

B00G - R0009 - Staff Kitchen

No Asbestos

B00G - R0010 - Shower/Change

No Asbestos

B00G - R0011 - General Storeroom

No Asbestos

B00G - R0012 - Sport Equipment Store

No Asbestos

B00G - R0013 - Plant

No Asbestos

B00G - R0014 - Plant

No Asbestos

B00G - R0015 - Chair Store

No Asbestos

B00G - R0016 - Plant

No Asbestos

B00G - R0017 - Toilets-Disabled

No Asbestos

B00G - R0018 - Main Switchroom

No Asbestos

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
B00G - R0019 - Toilets-Boys						
Wall Linings Internal	Flat AC Sheeting		8355/B00G/R0001/Wall Linings Internal/S1			No Asbestos Detected
Ceiling Structures/Linings	Flat AC Sheeting		8355/B00G/R0019/Ceiling Structures/Linings/S3			No Asbestos Detected
B00G - R0020 - Multi-Purpose Space						
No Asbestos						
B00G - R0021 - Movement						
No Asbestos						

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B001 - Building Services - 1999 - Brick/Block (Brick/Block)

Exterior

Underfloor Voids - Slab on Ground	No Asbestos Found
Ceiling Voids	No Asbestos Found

Interior

B001 - R0002 - Project Store - Type 1

No Asbestos

B001 - R0003 - Covered Outdoor Space

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00K - Multi Purpose Facilities - 2006 - Brick/Veneer (Brick/Veneer)

Exterior

Underfloor Voids - Slab on Ground	No Asbestos Found
Ceiling Voids	No Asbestos Found

Interior

B00K - R0001 - Bulk Store

No Asbestos

B00K - R0002 - Gymnasium

No Asbestos

B00K - R0003 - External Movement

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00L - Science Learning - 2010 - Brick/Veneer (Brick/Veneer)**Exterior**

Ceiling Voids	No Asbestos Found
Underfloor Void	No Asbestos Found

Interior**B00L - R0001 - General Learning Space**

No Asbestos

B00L - R0002 - Science Laboratory

No Asbestos

B00L - R0003 - Preparation

No Asbestos

B00L - R0004 - Apparatus Store

No Asbestos

B00L - R0005 - Chemical Store

No Asbestos

B00L - R0006 - Staff Study

No Asbestos

B00L - R0007 - Seminar - Type 2

No Asbestos

B00L - R0008 - Movement

No Asbestos

B00L - R0009 - Distribution Board Cupboard

Note: No inspection of live electrical installation.

No Asbestos

B00L - R0010 - External Movement

No Asbestos

B00L - R0011 - Outdoor Learning Space - Type 4

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00M - Agricultural Science - 2014 - Metal Shed (Metal Shed)

Exterior

Underfloor Voids - Slab on Ground	No Asbestos Found
Ceiling Voids	No Asbestos Found

Interior

B00M - R0001 - Other-Vacant

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

Demountables

Demountable details as per the AMS records as of 15 Feb 2017.

OS 601 - D10366 - Learning Unit - Standard/Withdrawal : Placement Date - 10/02/2005

Exterior

Step Treads	Compressed AC Sheet	Assumed Asbestos	1.08 m2
Landing	Compressed AC Sheet	Assumed Asbestos	1.2 m2
Eave Lining	Flat AC Sheet	Assumed Asbestos	11.52 m2

Interior

R1 - Entry

End wall panel	Flat AC Sheet	Assumed Asbestos	18 m2
Ceiling	Flat AC Sheet	Assumed Asbestos	8 m2

R2 - General Learning Space

End wall panel	Flat AC Sheet	Assumed Asbestos	18 m2
Ceiling	Flat AC Sheet	Assumed Asbestos	55 m2

R3 - Store

Ceiling	Flat AC Sheet	Assumed Asbestos	10 m2
---------	---------------	------------------	-------

OS 601 - D13923 - Learning Unit - Standard/Withdrawal : Placement Date - 30/06/1995

Exterior

Step Treads	Compressed AC Sheet	Assumed Asbestos	1.08 m2
Landing	Compressed AC Sheet	Assumed Asbestos	1.2 m2
Eave Lining	Flat AC Sheet	Assumed Asbestos	11.52 m2

Interior

R1 - Entry

End wall panel	Flat AC Sheet	Assumed Asbestos	18 m2
Ceiling	Flat AC Sheet	Assumed Asbestos	8 m2

R2 - General Learning Space

End wall panel	Flat AC Sheet	Assumed Asbestos	18 m2
Ceiling	Flat AC Sheet	Assumed Asbestos	55 m2

R3 - Store

Ceiling	Flat AC Sheet	Assumed Asbestos	10 m2
---------	---------------	------------------	-------

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

Listing of Electronic Attachments as of 22/03/2017

There are no asbestos related file attachment(s) for this school.

2017