


Asbestos Register

(Hazardous Materials and Risk Assessment)

School : Glenorie Public School (2012)
Region : Northern Sydney
State Electorate : Hawkesbury
Local Government Area : Hornsby

Initial Survey : Noel Arnold & Associates : 10 - Mar - 2008
Reviewed By : Parsons Brinckerhoff : 13 - Sep - 2016



2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00A - Administration/Library - 1980 - Brick/Block (Brick/Block)

Exterior

Underfloor Voids - Slab on Ground	No Asbestos Found					
Ceiling Voids - Raked Ceiling	No Asbestos Found					
Eaves Linings	Flat AC Sheeting	40m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)
	2012/B00C/Eaves Linings/S9					Chrysotile (white asbestos)

Interior

B00A - R0001 - Toilets - Girls

Partition Walls (Cubicles)	Compressed AC Sheet	4m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)
	2012/B00A/R0001/Partition Walls (Cubicles)/S1					Chrysotile (white asbestos)

B00A - R0002 - General Storeroom

No Asbestos

B00A - R0003 - Toilets - Boys

Partition Walls (Cubicles)	Compressed AC Sheet	4m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)
	2012/B00A/R0001/Partition Walls (Cubicles)/S1					Chrysotile (white asbestos)

B00A - R0004 - Staff Toilet

No Asbestos

B00A - R0005 - Cleaning Distributed Store

Ceiling Structures/Linings	Flat AC Sheeting	1m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)
						Assumed Asbestos - Height Restriction

B00A - R0006 - Drinking Facilities

No Asbestos

B00A - R0007 - Movement

No Asbestos

B00A - R0008 - Movement

No Asbestos

B00A - R0009 - Movement

No Asbestos

B00A - R0010 - Distribution Board

Note: No inspection of live electrical installation.

No Asbestos

B00A - R0011 - Reading Area

No Asbestos

B00A - R0012 - K.L.A. Store

No Asbestos

B00A - R0013 - K.L.A. Store

No Asbestos

B00A - R0014 - Reading Area

No Asbestos

B00A - R0015 - Communications Room

No Asbestos

B00A - R0016 - Library Office/Workroom

No Asbestos

B00A - R0017 - Library Office/Workroom

No Asbestos

B00A - R0018 - Deputy Principal

No Asbestos

B00A - R0019 - Principal

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

No Asbestos

B00A - R0020 - Security Store

Floor Coverings Res/Textile Vinyl Tiles

2012/B00B/R0011/Floor Coverings Res/Textile/S2

No Asbestos Detected

B00A - R0021 - Duplicating Workroom

No Asbestos

B00A - R0022 - Clerical Office

No Asbestos

B00A - R0023 - Clerical Office

No Asbestos

B00A - R0024 - Entry Vestibule

No Asbestos

B00A - R0025 - Interview

No Asbestos

B00A - R0026 - Sick Bay

No Asbestos

B00A - R0027 - Disabled Toilet

No Asbestos

B00A - R0028 - Cleaning Distributed Store

No Asbestos

B00A - R0029 - Disabled Toilet

No Asbestos

B00A - R0030 - Movement

No Asbestos

B00A - R0031 - Stairs

No Asbestos

B00A - R0032 - Stairs

No Asbestos

B00A - R1001 - Movement

No Asbestos

B00A - R1002 - Movement

No Asbestos

B00A - R1003 - Staff Room

No Asbestos

B00A - R1004 - Stairs

No Asbestos

B00A - R1005 - Stairs

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00B - Communal Facilities - 1980 - Brick/Veneer (Brick/Veneer)**Exterior**

Ceiling Voids - Raked Ceiling	No Asbestos Found					
Underfloor Voids - Slab on Ground	No Asbestos Found					
Eaves Linings	Flat AC Sheeting	40m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)
	2012/B00C/Eaves Linings/S9					Chrysotile (white asbestos)

Interior**B00B - R0002 - Raised Platform**

No Asbestos

B00B - R0003 - Hall Chair Store

No Asbestos

B00B - R0004 - Toilets - Girls

Ceiling Structures/Linings	Flat AC Sheeting	6m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)
	2012/B00B/R0016/Ceiling Structures/Linings/S4					Chrysotile (white asbestos)

B00B - R0005 - Movement

No Asbestos

B00B - R0006 - General Storeroom

No Asbestos

B00B - R0007 - Uniform Shop

No Asbestos

B00B - R0008 - Main Switch Board

No Asbestos

B00B - R0009 - Cleaning Distributed Store

Wall Linings Internal	Flat AC Sheeting	8m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)
	2012/B00B/R0010/Wall Linings Internal/S3					Chrysotile (white asbestos)

B00B - R0010 - Cleaning Supplies

Wall Linings Internal	Flat AC Sheeting	12m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)
	2012/B00B/R0010/Wall Linings Internal/S3					Chrysotile (white asbestos)

Floor Coverings Res/Textile	Vinyl Tiles					
	2012/B00B/R0011/Floor Coverings Res/Textile/S2					No Asbestos Detected

B00B - R0011 - Cleaning Supplies

Floor Coverings Res/Textile	Vinyl Tiles					
	2012/B00B/R0011/Floor Coverings Res/Textile/S2					No Asbestos Detected

B00B - R0012 - General Assistant/Bulk Store

Wall Linings Internal	Flat AC Sheeting	20m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)
	2012/B00B/R0010/Wall Linings Internal/S3					Chrysotile (white asbestos)

Floor Coverings Res/Textile	Vinyl Tiles					
	2012/B00B/R0011/Floor Coverings Res/Textile/S2					No Asbestos Detected

B00B - R0013 - P.E. Store

Wall Linings Internal	Flat AC Sheeting	30m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)
	2012/B00B/R0010/Wall Linings Internal/S3					Chrysotile (white asbestos)

B00B - R0014 - Sports Store

Wall Linings Internal	Flat AC Sheeting	40m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)
	2012/B00B/R0010/Wall Linings Internal/S3					Chrysotile (white asbestos)

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
B00B - R0015 - Movement						
No Asbestos						
B00B - R0016 - Toilets - Girls						
Ceiling Structures/Linings	Flat AC Sheeting	7m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)
2012/B00B/R0016/Ceiling Structures/Linings/S4					Chrysotile (white asbestos)	
B00B - R0017 - Movement						
No Asbestos						
B00B - R0018 - Movement						
No Asbestos						
B00B - R0019 - Canteen						
Wall Linings Internal	Flat AC Sheeting	20m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)
2012/B00B/R0010/Wall Linings Internal/S3					Chrysotile (white asbestos)	
B00B - R0020 - Canteen Office/Store						
Ceiling Structures/Linings	Flat AC Sheeting	4m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)
2012/B00B/R0016/Ceiling Structures/Linings/S4					Chrysotile (white asbestos)	
B00B - R0021 - Staff Toilet						
No Asbestos						
B00B - R0022 - Canteen Office/Store						
Wall Linings Internal	Flat AC Sheeting	10m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)
2012/B00B/R0010/Wall Linings Internal/S3					Chrysotile (white asbestos)	
B00B - R0023 - Communal Space						
No Asbestos						
B00B - R0024 - Covered Outdoor Learning Area						
No Asbestos						

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00C - General Learning - 1980 - Brick/Block (Brick/Block)

Exterior

Ceiling Voids - Raked Ceiling	No Asbestos Found					
Underfloor Voids - Slab on Ground	No Asbestos Found					
Eaves Linings	Flat AC Sheeting	50m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)
	2012/B00C/Eaves Linings/S9					Chrysotile (white asbestos)

Interior

B00C - R0001 - General Storeroom

No Asbestos

B00C - R0002 - Craft Store

Floor Coverings Res/Textile	Vinyl Tiles					
	2012/B00B/R0011/Floor Coverings Res/Textile/S2					No Asbestos Detected

B00C - R0003 - Cleaning Distributed Store

Floor Coverings Res/Textile	Vinyl Tiles					
	2012/B00B/R0011/Floor Coverings Res/Textile/S2					No Asbestos Detected

B00C - R0004 - General Storeroom

No Asbestos

B00C - R0005 - Practical Activities - 1hb

No Asbestos

B00C - R0006 - Home Base

No Asbestos

B00C - R0007 - Home Base Store

Floor Coverings Res/Textile	Vinyl Tiles					
	2012/B00B/R0011/Floor Coverings Res/Textile/S2					No Asbestos Detected

B00C - R0008 - Withdrawal Space - 1hb

No Asbestos

B00C - R0009 - Home Base

No Asbestos

B00C - R0010 - Home Base Store

Floor Coverings Res/Textile	Vinyl Tiles					
	2012/B00B/R0011/Floor Coverings Res/Textile/S2					No Asbestos Detected

B00C - R0011 - Movement

Wall Linings Internal	Flat AC Sheeting	1m2	Above door, infill panels	Good Condition (1)	Low (1)	Low Priority (2-3)
	2012/B00B/R0010/Wall Linings Internal/S3					Chrysotile (white asbestos)

B00C - R0012 - Home Base

No Asbestos

B00C - R0013 - Home Base Store

Floor Coverings Res/Textile	Vinyl Tiles					
	2012/B00B/R0011/Floor Coverings Res/Textile/S2					No Asbestos Detected

B00C - R0014 - Withdrawal Space - 1hb

No Asbestos

B00C - R0015 - Home Base Store

Floor Coverings Res/Textile	Vinyl Tiles					
	2012/B00B/R0011/Floor Coverings Res/Textile/S2					No Asbestos Detected

B00C - R0016 - Home Base

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
No Asbestos						
B00C - R0017 - Movement						
Wall Linings Internal	Flat AC Sheeting	2m2	Above door, infill panels	Good Condition (1)	Low (1)	Low Priority (2-3)
2012/B00B/R0010/Wall Linings Internal/S3					Chrysotile (white asbestos)	
B00C - R0018 - Special Programs Room						
No Asbestos						
B00C - R0019 - Toilets - Boys						
Wall Linings Internal	Flat AC Sheeting	20m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)
2012/B00B/R0010/Wall Linings Internal/S3					Chrysotile (white asbestos)	
B00C - R0020 - Toilets - Girls						
Wall Linings Internal	Flat AC Sheeting	20m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)
2012/B00B/R0010/Wall Linings Internal/S3					Chrysotile (white asbestos)	
B00C - R0021 - Movement						
Wall Linings Internal	Flat AC Sheeting	1m2	Above door & windows, infill panel	Good Condition (1)	Low (1)	Low Priority (2-3)
2012/B00B/R0010/Wall Linings Internal/S3					Chrysotile (white asbestos)	
B00C - R0022 - Practical Activities - 1hb						
No Asbestos						
B00C - R0023 - Craft Store						
No Asbestos						
B00C - R0024 - Distribution Board						
					Note: No inspection of live electrical installation.	
Floor Coverings Res/Textile	Vinyl Tiles					
2012/B00B/R0011/Floor Coverings Res/Textile/S2					No Asbestos Detected	
B00C - R0025 - Communal/Performance Store						
Floor Coverings Res/Textile	Vinyl Tiles					
2012/B00B/R0011/Floor Coverings Res/Textile/S2					No Asbestos Detected	
B00C - R0026 - Craft Store						
No Asbestos						
B00C - R0027 - Movement						
Wall Linings Internal	Flat AC Sheeting	1m2	Above door, infill panels	Good Condition (1)	Low (1)	Low Priority (2-3)
2012/B00B/R0010/Wall Linings Internal/S3					Chrysotile (white asbestos)	
B00C - R0028 - Movement						
Wall Linings Internal	Flat AC Sheeting	3m2	Above door, infill panels	Good Condition (1)	Low (1)	Low Priority (2-3)
2012/B00B/R0010/Wall Linings Internal/S3					Chrysotile (white asbestos)	
B00C - R0029 - Withdrawal Space - 1hb						
No Asbestos						
B00C - R0030 - Staff Toilet						
No Asbestos						
B00C - R0031 - Staff Toilet						
No Asbestos						
B00C - R0032 - Movement						
Wall Linings Internal	Flat AC Sheeting	1m2	Above door, infill panels	Good Condition (1)	Low (1)	Low Priority (2-3)
2012/B00B/R0010/Wall Linings Internal/S3					Chrysotile (white asbestos)	

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00D - General Learning/Tiered Learning - 1980 - Brick/Veneer (Brick/Veneer)

Exterior

Underfloor Voids - Slab on Ground	No Asbestos Found					
Ceiling Voids - Raked Ceiling	No Asbestos Found					
Eaves Linings	Flat AC Sheeting	40m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)
	2012/B00C/Eaves Linings/S9					Chrysotile (white asbestos)

Interior

B00D - M0001 - Plant

No Asbestos

B00D - R0001 - Special Programs Room

No Asbestos

B00D - R0002 - Toilets - Boys

Wall Linings Internal	Flat AC Sheeting	20m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)
	2012/B00B/R0010/Wall Linings Internal/S3					Chrysotile (white asbestos)

B00D - R0003 - Toilets - Girls

Wall Linings Internal	Flat AC Sheeting	20m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)
	2012/B00B/R0010/Wall Linings Internal/S3					Chrysotile (white asbestos)

B00D - R0004 - Special Programs Room

No Asbestos

B00D - R0005 - Home Base

No Asbestos

B00D - R0006 - Home Base Store

Floor Coverings Res/Textile	Vinyl Tiles					
	2012/B00B/R0011/Floor Coverings Res/Textile/S2					No Asbestos Detected

B00D - R0007 - Withdrawal Space - 1hb

No Asbestos

B00D - R0008 - Home Base Store

Floor Coverings Res/Textile	Vinyl Tiles					
	2012/B00B/R0011/Floor Coverings Res/Textile/S2					No Asbestos Detected

B00D - R0009 - Home Base

No Asbestos

B00D - R0010 - Movement

Wall Linings Internal	Flat AC Sheeting	4m2	Above door, infill panels	Good Condition (1)	Low (1)	Low Priority (2-3)
	2012/B00B/R0010/Wall Linings Internal/S3					Chrysotile (white asbestos)

B00D - R0011 - Home Base

No Asbestos

B00D - R0012 - Home Base Store

Floor Coverings Res/Textile	Vinyl Tiles					
	2012/B00B/R0011/Floor Coverings Res/Textile/S2					No Asbestos Detected

B00D - R0013 - Withdrawal Space - 1hb


No Asbestos

B00D - R0014 - Home Base

No Asbestos

B00D - R0015 - Home Base Store

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
Floor Coverings Res/Textile	Vinyl Tiles					
	2012/B00B/R0011/Floor Coverings Res/Textile/S2					No Asbestos Detected
B00D - R0016 - Practical Activities - 1hb						
No Asbestos						
B00D - R0017 - General Storeroom						
No Asbestos						
B00D - R0018 - Cleaning Distributed Store						
Floor Coverings Res/Textile	Vinyl Tiles					
	2012/B00B/R0011/Floor Coverings Res/Textile/S2					No Asbestos Detected
B00D - R0019 - Craft Store						
No Asbestos						
B00D - R0020 - Craft Store						
No Asbestos						
B00D - R0021 - Movement						
Wall Linings Internal	Flat AC Sheeting	4m2	Above door, infill panels	Good Condition (1)	Low (1)	Low Priority (2-3)
	2012/B00B/R0010/Wall Linings Internal/S3					Chrysotile (white asbestos)
B00D - R0022 - Practical Activities - 1hb						
No Asbestos						
B00D - R0023 - Craft Store						
No Asbestos						
B00D - R0024 - Craft Store						
Floor Coverings Res/Textile	Vinyl Tiles					
	2012/B00B/R0011/Floor Coverings Res/Textile/S2					No Asbestos Detected
B00D - R0025 - Distribution Board						
					Note: No inspection of live electrical installation.	
Floor Coverings Res/Textile	Vinyl Tiles					
	2012/B00B/R0011/Floor Coverings Res/Textile/S2					No Asbestos Detected
B00D - R0026 - General Storeroom						
No Asbestos						
B00D - R0027 - Movement						
Wall Linings Internal	Flat AC Sheeting	4m2	Above door & windows, infill panel	Good Condition (1)	Low (1)	Low Priority (2-3)
	2012/B00B/R0010/Wall Linings Internal/S3					Chrysotile (white asbestos)
B00D - R0028 - Movement						
Wall Linings Internal	Flat AC Sheeting	4m2	Above door & windows, infill panels	Good Condition (1)	Low (1)	Low Priority (2-3)
	2012/B00B/R0010/Wall Linings Internal/S3					Chrysotile (white asbestos)



Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00E - General Learning/Tiered Learning - 1980 - Brick/Veneer (Brick/Veneer)

Exterior

Underfloor Voids - Slab on Ground No Asbestos Found

Ceiling Voids - Raked Ceiling Non Accessible Area
- Height Restriction >3m.

Interior

B00E - M0001 - Plant

Non Accessible

B00E - R0001 - Personal Effects Storage

Ceiling Structures/Linings	Flat AC Sheeting	14m2	North facing, East facing	Good Condition (1)	Low (1)	Low Priority (2-3)
----------------------------	------------------	------	---------------------------	--------------------	---------	--------------------

Assumed Asbestos - Height Restriction >3m.

Wall Linings Internal	Flat AC Sheeting	14m2	Above windows, infill panels	Good Condition (1)	Low (1)	Low Priority (2-3)
-----------------------	------------------	------	------------------------------	--------------------	---------	--------------------

Assumed Asbestos - Height Restriction >3m.

B00E - R0002 - Special Programs Room

No Asbestos

B00E - R0003 - Teachers Aide Special Ed

No Asbestos

B00E - R0004 - Toilets - Boys/Girls

Wall Linings Internal	Flat AC Sheeting	14m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)
-----------------------	------------------	------	--------------	--------------------	---------	--------------------

2012/B00E/R0004/Wall Linings Internal/S5

Chrysotile (white asbestos)

B00E - R0005 - Practical Activities - 1hb

No Asbestos

B00E - R0006 - Home Base

No Asbestos

B00E - R0007 - Movement

Wall Linings Internal	Flat AC Sheeting	16m2	Above windows, infill panels	Good Condition (1)	Low (1)	Low Priority (2-3)
-----------------------	------------------	------	------------------------------	--------------------	---------	--------------------

Assumed Asbestos - Height Restriction >3m.

B00E - R0008 - Home Base

No Asbestos

B00E - R0009 - Entry Vestibule

Floor Coverings Res/Textile	Vinyl Tiles				
					No Asbestos Detected

2012/B00B/R0011/Floor Coverings Res/Textile/S2

B00E - R0010 - Cleaning Distributed Store

Floor Coverings Res/Textile	Vinyl Tiles				
					No Asbestos Detected

2012/B00B/R0011/Floor Coverings Res/Textile/S2

B00E - R0011 - Home Base

No Asbestos

B00E - R0012 - Home Base Store

Floor Coverings Res/Textile	Vinyl Tiles				
					No Asbestos Detected

2012/B00B/R0011/Floor Coverings Res/Textile/S2

B00E - R0013 - Practical Activities - 1hb

No Asbestos

B00E - R0014 - Sports Store

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
Floor Coverings Res/Textile	Vinyl Tiles					
	2012/B00B/R0011/Floor Coverings Res/Textile/S2				No Asbestos Detected	
B00E - R0015 - Craft Store						
Floor Coverings Res/Textile	Vinyl Tiles					
	2012/B00B/R0011/Floor Coverings Res/Textile/S2				No Asbestos Detected	

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00F - General Learning/Pupil Facilities - 1906 - Brick/Block (Brick/Block)

Exterior

Ceiling Voids - Raked Ceiling
 Non Accessible Area
 - Height Restriction >3m.

Underfloor Voids - Slab on Ground
 No Asbestos Found

Interior

B00F - R0001 - Personal Effects Storage

No Asbestos

B00F - R0002 - Practical Activities - 1hb

No Asbestos

B00F - R0003 - Home Base

Ceiling Structures/Linings	Flat AC Sheeting	0.5m2	Access hatch	Good Condition (1)	Low (1)	Low Priority (2-3)
----------------------------	------------------	-------	--------------	--------------------	---------	--------------------

Assumed Asbestos - Height Restriction >3m.

B00F - R0004 - Home Base Store

Floor Coverings Res/Textile	Vinyl Tiles					No Asbestos Detected
2012/B00B/R0011/Floor Coverings Res/Textile/S2						

B00F - R0005 - Withdrawal Space - 1hb

No Asbestos

B00F - R0006 - Distribution Board

Note: No inspection of live electrical installation.

No Asbestos

B00F - R0007 - Toilets - Boys/Girls

Wall Linings Internal	Flat AC Sheeting	8m2	East facing, West facing	Good Condition (1)	Low (1)	Low Priority (2-3)
-----------------------	------------------	-----	-----------------------------	--------------------	---------	--------------------

2012/B00B/R0010/Wall Linings Internal/S3

Chrysotile (white asbestos)

B00F - R0008 - Movement

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00G - General Learning - 1957 - Timber (Timber)

Exterior

Underfloor Voids - Packing to Floor Joists
 Non Accessible Area
 - Height Restriction < 0.3m.

Ceiling Voids - Raked Ceiling
 Non Accessible Area
 - Height Restriction >3m.

Interior

B00G - R0001 - Practical Activities - 1hb

Floor Coverings Res/Textile Vinyl Tiles
 2012/B00G/R0001/Floor Coverings Res/Textile/S6
No Asbestos Detected

B00G - R0002 - Home Base

Wall Linings Internal	Flat AC Sheeting	2m2	Southwest corner, lower portion	Good Condition (1)	Low (1)	Low Priority (2-3)
-----------------------	------------------	-----	---------------------------------	--------------------	---------	--------------------

2012/B00G/R0002/Wall Linings Internal/S7
Chrysotile (white asbestos)

B00G - R0003 - Personal Effects Storage

Ceiling Structures/Linings	Flat AC Sheeting	18m2	All surfaces	Minimal Damage (2)	Low (1)	Low Priority (2-3)
----------------------------	------------------	------	--------------	--------------------	---------	--------------------

2012/B00G/R0003/Ceiling Structures/Linings/S8
Chrysotile (white asbestos) , Amosite (brown asbestos)

B00G - R0004 - General Storeroom

Ceiling Structures/Linings	Flat AC Sheeting	6m2	Upper portion	Good Condition (1)	Low (1)	Low Priority (2-3)
----------------------------	------------------	-----	---------------	--------------------	---------	--------------------

2012/B00G/R0003/Ceiling Structures/Linings/S8
Chrysotile (white asbestos) , Amosite (brown asbestos)

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00H - Other - Community Use - 1970 - Brick/Block (Brick/Block)

Exterior

Ceiling Void	Requires Inspection
Underfloor Void	Requires Inspection

Interior

B00H - R0001 - Other-Community Use

Recently Modified Space	Requires Inspection
-------------------------	---------------------

B00H - R0002 - Other-Community Use

Recently Modified Space	Requires Inspection
-------------------------	---------------------

B00H - R0003 - Other-Community Use

Recently Modified Space	Requires Inspection
-------------------------	---------------------

B00H - R0004 - Other-Community Use

Recently Modified Space	Requires Inspection
-------------------------	---------------------

B00H - R0005 - Other-Community Use

Recently Modified Space	Requires Inspection
-------------------------	---------------------

B00H - R0006 - Other-Community Use

Recently Modified Space	Requires Inspection
-------------------------	---------------------

B00H - R0007 - Other-Community Use

Recently Modified Space	Requires Inspection
-------------------------	---------------------

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

Demountables

There are no Demountable(s) located at this school as per the AMS records as of 15 Feb 2017.

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

Listing of Electronic Attachments as of 22/03/2017

There are no asbestos related file attachment(s) for this school.

2017