


# Asbestos Register

(Hazardous Materials and Risk Assessment)

**School :** Glen William Public School (2020)  
**Region :** Hunter/Central Coast  
**State Electorate :** Upper Hunter  
**Local Government Area :** Dungog

**Initial Survey :** Noel Arnold & Associates : 19 - May - 2008  
**Reviewed By :** AECOM : 29 - Jun - 2016



# 2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No				Test Result		

**B00A - General Learning/Pupil Facilities - 1890 - Brick/Block (Brick/Block)****Exterior**

Ceiling Voids - Flat Roof	Non Accessible Area - Area inaccessible no void entrance located.					
Underfloor Voids - Packing to Floor Joists	Non Accessible Area - Area inaccessible no void entrance located.					
Eaves Linings	Flat AC Sheeting	10m2	West, Lower portion	Good Condition (1)	Low (1)	Low Priority (2-3)
	2020/B00A/Eaves Linings/S2					<b>Chrysotile (white asbestos)</b>

**Interior****B00A - R0001 - Clerical Office**

Ceiling Structures/Linings	Flat AC Sheeting	17m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	2020/B00A/R0001/Ceiling Structures/Linings/S1					<b>Chrysotile (white asbestos)</b>

**B00A - R0004 - Movement**

Ceiling Structures/Linings	Flat AC Sheeting	2m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	2020/B00A/R0001/Ceiling Structures/Linings/S1					<b>Chrysotile (white asbestos)</b>

**B00A - R0005 - Staff Toilet**

Ceiling Structures/Linings	Flat AC Sheeting	2m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	2020/B00A/R0001/Ceiling Structures/Linings/S1					<b>Chrysotile (white asbestos)</b>

Wall Linings Internal	Flat AC Sheeting	2m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	2020/B00A/R0001/Ceiling Structures/Linings/S1					<b>Chrysotile (white asbestos)</b>

**B00A - R0006 - Toilets - Girls**

Ceiling Structures/Linings	Flat AC Sheeting	4m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	2020/B00A/R0001/Ceiling Structures/Linings/S1					<b>Chrysotile (white asbestos)</b>

Wall Linings Internal	Flat AC Sheeting	4m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	2020/B00A/R0001/Ceiling Structures/Linings/S1					<b>Chrysotile (white asbestos)</b>

**B00A - R0007 - Toilets - Boys**

Ceiling Structures/Linings	Flat AC Sheeting	6m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	2020/B00A/R0001/Ceiling Structures/Linings/S1					<b>Chrysotile (white asbestos)</b>

Wall Linings Internal	Flat AC Sheeting	6m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	2020/B00A/R0001/Ceiling Structures/Linings/S1					<b>Chrysotile (white asbestos)</b>

**B00A - R0008 - General Storeroom**

Ceiling Structures/Linings	Flat AC Sheeting	6m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	2020/B00A/R0001/Ceiling Structures/Linings/S1					<b>Chrysotile (white asbestos)</b>

**B00A - R0009 - Practical Activities - 1hb**

Ceiling Structures/Linings	Flat AC Sheeting	13m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	2020/B00A/R0001/Ceiling Structures/Linings/S1					<b>Chrysotile (white asbestos)</b>

**B00A - R0010 - Practical Activities - 1hb**

No Asbestos

**B00A - R0011 - Movement**

No Asbestos

**B00A - R0012 - Movement**

No Asbestos

**B00A - R0013 - Home Base**

No Asbestos

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B00B - Pupil Facilities - 1991 - Timber (Timber)**

**Exterior**

Underfloor Voids - Slab on Ground	Non Accessible Area - Area inaccessible
-----------------------------------	--

Ceiling Voids	No Asbestos Found
---------------	-------------------

**Interior**

**B00B - R0001 - Canteen Covered Area**

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B00C - Communal Facilities - 1988 - Timber Shed (Timber Shed)**

**Exterior**

Underfloor Voids - Slab on Ground      Non Accessible Area  
 - Area inaccessible

Ceiling Voids      No Asbestos Found

**Interior**

**B00C - R0001 - Sports Store**

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B00D - Library - 2011 - Fibre Cement Clad (Fibre Cement Clad)**

**Exterior**

Underfloor Voids - Packing to Floor Joists      No Asbestos Found

Ceiling Voids      No Asbestos Found

**Interior**

**B00D - R0001 - External Movement**

No Asbestos

**B00D - R0002 - Reading Area**

No Asbestos

**B00D - R0003 - K.L.A. Store**

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B00E - Building Services - 2010 - Brick/Veneer (Brick/Veneer)**

**Exterior**

Underfloor Voids - Slab on Ground      Non Accessible Area  
 - Area inaccessible

Ceiling Voids      No Asbestos Found

**Interior**

**B00E - R0001 - General Assistant/Bulk Store**

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

## Demountables

**Demountable details as per the AMS records as of 15 Feb 2017.**

**OS 601 - D14877 - Learning Unit - Standard/Withdrawal : Placement Date - 12/11/1998**

### Exterior

Step Treads	Compressed AC Sheet	Assumed Asbestos		1.08 m2
Landing	Compressed AC Sheet	Assumed Asbestos		1.2 m2
Eave Lining	Flat AC Sheet	Assumed Asbestos		11.52 m2

### Interior

#### R1 - Entry

End wall panel	Flat AC Sheet	Assumed Asbestos		18 m2
Ceiling	Flat AC Sheet	Assumed Asbestos		8 m2

#### R2 - General Learning Space

End wall panel	Flat AC Sheet	Assumed Asbestos		18 m2
Ceiling	Flat AC Sheet	Assumed Asbestos		55 m2

#### R3 - Store

Ceiling	Flat AC Sheet	Assumed Asbestos		10 m2
---------	---------------	------------------	--	-------

**OS 500 - D18120 - Admin - Library : Placement Date - 1/05/2002**

### Exterior

Step Treads	Compressed AC Sheet	Assumed Asbestos		1.08 m2
Landing	Compressed AC Sheet	Assumed Asbestos		1.2 m2
Eave Lining	Flat AC Sheet	Assumed Asbestos		20.16 m2

### Interior

#### R1 - Entry

End wall panel	Flat AC Sheet	Assumed Asbestos		18 m2
Ceiling	Flat AC Sheet	Assumed Asbestos		13 m2

#### R2 - Principal

Ceiling	Flat AC Sheet	Assumed Asbestos		18 m2
---------	---------------	------------------	--	-------

#### R3 - Staff Room/Kitchen

Ceiling	Flat AC Sheet	Assumed Asbestos		19 m2
---------	---------------	------------------	--	-------

#### R4 - Clerical Office

Ceiling	Flat AC Sheet	Assumed Asbestos		18 m2
---------	---------------	------------------	--	-------

#### R5 - Library

Ceiling	Flat AC Sheet	Assumed Asbestos		54 m2
---------	---------------	------------------	--	-------

#### R6 - Storeroom

Ceiling	Flat AC Sheet	Assumed Asbestos		0 m2
---------	---------------	------------------	--	------

#### R7 - Staff Toilet

Toilet partitions	Compressed AC Sheet	Assumed Asbestos		6 m2
End wall panel	Flat AC Sheet	Assumed Asbestos		18 m2
Ceiling	Flat AC Sheet	Assumed Asbestos		4 m2

#### R8 - Entry to toilet

Ceiling	Flat AC Sheet	Assumed Asbestos		0 m2
---------	---------------	------------------	--	------

**OS 844 - D18136 - Country Toilet - Reltc - Boys/Girls : Placement Date - 29/03/2001**

### Exterior

Step Treads	Compressed AC Sheet	Assumed Asbestos		1.08 m2
Landing	Compressed AC Sheet	Assumed Asbestos		1.2 m2
Eave Lining	Flat AC Sheet	Assumed Asbestos		2.88 m2

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
<b>Interior</b>						
<b>R1 - Staff Toilet</b>						
End wall panel	Flat AC Sheet	Assumed Asbestos				18 m2
Ceiling	Flat AC Sheet	Assumed Asbestos				9 m2
<b>R2 - Staff Toilet</b>						
End wall panel	Flat AC Sheet	Assumed Asbestos				18 m2
Ceiling	Flat AC Sheet	Assumed Asbestos				9 m2

2017



Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

*Listing of Electronic Attachments as of 22/03/2017*

**There are no asbestos related file attachment(s) for this school.**

2017