

Asbestos Register

(Hazardous Materials and Risk Assessment)



School : Gum Flat Public School (2100)
Region : New England
State Electorate : Northern Tablelands
Local Government Area : Inverell

Initial Survey : Noel Arnold & Associates : 21 - May - 2008
Reviewed By : AECOM : 29 - Apr - 2016



2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00A - General Learning/Administration - 1965 - Brick/Veneer (Brick/Veneer)

Exterior

Ceiling Voids - Raked Ceiling	Non Accessible Area - Height Restriction AR0009, 3.4m					
Underfloor Voids - Slab on Ground	Non Accessible Area - Area inaccessible, slab on ground, no access points.					
Eaves Linings	Flat AC Sheeting 2100/B00A/Eaves Linings/S1					No Asbestos Detected

Interior

B00A - R0001 - Staff Room

No Asbestos

B00A - R0005 - Home Base

No Asbestos

B00A - R0006 - Practical Activity Area

No Asbestos

B00A - R0007 - Covered Outdoor Learning Area

No Asbestos

B00A - R0008 - Withdrawal - Pre

No Asbestos

B00A - R0009 - Principal

No Asbestos

B00A - R0010 - Clerical Office

No Asbestos

B00A - R0011 - Duplicating Workroom

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00B - Communal Facilities/General Learning - 1945 - Timber (Timber)

Exterior

Ceiling Voids - Raked Ceiling
 Non Accessible Area
 - Area inaccessible no access points.

Underfloor Voids - Packing to Floor Joists
 No Asbestos Found

Interior

B00B - R0001 - Sports Store

No Asbestos

B00B - R0002 - Practical Activities - 1hb

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00D - Special Purpose - 1883 - Timber (Timber)

Exterior

Ceiling Voids - Raked Ceiling	No Asbestos Found					
Underfloor Voids - Slab on Ground	No Asbestos Found					
Eaves Linings	Flat AC Sheeting 2100/B00D/Eaves Linings/S5					No Asbestos Detected
Eaves Linings	Flat AC Sheeting	6m2	Upper eaves linings, throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
Assumed Asbestos - Height Restriction 4.5m						

Interior

B00D - R0001 - Special Programs Room

No Asbestos

B00D - R0002 - General Storeroom

In-fill-panel	Flat AC Sheeting 2100/B00D/R0002/In Fill Panel to Window/S2					No Asbestos Detected
---------------	--	--	--	--	--	-----------------------------

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00H - Communal Facilities - 1966 - Brick/Block (Brick/Block)

Exterior

Ceiling Voids - Flat Roof	Non Accessible Area - Area inaccessible, no access points.					
Underfloor Voids - Slab on Ground	Non Accessible Area - Area inaccessible, slab on ground, no access points.					
Eaves Linings	Flat AC Sheeting 2100/B00H/R0004/Ceiling Structures/Linings/S4					No Asbestos Detected

Interior

B00H - R0002 - Garden Store

Wall Linings Internal	Flat AC Sheeting 2100/B00H/R0004/Wall Linings Internal/S3					No Asbestos Detected
Ceiling Structures/Linings	Flat AC Sheeting 2100/B00H/R0004/Ceiling Structures/Linings/S4					No Asbestos Detected

B00H - R0003 - Sports Store

Wall Linings Internal	Flat AC Sheeting 2100/B00H/R0004/Wall Linings Internal/S3					No Asbestos Detected
Ceiling Structures/Linings	Flat AC Sheeting 2100/B00H/R0004/Ceiling Structures/Linings/S4					No Asbestos Detected

B00H - R0004 - Sports Store

Wall Linings Internal	Flat AC Sheeting 2100/B00H/R0004/Wall Linings Internal/S3					No Asbestos Detected
Ceiling Structures/Linings	Flat AC Sheeting 2100/B00H/R0004/Ceiling Structures/Linings/S4					No Asbestos Detected

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00I - Pupil Facilities - 1999 - Brick/Veneer (Brick/Veneer)

Exterior

Underfloor Voids - Slab on Ground	Non Accessible Area - Area inaccessible, slab on ground, no access points.
Ceiling Voids	No Asbestos Found

Interior

B00I - R0001 - Toilets-Boys

No Asbestos

B00I - R0002 - Toilets-Girls

No Asbestos

B00I - R0003 - Staff Toilet

No Asbestos

B00I - R0004 - Movement

No Asbestos

B00I - R0005 - Movement

No Asbestos

B00I - R0006 - Movement

No Asbestos

B00I - R0007 - Drinking Facilities

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00J - Communal Facilities - 2005 - Metal Shed (Metal Shed)

Exterior

Underfloor Voids - Slab on Ground Non Accessible Area
 - Area inaccessible, slab on ground, no access points.

Ceiling Voids No Asbestos Found

Interior

B00J - R0001 - Sports Store

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00K - Library - 2011 - Fibre Cement Clad (Fibre Cement Clad)

Exterior

Underfloor Voids - Packing to Floor Joists	No Asbestos Found
Ceiling Voids	No Asbestos Found

Interior

B00K - R0001 - External Movement

No Asbestos

B00K - R0002 - Reading Area

No Asbestos

B00K - R0003 - Library Office/Workroom

No Asbestos

B00K - R0004 - Communications Room

No Asbestos

B00K - R0005 - Security Store

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00L - Multi Purpose Facilities - 2010 - Fibre Cement Clad (Fibre Cement Clad)

Exterior

Underfloor Voids - Slab on Ground	Non Accessible Area - Area inaccessible, slab on ground, no access points.
Ceiling Voids	No Asbestos Found

Interior

B00L - R0001 - Communal Space

No Asbestos

B00L - R0002 - General Storeroom

No Asbestos

B00L - R0003 - Practical Activities

No Asbestos

B00L - R0004 - External Movement

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00M - Pupil Facilities - 2010 - Brick/Veneer (Brick/Veneer)

Exterior

Underfloor Voids - Slab on Ground Non Accessible Area
 - Area inaccessible, slab on ground, no access points.

Ceiling Voids No Asbestos Found

Interior

B00M - R0001 - Sports Store

No Asbestos

B00M - R0002 - General Storeroom

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

Demountables

Demountable details as per the AMS records as of 15 Feb 2017.

OS 531 - D12478 - Library : Placement Date - 30/04/2003

Exterior

Step Treads	Compressed AC Sheet	Assumed Asbestos		1.08 m2
Landing	Compressed AC Sheet	Assumed Asbestos		1.2 m2
Eave Lining	Flat AC Sheet	Assumed Asbestos		11.52 m2

Interior

R1 - Entry/classroom

End wall panel	Flat AC Sheet	Assumed Asbestos		18 m2
Ceiling	Flat AC Sheet	Assumed Asbestos		63 m2

R2 - Reading Area/workroom

End wall panel	Flat AC Sheet	Assumed Asbestos		18 m2
Ceiling	Flat AC Sheet	Assumed Asbestos		10 m2

OS 601 - D13925 - Learning Unit - Standard/Withdrawal : Placement Date - 14/02/2007

Exterior

Step Treads	Compressed AC Sheet	Assumed Asbestos		1.08 m2
Landing	Compressed AC Sheet	Assumed Asbestos		1.2 m2
Eave Lining	Flat AC Sheet	Assumed Asbestos		11.52 m2

Interior

R1 - Entry

End wall panel	Flat AC Sheet	Assumed Asbestos		18 m2
Ceiling	Flat AC Sheet	Assumed Asbestos		8 m2

R2 - General Learning Space

End wall panel	Flat AC Sheet	Assumed Asbestos		18 m2
Ceiling	Flat AC Sheet	Assumed Asbestos		55 m2

R3 - Store

Ceiling	Flat AC Sheet	Assumed Asbestos		10 m2
---------	---------------	------------------	--	-------

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

Listing of Electronic Attachments as of 22/03/2017

There are no asbestos related file attachment(s) for this school.

2017