


Asbestos Register

(Hazardous Materials and Risk Assessment)

School : Gorokan Public School (4517)
Region : Hunter/Central Coast
State Electorate : Wyong
Local Government Area : Wyong

Initial Survey : Noel Arnold & Associates : 29 - Mar - 2008
Reviewed By : Parsons Brinckerhoff : 17 - Jun - 2015



2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00A - General Learning/Administration - 1981 - Brick/Block (Brick/Block)

Exterior

Ceiling Voids	No Asbestos Found					
Underfloor Voids	No Asbestos Found					
Grease Trap Cover	Compressed AC Sheet	2m2	South Entrance to Chook Yard	Some Damage - Unsealed (3)	Low (1)	Medium Priority (4-5)
4517/B00A/Grease Trap Cover/S8					Chrysotile (white asbestos)	

Interior

B00A - M0001 - Practical Activities - 1hb

No Asbestos

B00A - M0002 - Stairs

No Asbestos

B00A - R0001 - Movement

No Asbestos

B00A - R0002 - Home Base Store

Floor Coverings Res/Textile	Vinyl Sheet					
4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected	

B00A - R0003 - Personal Effects Storage

No Asbestos

B00A - R0004 - Home Base

No Asbestos

B00A - R0005 - Movement

No Asbestos

B00A - R0006 - Withdrawal Space - 1hb

Floor Coverings Res/Textile	Vinyl Sheet					
4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected	

B00A - R0007 - Home Base

No Asbestos

B00A - R0008 - Movement

No Asbestos

B00A - R0009 - Withdrawal Space - 1hb

No Asbestos

B00A - R0010 - Home Base

No Asbestos

B00A - R0011 - Toilets - Girls

Partition Walls (Cubicles)	Compressed AC Sheet	5m2	North, South	Good Condition (1)	Low (1)	Low Priority (2-3)
4517/B00A/R0085/Partition Walls (Cubicles)/S2					Chrysotile (white asbestos)	

B00A - R0012 - Distribution Board Note: No inspection of live electrical installation.

No Asbestos

B00A - R0013 - Toilets - Boys

Partition Walls (Cubicles)	Compressed AC Sheet	1m2	North, South	Good Condition (1)	Low (1)	Low Priority (2-3)
4517/B00A/R0085/Partition Walls (Cubicles)/S2					Chrysotile (white asbestos)	

B00A - R0014 - Movement

No Asbestos

B00A - R0015 - Cleaning Distributed Store

Floor Coverings Res/Textile	Vinyl Sheet					
4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected	

B00A - R0016 - General Storeroom

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
Floor Coverings Res/Textile	Vinyl Sheet					
	4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected
B00A - R0017 - Withdrawal Space - 1hb						
No Asbestos						
B00A - R0018 - Practical Activities - 1hb						
Floor Coverings Res/Textile	Vinyl Sheet					
	4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected
B00A - R0019 - Home Base Store						
Floor Coverings Res/Textile	Vinyl Sheet					
	4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected
B00A - R0020 - Personal Effects Storage						
No Asbestos						
B00A - R0021 - Home Base Store						
Floor Coverings Res/Textile	Vinyl Sheet					
	4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected
B00A - R0022 - Personal Effects Storage						
No Asbestos						
B00A - R0023 - Movement						
Floor Coverings Res/Textile	Vinyl Sheet					
	4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected
B00A - R0024 - Movement						
No Asbestos						
B00A - R0025 - General Assistant/Bulk Store						
Floor Coverings Res/Textile	Vinyl Sheet					
	4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected
B00A - R0026 - Tiered Learning Space						
No Asbestos						
B00A - R0027 - Home Base Store						
Floor Coverings Res/Textile	Vinyl Sheet					
	4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected
B00A - R0028 - Toilets - Boys						
Partition Walls (Cubicles)	Compressed AC Sheet	1m2	North, South	Good Condition (1)	Low (1)	Low Priority (2-3)
	4517/B00A/R0085/Partition Walls (Cubicles)/S2					Chrysotile (white asbestos)
B00A - R0029 - Distribution Board						
Loose Panel Above Distribution Board	Flat AC Sheeting	1m2	Throughout	Some Damage / Unsealed (3)	Low (1)	Low Priority (2-3)
	4517/B00A/R0029/Louse Panel Above Distribution Board/S3					Chrysotile (white asbestos) , Amosite (brown asbestos)
B00A - R0030 - Toilets - Girls						
Partition Walls (Cubicles)	Compressed AC Sheet	5m2	North, South	Good Condition (1)	Low (1)	Low Priority (2-3)
	4517/B00A/R0085/Partition Walls (Cubicles)/S2					Chrysotile (white asbestos)
B00A - R0031 - Movement						
No Asbestos						
B00A - R0032 - Movement						
No Asbestos						
B00A - R0033 - Entry Vestibule						
No Asbestos						

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
B00A - R0034 - Clerical Office						
No Asbestos						
B00A - R0035 - External Movement						
No Asbestos						
B00A - R0036 - Interview						
No Asbestos						
B00A - R0037 - Deputy Principal						
No Asbestos						
B00A - R0038 - Movement						
No Asbestos						
B00A - R0039 - Community Clinic						
No Asbestos						
B00A - R0040 - Staff Toilet						
No Asbestos						
B00A - R0041 - General Storeroom						
No Asbestos						
B00A - R0042 - Movement						
No Asbestos						
B00A - R0043 - Cleaning Distributed Store						
Floor Coverings Res/Textile	Vinyl Sheet					
			4517/B00A/R0130/Floor Coverings Res/Textile/S1			No Asbestos Detected
B00A - R0044 - General Storeroom						
Floor Coverings Res/Textile	Vinyl Sheet					
			4517/B00A/R0130/Floor Coverings Res/Textile/S1			No Asbestos Detected
B00A - R0045 - Withdrawal Space - 1hb						
No Asbestos						
B00A - R0046 - Movement						
No Asbestos						
B00A - R0047 - Home Base Store						
Floor Coverings Res/Textile	Vinyl Sheet					
			4517/B00A/R0130/Floor Coverings Res/Textile/S1			No Asbestos Detected
B00A - R0048 - Personal Effects Storage						
No Asbestos						
B00A - R0049 - Home Base						
No Asbestos						
B00A - R0050 - Movement						
No Asbestos						
B00A - R0051 - Withdrawal Space - 1hb						
No Asbestos						
B00A - R0052 - Home Base						
No Asbestos						
B00A - R0053 - Movement						
No Asbestos						
B00A - R0054 - Withdrawal Space - 1hb						
No Asbestos						
B00A - R0055 - Home Base						
No Asbestos						
B00A - R0056 - Practical Activities - 1hb						

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
Floor Coverings Res/Textile	Vinyl Sheet					
	4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected
B00A - R0057 - Home Base Store						
Floor Coverings Res/Textile	Vinyl Sheet					
	4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected
B00A - R0058 - Personal Effects Storage						
No Asbestos						
B00A - R0059 - Home Base Store						
Floor Coverings Res/Textile	Vinyl Sheet					
	4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected
B00A - R0060 - Personal Effects Storage						
No Asbestos						
B00A - R0061 - Sick Bay						
No Asbestos						
B00A - R0062 - Principal						
No Asbestos						
B00A - R0063 - Deputy Principal						
No Asbestos						
B00A - R0064 - Duplicating Workroom						
Floor Coverings Res/Textile	Vinyl Sheet					
	4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected
B00A - R0065 - General Storeroom						
No Asbestos						
B00A - R0066 - General Storeroom						
Floor Coverings Res/Textile	Vinyl Sheet					
	4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected
B00A - R0067 - Staff Toilet						
Partition Walls (Cubicles)	Compressed AC Sheet	2m2	North, South	Good Condition (1)	Low (1)	Low Priority (2-3)
	4517/B00A/R0085/Partition Walls (Cubicles)/S2					Chrysotile (white asbestos)
B00A - R0068 - Distribution Board						
					Note: No inspection of live electrical installation.	
No Asbestos						
B00A - R0069 - Disabled Toilet						
Partition Walls (Cubicles)	Compressed AC Sheet	1m2	North, South	Good Condition (1)	Low (1)	Low Priority (2-3)
	4517/B00A/R0085/Partition Walls (Cubicles)/S2					Chrysotile (white asbestos)
B00A - R0070 - Staff Toilet						
Partition Walls (Cubicles)	Compressed AC Sheet	1m2	North, South	Good Condition (1)	Low (1)	Low Priority (2-3)
	4517/B00A/R0085/Partition Walls (Cubicles)/S2					Chrysotile (white asbestos)
B00A - R0071 - Staff Toilet						
Partition Walls (Cubicles)	Compressed AC Sheet	5m2	North, South	Good Condition (1)	Low (1)	Low Priority (2-3)
	4517/B00A/R0085/Partition Walls (Cubicles)/S2					Chrysotile (white asbestos)
B00A - R0072 - Security Store						
Floor Coverings Res/Textile	Vinyl Sheet					
	4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected
B00A - R0075 - Staff Shower/Change						
Floor Coverings Res/Textile	Vinyl Sheet					
	4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No						Test Result
B00A - R0076 - Library Office/Workroom						
No Asbestos						
B00A - R0077 - Library Office/Workroom						
No Asbestos						
B00A - R0078 - Library Office/Workroom						
No Asbestos						
B00A - R0079 - Tiered Learning Space						
No Asbestos						
B00A - R0080 - Movement						
No Asbestos						
B00A - R0081 - Tiered Learning Space						
No Asbestos						
B00A - R0082 - Reading Area						
No Asbestos						
B00A - R0083 - Movement						
Floor Coverings Res/Textile	Vinyl Sheet					
4517/B00A/R0130/Floor Coverings Res/Textile/S1						No Asbestos Detected
B00A - R0084 - Plant						
No Asbestos						
B00A - R0085 - Toilets - Boys						
Partition Walls (Cubicles)	Compressed AC Sheet	1m2	North, South	Good Condition (1)	Low (1)	Low Priority (2-3)
4517/B00A/R0085/Partition Walls (Cubicles)/S2						Chrysotile (white asbestos)
B00A - R0086 - Distribution Board						
No Asbestos						Note: No inspection of live electrical installation.
B00A - R0087 - Toilets - Girls						
Partition Walls (Cubicles)	Compressed AC Sheet	5m2	North, South	Good Condition (1)	Low (1)	Low Priority (2-3)
4517/B00A/R0085/Partition Walls (Cubicles)/S2						Chrysotile (white asbestos)
B00A - R0088 - Movement						
No Asbestos						
B00A - R0089 - Cleaning Distributed Store						
Floor Coverings Res/Textile	Vinyl Sheet					
4517/B00A/R0130/Floor Coverings Res/Textile/S1						No Asbestos Detected
B00A - R0090 - K.L.A. Store						
Floor Coverings Res/Textile	Vinyl Sheet					
4517/B00A/R0130/Floor Coverings Res/Textile/S1						No Asbestos Detected
B00A - R0091 - Withdrawal Space - 1hb						
No Asbestos						
B00A - R0092 - Movement						
No Asbestos						
B00A - R0093 - Movement						
No Asbestos						
B00A - R0094 - Personal Effects Storage						
No Asbestos						
B00A - R0095 - Home Base Store						
Floor Coverings Res/Textile	Vinyl Sheet					
4517/B00A/R0130/Floor Coverings Res/Textile/S1						No Asbestos Detected
B00A - R0096 - Home Base						
No Asbestos						

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
B00A - R0097 - Movement						
No Asbestos						
B00A - R0098 - Withdrawal Space - 1hb						
No Asbestos						
B00A - R0099 - Home Base						
No Asbestos						
B00A - R0100 - Home Base						
No Asbestos						
B00A - R0101 - Movement						
No Asbestos						
B00A - R0102 - Withdrawal Space - 1hb						
No Asbestos						
B00A - R0103 - Home Base						
No Asbestos						
B00A - R0104 - Personal Effects Storage						
No Asbestos						
B00A - R0105 - Home Base Store						
Floor Coverings Res/Textile	Vinyl Sheet					
		4517/B00A/R0130/Floor Coverings Res/Textile/S1				No Asbestos Detected
B00A - R0106 - Personal Effects Storage						
No Asbestos						
B00A - R0107 - Home Base Store						
Floor Coverings Res/Textile	Vinyl Sheet					
		4517/B00A/R0130/Floor Coverings Res/Textile/S1				No Asbestos Detected
B00A - R0108 - Personal Effects Storage						
No Asbestos						
B00A - R0109 - Home Base Store						
Floor Coverings Res/Textile	Vinyl Sheet					
		4517/B00A/R0130/Floor Coverings Res/Textile/S1				No Asbestos Detected
B00A - R0110 - Kiln Room						
No Asbestos						
B00A - R0111 - Practical Activities - 1hb						
Floor Coverings Res/Textile	Vinyl Sheet					
		4517/B00A/R0130/Floor Coverings Res/Textile/S1				No Asbestos Detected
B00A - R0112 - Movement						
Floor Coverings Res/Textile	Vinyl Sheet					
		4517/B00A/R0130/Floor Coverings Res/Textile/S1				No Asbestos Detected
B00A - R0113 - Practical Activities - 1hb						
Floor Coverings Res/Textile	Vinyl Sheet					
		4517/B00A/R0130/Floor Coverings Res/Textile/S1				No Asbestos Detected
B00A - R0114 - Movement						
No Asbestos						
B00A - R0115 - Movement						
No Asbestos						
B00A - R0116 - Cleaning Supplies						
Floor Coverings Res/Textile	Vinyl Sheet					
		4517/B00A/R0130/Floor Coverings Res/Textile/S1				No Asbestos Detected

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
B00A - R0117 - Tiered Learning Space						
No Asbestos						
B00A - R0118 - Movement						
No Asbestos						
B00A - R0119 - Toilets - Boys						
Partition Walls (Cubicles)	Compressed AC Sheet	1m2	North, South	Good Condition (1)	Low (1)	Low Priority (2-3)
4517/B00A/R0085/Partition Walls (Cubicles)/S2					Chrysotile (white asbestos)	
B00A - R0120 - Distribution Board						
Note: No inspection of live electrical installation.						
Loose Panel Above Distribution Board	Flat AC Sheeting	1m2	Throughout	Some Damage / Unsealed (3)	Low (1)	Low Priority (2-3)
4517/B00A/R0029/Louse Panel Above Distribution Board/S3					Chrysotile (white asbestos) , Amosite (brown asbestos)	
B00A - R0121 - Toilets - Girls						
Partition Walls (Cubicles)	Compressed AC Sheet	5m2	North, South	Good Condition (1)	Low (1)	Low Priority (2-3)
4517/B00A/R0085/Partition Walls (Cubicles)/S2					Chrysotile (white asbestos)	
B00A - R0122 - Movement						
No Asbestos						
B00A - R0123 - Movement						
Floor Coverings Res/Textile	Vinyl Sheet					
4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected	
B00A - R0124 - Practical Activities - 1hb						
Floor Coverings Res/Textile	Vinyl Sheet					
4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected	
B00A - R0125 - Cleaning Distributed Store						
Floor Coverings Res/Textile	Vinyl Sheet					
4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected	
B00A - R0126 - General Storeroom						
Floor Coverings Res/Textile	Vinyl Sheet					
4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected	
B00A - R0127 - Withdrawal Space - 1hb						
No Asbestos						
B00A - R0128 - Movement						
No Asbestos						
B00A - R0129 - Movement						
No Asbestos						
B00A - R0130 - Practical Activities - 1hb						
Floor Coverings Res/Textile	Vinyl Sheet					
4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected	
B00A - R0131 - Movement						
No Asbestos						
B00A - R0132 - Home Base Store						
Floor Coverings Res/Textile	Vinyl Sheet					
4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected	
B00A - R0133 - Personal Effects Storage						
No Asbestos						
B00A - R0134 - Home Base						
No Asbestos						
B00A - R0135 - Movement						

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
No Asbestos						
B00A - R0136 - Withdrawal Space - 1hb						
No Asbestos						
B00A - R0137 - Home Base						
No Asbestos						
B00A - R0138 - Home Base Store						
Floor Coverings Res/Textile	Vinyl Sheet					
4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected	
B00A - R0139 - Personal Effects Storage						
No Asbestos						
B00A - R0140 - Home Base						
No Asbestos						
B00A - R0141 - Movement						
No Asbestos						
B00A - R0142 - Withdrawal Space - 1hb						
No Asbestos						
B00A - R0143 - Special Programs Room						
No Asbestos						
B00A - R0144 - Home Base Store						
Floor Coverings Res/Textile	Vinyl Sheet					
4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected	
B00A - R0145 - Personal Effects Storage						
No Asbestos						
B00A - R0146 - Security Store						
Floor Coverings Res/Textile	Vinyl Sheet					
4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected	
B00A - R0147 - Main Switch Board						
No Asbestos						
B00A - R0150 - Plant						
No Asbestos						
B00A - R0151 - Canteen Office/Store						
Floor Coverings Res/Textile	Vinyl Sheet					
4517/B00A/R0154/Floor Coverings Res/Textile/S6					No Asbestos Detected	
B00A - R0152 - Canteen Office/Store						
Floor Coverings Res/Textile	Vinyl Sheet					
4517/B00A/R0154/Floor Coverings Res/Textile/S6					No Asbestos Detected	
B00A - R0154 - Canteen						
Floor Coverings Res/Textile	Vinyl Sheet					
4517/B00A/R0154/Floor Coverings Res/Textile/S6					No Asbestos Detected	
B00A - R0155 - Movement						
No Asbestos						
B00A - R0156 - Staff Toilet						
No Asbestos						
B00A - R0159 - Movement						
No Asbestos						
B00A - R0160 - Communal Space						
No Asbestos						
B00A - R0161 - Raised Platform						

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
No Asbestos						
B00A - R0162 - Personal Effects Storage						
No Asbestos						
B00A - R0163 - Movement						
No Asbestos						
B00A - R0164 - Toilets - Girls						
Partition Walls (Cubicles)	Compressed AC Sheet		4517/B00A/R0164/Partition Walls (Cubicles)/S4			No Asbestos Detected
B00A - R0165 - Toilets - Boys						
Partition Walls (Cubicles)	Compressed AC Sheet		4517/B00A/R0164/Partition Walls (Cubicles)/S4			No Asbestos Detected
B00A - R0166 - Sports Store						
No Asbestos						
B00A - R0167 - Movement						
No Asbestos						
B00A - R0168 - P.E. Store						
No Asbestos						
B00A - R0170 - General Storeroom						
No Asbestos						
B00A - R0171 - Stairs						
No Asbestos						
B00A - R0172 - Stairs						
No Asbestos						
B00A - R0173 - Cleaning Distributed Store						
No Asbestos						
B00A - R0174 - Stairs						
No Asbestos						
B00A - R0175 - Movement						
No Asbestos						
B00A - R0176 - Stairs						
No Asbestos						
B00A - R0177 - Movement						
No Asbestos						
B00A - R1001 - External Movement						
No Asbestos						
B00A - R1002 - Home Base Store						
Floor Coverings Res/Textile	Vinyl Sheet		4517/B00A/R0130/Floor Coverings Res/Textile/S1			No Asbestos Detected
B00A - R1003 - Personal Effects Storage						
No Asbestos						
B00A - R1004 - Home Base						
No Asbestos						
B00A - R1005 - Movement						
No Asbestos						
B00A - R1006 - Withdrawal Space - 1hb						
No Asbestos						
B00A - R1007 - Home Base Store						
Floor Coverings Res/Textile	Vinyl Sheet		4517/B00A/R0130/Floor Coverings Res/Textile/S1			No Asbestos Detected
B00A - R1008 - Personal Effects Storage						

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No						Test Result
No Asbestos						
B00A - R1009 - Home Base						
No Asbestos						
B00A - R1010 - Movement						
No Asbestos						
B00A - R1011 - Withdrawal Space - 1hb						
No Asbestos						
B00A - R1012 - Home Base Store						
Floor Coverings Res/Textile	Vinyl Sheet					
4517/B00A/R0130/Floor Coverings Res/Textile/S1						No Asbestos Detected
B00A - R1013 - Personal Effects Storage						
No Asbestos						
B00A - R1014 - Home Base						
No Asbestos						
B00A - R1015 - Kiln Room						
No Asbestos						
B00A - R1016 - Practical Activities - 1hb						
Floor Coverings Res/Textile	Vinyl Sheet					
4517/B00A/R0130/Floor Coverings Res/Textile/S1						No Asbestos Detected
B00A - R1017 - Withdrawal Space - 1hb						
No Asbestos						
B00A - R1018 - General Storeroom						
Floor Coverings Res/Textile	Vinyl Sheet					
4517/B00A/R0130/Floor Coverings Res/Textile/S1						No Asbestos Detected
B00A - R1019 - Cleaning Distributed Store						
Floor Coverings Res/Textile	Vinyl Sheet					
4517/B00A/R0130/Floor Coverings Res/Textile/S1						No Asbestos Detected
B00A - R1020 - Movement						
No Asbestos						
B00A - R1021 - Toilets - Boys						
Partition Walls (Cubicles)	Compressed AC Sheet	1m2	North, South	Good Condition (1)	Low (1)	Low Priority (2-3)
4517/B00A/R0085/Partition Walls (Cubicles)/S2						Chrysotile (white asbestos)
Manhole infill panel	Flat AC Sheeting	1m2	Middle portion	Minimal Damage (2)	Low (1)	Low Priority (2-3)
4517/B00A/R1021/Manhole infill panel/S7						Chrysotile (white asbestos)
B00A - R1022 - Distribution Board						
						Note: No inspection of live electrical installation.
No Asbestos						
B00A - R1023 - Toilets - Girls						
Partition Walls (Cubicles)	Compressed AC Sheet	5m2	North, South	Good Condition (1)	Low (1)	Low Priority (2-3)
4517/B00A/R0085/Partition Walls (Cubicles)/S2						Chrysotile (white asbestos)
B00A - R1024 - Movement						
No Asbestos						
B00A - R1025 - Staff Room						
No Asbestos						
B00A - R1026 - Movement						
Floor Coverings Res/Textile	Vinyl Sheet					
4517/B00A/R0130/Floor Coverings Res/Textile/S1						No Asbestos Detected
B00A - R1027 - Movement						

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No						Test Result
Floor Coverings Res/Textile	Vinyl Sheet					
	4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected
B00A - R1028 - Movement						
No Asbestos						
B00A - R1029 - Toilets - Boys						
Partition Walls (Cubicles)	Compressed AC Sheet	1m2	North, South	Good Condition (1)	Low (1)	Low Priority (2-3)
	4517/B00A/R0085/Partition Walls (Cubicles)/S2					Chrysotile (white asbestos)
B00A - R1030 - Distribution Board						Note: No inspection of live electrical installation.
No Asbestos						
B00A - R1031 - Toilets - Girls						
Partition Walls (Cubicles)	Compressed AC Sheet	5m2	North, South	Good Condition (1)	Low (1)	Low Priority (2-3)
	4517/B00A/R0085/Partition Walls (Cubicles)/S2					Chrysotile (white asbestos)
B00A - R1032 - Movement						
No Asbestos						
B00A - R1033 - Cleaning Distributed Store						
Floor Coverings Res/Textile	Vinyl Sheet					
	4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected
B00A - R1034 - General Storeroom						
Floor Coverings Res/Textile	Vinyl Sheet					
	4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected
B00A - R1035 - Withdrawal Space - 1hb						
No Asbestos						
B00A - R1036 - Movement						
No Asbestos						
B00A - R1037 - External Movement						
No Asbestos						
B00A - R1038 - Practical Activities - 1hb						
Floor Coverings Res/Textile	Vinyl Sheet					
	4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected
B00A - R1039 - Kiln Room						
No Asbestos						
B00A - R1040 - Movement						
Floor Coverings Res/Textile	Vinyl Sheet					
	4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected
B00A - R1041 - Practical Activities - 1hb						
Floor Coverings Res/Textile	Vinyl Sheet					
	4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected
B00A - R1042 - Movement						
Floor Coverings Res/Textile	Vinyl Sheet					
	4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected
B00A - R1043 - Home Base Store						
Floor Coverings Res/Textile	Vinyl Sheet					
	4517/B00A/R0130/Floor Coverings Res/Textile/S1					No Asbestos Detected
B00A - R1044 - Personal Effects Storage						
No Asbestos						
B00A - R1045 - Home Base						

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

No Asbestos

B00A - R1046 - Movement

No Asbestos

B00A - R1047 - Withdrawal Space - 1hb

No Asbestos

B00A - R1048 - Home Base Store

Floor Coverings Vinyl Sheet
Res/Textile

4517/B00A/R0130/Floor Coverings Res/Textile/S1

No Asbestos Detected

B00A - R1049 - Personal Effects Storage

No Asbestos

B00A - R1050 - Home Base

No Asbestos

B00A - R1051 - Home Base Store

Floor Coverings Vinyl Sheet
Res/Textile

4517/B00A/R0130/Floor Coverings Res/Textile/S1

No Asbestos Detected

B00A - R1052 - Personal Effects Storage

No Asbestos

B00A - R1053 - Home Base

No Asbestos

B00A - R1054 - Movement

No Asbestos

B00A - R1055 - Withdrawal Space - 1hb

No Asbestos

B00A - R1056 - Home Base Store

Floor Coverings Vinyl Sheet
Res/Textile

4517/B00A/R0130/Floor Coverings Res/Textile/S1

No Asbestos Detected

B00A - R1057 - Personal Effects Storage

No Asbestos

B00A - R1058 - Home Base

No Asbestos

B00A - R1059 - General Storeroom

Floor Coverings Vinyl Sheet
Res/Textile

4517/B00A/R0130/Floor Coverings Res/Textile/S1

No Asbestos Detected

B00A - R1060 - Stairs

No Asbestos

B00A - R1061 - Stairs

No Asbestos

B00A - R1062 - Stairs

No Asbestos



Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
	Sample No					Test Result

B00B - General Learning/Pupil Facilities - 2010 - Brick/Veneer (Brick/Veneer)**Exterior**

Ceiling Voids	No Asbestos Found
Underfloor Voids	No Asbestos Found

Interior**B00B - R0001 - Staff Kitchen**

No Asbestos

B00B - R0002 - Staff Room Annexe

No Asbestos

B00B - R0003 - Practical Activities - 1hb

No Asbestos

B00B - R0004 - Personal Effects Storage

No Asbestos

B00B - R0005 - Withdrawal Space - 1hb

No Asbestos

B00B - R0006 - Home Base Store

No Asbestos

B00B - R0007 - Home Base

No Asbestos

B00B - R0008 - Practical Activities - 1hb

No Asbestos

B00B - R0009 - Personal Effects Storage

No Asbestos

B00B - R0010 - Home Base Store

No Asbestos

B00B - R0011 - Home Base

No Asbestos

B00B - R0012 - Withdrawal Space - 2hb

No Asbestos

B00B - R0013 - Practical Activities - 1hb

No Asbestos

B00B - R0014 - Personal Effects Storage

No Asbestos

B00B - R0015 - Home Base Store

No Asbestos

B00B - R0016 - Home Base

No Asbestos

B00B - R0017 - Toilets - Girls

No Asbestos

B00B - R0018 - Toilets - Boys

No Asbestos

B00B - R0019 - Access Shower/Toilet/Change

No Asbestos

B00B - R0020 - External Movement

No Asbestos

B00B - R0021 - External Movement

No Asbestos

B00B - R0022 - External Movement

No Asbestos

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00C - General Learning - 2010 - Brick/Veneer (Brick/Veneer)

Exterior

Ceiling Voids	No Asbestos Found
Underfloor Voids	No Asbestos Found

Interior

B00C - R0001 - Practical Activities - 1hb

No Asbestos

B00C - R0002 - Personal Effects Storage

No Asbestos

B00C - R0003 - Home Base Store

No Asbestos

B00C - R0004 - Home Base

No Asbestos

B00C - R0005 - Withdrawal Space - 2hb

No Asbestos

B00C - R0006 - Practical Activities - 1hb

No Asbestos

B00C - R0007 - Personal Effects Storage

No Asbestos

B00C - R0008 - Home Base Store

No Asbestos

B00C - R0009 - Home Base

No Asbestos

B00C - R0010 - External Movement

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

Demountables

Demountable details as per the AMS records as of 15 Feb 2017.

OS 534 - D11235 - Library/Group Study/Office/A V Store : Placement Date - 25/01/2016

Exterior

No Asbestos Found.

Interior

R1 - Clerical Office

No Asbestos Found.

R2 - Staff Room

No Asbestos Found.

R3 - Security Store

No Asbestos Found.

R4 - Principal

No Asbestos Found.

R5 - Staff Toilet

No Asbestos Found.

R6 - Staff Toilet

No Asbestos Found.

R7 - Reading Area

No Asbestos Found.

R8 - Entry

No Asbestos Found.

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

Listing of Electronic Attachments as of 22/03/2017

There are no asbestos related file attachment(s) for this school.

2017