

Asbestos Register

(Hazardous Materials and Risk Assessment)

School : Glenwood Public School (4529)
Region : South Western Sydney
State Electorate : Macquarie Fields
Local Government Area : Campbelltown

Initial Survey : Noel Arnold & Associates : 01 - May - 2008
Reviewed By : Parsons Brinckerhoff : 03 - Jan - 2017



2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00A - Administration - 1981 - Brick/Block (Brick/Block)

Exterior

Underfloor Voids - Slab on Ground	No Asbestos Found					
Eaves Linings	Flat AC Sheeting 4529/B00D/Eaves Linings/S15					No Asbestos Detected
Ceiling Void	No Asbestos Found					

Interior

B00A - R0001 - Staff Kitchen

Floor Coverings Res/Textile	Vinyl Tiles 4529/B00A/R0011/Floor Coverings Res/Textile/S4					No Asbestos Detected
-----------------------------	---	--	--	--	--	----------------------

B00A - R0002 - Staff Room

No Asbestos

B00A - R0003 - Security Store

Floor Coverings Res/Textile	Vinyl Tiles 4529/B00A/R0011/Floor Coverings Res/Textile/S4					No Asbestos Detected
-----------------------------	---	--	--	--	--	----------------------

B00A - R0004 - Staff Toilet

No Asbestos

B00A - R0005 - Staff Toilet

No Asbestos

B00A - R0006 - Staff Room Annexe

No Asbestos

B00A - R0007 - Staff Room Annexe

No Asbestos

B00A - R0008 - Interview

No Asbestos

B00A - R0009 - Duplicating Workroom

No Asbestos

B00A - R0010 - Clerical Office

No Asbestos

B00A - R0011 - Sick Bay

Floor Coverings Res/Textile	Vinyl Tiles 4529/B00A/R0011/Floor Coverings Res/Textile/S4					No Asbestos Detected
-----------------------------	---	--	--	--	--	----------------------

B00A - R0012 - Principal

No Asbestos

B00A - R0013 - Distribution Board

Note: No inspection of live electrical installation.

No Asbestos

B00A - R0014 - Cleaning Distributed Store

No Asbestos

B00A - R0015 - Staff Toilet

No Asbestos

B00A - R0016 - Community Clinic

Floor Coverings Res/Textile	Vinyl Tiles 4529/B00A/R0011/Floor Coverings Res/Textile/S4					No Asbestos Detected
-----------------------------	---	--	--	--	--	----------------------

B00A - R0017 - Staff Toilet

No Asbestos

B00A - R0018 - Movement

No Asbestos

B00A - R0019 - Movement

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
Ceiling Structures/Linings	Flat AC Sheeting	2m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
4529/B00A/R0023/Ceiling Structures/Linings/S3					Chrysotile (white asbestos)	
B00A - R0020 - Movement						
No Asbestos						
B00A - R0021 - Entry Vestibule						
No Asbestos						
B00A - R0022 - Movement						
Ceiling Structures/Linings	Flat AC Sheeting	3m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
4529/B00A/R0023/Ceiling Structures/Linings/S3					Chrysotile (white asbestos)	
B00A - R0023 - Movement						
Ceiling Structures/Linings	Flat AC Sheeting	46m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
4529/B00A/R0023/Ceiling Structures/Linings/S3					Chrysotile (white asbestos)	

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00B - Library - 1981 - Brick/Block (Brick/Block)

Exterior

Ceiling Voids - Raked Ceiling	No Asbestos Found					
Underfloor Voids - Slab on Ground	No Asbestos Found					
Eaves Linings	Flat AC Sheeting	22m2	South, Upper portion, Lower portion	Good Condition (1)	Low (1)	Low Priority (2-3)
	4529/B00B/Eaves Linings/S2					Chrysotile (white asbestos)

Interior

B00B - R0001 - Movement

Ceiling Structures/Linings	Flat AC Sheeting	3m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4529/B00B/Eaves Linings/S2					Chrysotile (white asbestos)

B00B - R0002 - Cleaning Distributed Store

Floor Coverings Res/Textile	Vinyl Tiles					
	4529/B00B/R0002/Floor Coverings Res/Textile/S14					No Asbestos Detected

B00B - R0003 - Special Programs Room

No Asbestos

B00B - R0004 - Distribution Board

Note: No inspection of live electrical installation.

No Asbestos

B00B - R0005 - Reading Area

No Asbestos

B00B - R0006 - Reading Area

No Asbestos

B00B - R0007 - Toilets - Boys

No Asbestos

B00B - R0008 - Toilets - Girls

No Asbestos

B00B - R0009 - Library Office/Workroom

No Asbestos

B00B - R0010 - Library Office/Workroom

No Asbestos

B00B - R0011 - K.L.A. Store

No Asbestos

B00B - R0012 - K.L.A. Store

No Asbestos

B00B - R0013 - K.L.A. Store

No Asbestos

B00B - R0014 - Movement

No Asbestos



Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00C - Communal Facilities - 1981 - Brick/Block (Brick/Block)

Exterior

Ceiling Voids - Raked Ceiling	No Asbestos Found					
Underfloor Voids - Slab on Ground	No Asbestos Found					
Eaves Linings	Flat AC Sheeting 4529/B00D/Eaves Linings/S15					No Asbestos Detected

Interior

B00C - R0001 - Uniform Shop

No Asbestos

B00C - R0002 - Distribution Board

Note: No inspection of live electrical installation.

No Asbestos

B00C - R0003 - Movement

No Asbestos

B00C - R0004 - Canteen Office/Store

No Asbestos

B00C - R0005 - Staff Toilet

No Asbestos

B00C - R0006 - Canteen Office/Store

No Asbestos

B00C - R0007 - Canteen

No Asbestos

B00C - R0008 - Raised Platform

No Asbestos

B00C - R0009 - General Storeroom

No Asbestos

B00C - R0010 - Communal Space

No Asbestos

B00C - R0011 - Hall Chair Store

No Asbestos

B00C - R0012 - Movement

Ceiling Structures/Linings	Flat AC Sheeting 4529/B00C/R0022/Ceiling Structures/Linings/S16					No Asbestos Detected
----------------------------	--	--	--	--	--	-----------------------------

B00C - R0013 - Movement

Ceiling Structures/Linings	Flat AC Sheeting 4529/B00C/R0022/Ceiling Structures/Linings/S16					No Asbestos Detected
----------------------------	--	--	--	--	--	-----------------------------

B00C - R0016 - Toilets - Girls

Ceiling Structures/Linings	Flat AC Sheeting 4529/B00C/R0014/Ceiling Structures/Linings/S8					No Asbestos Detected
----------------------------	---	--	--	--	--	-----------------------------

B00C - R0017 - Toilets - Boys

Ceiling Structures/Linings	Flat AC Sheeting 4529/B00C/R0014/Ceiling Structures/Linings/S8					No Asbestos Detected
----------------------------	---	--	--	--	--	-----------------------------

B00C - R0018 - Garden Store

No Asbestos

B00C - R0019 - Garden Store

No Asbestos

B00C - R0020 - Sports Store

No Asbestos

B00C - R0021 - General Storeroom

No Asbestos

B00C - R0022 - External Movement

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

Ceiling Structures/Linings	Flat AC Sheeting		4529/B00C/R0022/Ceiling Structures/Linings/S16			No Asbestos Detected
----------------------------	------------------	--	--	--	--	-----------------------------

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00D - General Learning - 1981 - Brick/Block (Brick/Block)**Exterior**

Underfloor Voids - Slab on Ground	No Asbestos Found					
Ceiling Voids - Raked Ceiling	No Asbestos Found					
Eaves Linings	Flat AC Sheeting 4529/B00D/Eaves Linings/S15					No Asbestos Detected

Interior**B00D - R0001 - Cleaning Supplies**

Floor Coverings Res/Textile	Vinyl Tiles 4529/B00D/R0003/Floor Coverings Res/Textile/S10					No Asbestos Detected
-----------------------------	--	--	--	--	--	-----------------------------

B00D - R0002 - Main Switch Board

Electrical Mounting Board	Millboard	1Unit	East	Good Condition (1)	Low (1)	Low Priority (2-3)
	4529/B00D/R0002/Electrical Mounting Board/S18					Chrysotile (white asbestos)

B00D - R0003 - Personal Effects Storage

Floor Coverings Res/Textile	Vinyl Tiles 4529/B00D/R0003/Floor Coverings Res/Textile/S10					No Asbestos Detected
-----------------------------	--	--	--	--	--	-----------------------------

B00D - R0004 - Practical Activities - 1hb

Floor Coverings Res/Textile	Vinyl Tiles 4529/B00D/R0003/Floor Coverings Res/Textile/S10					No Asbestos Detected
-----------------------------	--	--	--	--	--	-----------------------------

B00D - R0005 - Home Base Store

No Asbestos

B00D - R0006 - Home Base

No Asbestos

B00D - R0007 - Withdrawal Space - 1hb

No Asbestos

B00D - R0008 - Home Base

No Asbestos

B00D - R0009 - Home Base Store

No Asbestos

B00D - R0010 - General Storeroom

Floor Coverings Res/Textile	Vinyl Tiles 4529/B00D/R0003/Floor Coverings Res/Textile/S10					No Asbestos Detected
-----------------------------	--	--	--	--	--	-----------------------------

B00D - R0011 - External Movement

No Asbestos

B00D - R0012 - Toilets - Boys

No Asbestos

B00D - R0013 - Toilets - Girls

No Asbestos

B00D - R0014 - External Movement

Ceiling Structures/Linings	Flat AC Sheeting	33m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4529/B00D/R0014/Ceiling Structures/Linings/S9					Chrysotile (white asbestos)

B00D - R0017 - External Movement

Ceiling Structures/Linings	Flat AC Sheeting	10m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4529/B00D/R0014/Ceiling Structures/Linings/S9					Chrysotile (white asbestos)

B00D - R0018 - External Movement

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
Ceiling Structures/Linings	Flat AC Sheeting	17m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
4529/B00D/R0018/Ceiling Structures/Linings/S17					Chrysotile (white asbestos)	

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00E - General Learning - 1981 - Brick/Block (Brick/Block)

Exterior

Underfloor Voids - Slab on Ground	No Asbestos Found					
Ceiling Voids - Raked Ceiling	No Asbestos Found					
Eaves Linings	Flat AC Sheeting 4529/B00D/Eaves Linings/S15					No Asbestos Detected

Interior

B00E - R0001 - Practical Activities - 1hb

Floor Coverings Res/Textile	Vinyl Tiles 4529/B00E/R0001/Floor Coverings Res/Textile/S6					No Asbestos Detected
-----------------------------	---	--	--	--	--	-----------------------------

B00E - R0002 - General Storeroom

Floor Coverings Res/Textile	Vinyl Tiles 4529/B00E/R0001/Floor Coverings Res/Textile/S6					No Asbestos Detected
-----------------------------	---	--	--	--	--	-----------------------------

B00E - R0003 - Home Base Store

No Asbestos

B00E - R0004 - Home Base

No Asbestos

B00E - R0005 - Withdrawal Space - 1hb

No Asbestos

B00E - R0006 - Home Base

No Asbestos

B00E - R0007 - Home Base Store

No Asbestos

B00E - R0008 - Withdrawal Space - 1hb

No Asbestos

B00E - R0009 - Movement

Floor Coverings Res/Textile	Vinyl Tiles 4529/B00E/R0001/Floor Coverings Res/Textile/S6					No Asbestos Detected
-----------------------------	---	--	--	--	--	-----------------------------

B00E - R0010 - Toilets - Girls

No Asbestos

B00E - R0011 - Toilets - Boys

No Asbestos

B00E - R0012 - Cleaning Distributed Store

Floor Coverings Res/Textile	Vinyl Tiles 4529/B00E/R0001/Floor Coverings Res/Textile/S6					No Asbestos Detected
-----------------------------	---	--	--	--	--	-----------------------------

B00E - R0013 - Practical Activities - 1hb

Floor Coverings Res/Textile	Vinyl Tiles 4529/B00E/R0001/Floor Coverings Res/Textile/S6					No Asbestos Detected
-----------------------------	---	--	--	--	--	-----------------------------

B00E - R0014 - Home Base

No Asbestos

B00E - R0015 - Withdrawal Space - 1hb

No Asbestos

B00E - R0016 - Home Base Store

No Asbestos

B00E - R0017 - Home Base

No Asbestos

B00E - R0018 - Home Base Store

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

No Asbestos

B00E - R0019 - Craft Store

Floor Coverings Res/Textile	Vinyl Tiles					
4529/B00E/R0001/Floor Coverings Res/Textile/S6					No Asbestos Detected	

B00E - R0020 - Personal Effects Storage

Ceiling Structures/Linings	Flat AC Sheeting	10m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
4529/B00E/R0020/Ceiling Structures/Linings/S5					Chrysotile (white asbestos)	

B00E - R0021 - Personal Effects Storage

Ceiling Structures/Linings	Flat AC Sheeting	10m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
4529/B00E/R0020/Ceiling Structures/Linings/S5					Chrysotile (white asbestos)	

B00E - R0022 - Personal Effects Storage

Ceiling Structures/Linings	Flat AC Sheeting	9m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
4529/B00E/R0020/Ceiling Structures/Linings/S5					Chrysotile (white asbestos)	

B00E - R0023 - Personal Effects Storage

Ceiling Structures/Linings	Flat AC Sheeting	9m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
4529/B00E/R0020/Ceiling Structures/Linings/S5					Chrysotile (white asbestos)	

B00E - R0024 - Movement

Ceiling Structures/Linings	Flat AC Sheeting	24m2	South	Good Condition (1)	Low (1)	Low Priority (2-3)
4529/B00E/R0020/Ceiling Structures/Linings/S5					Chrysotile (white asbestos)	

B00E - R0025 - Movement

No Asbestos

B00E - R0026 - Distribution Board

Note: No inspection of live electrical installation.

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00F - General Learning - 1981 - Brick/Block (Brick/Block)

Exterior

Underfloor Voids - Slab on Ground	No Asbestos Found					
Ceiling Voids - Raked Ceiling	No Asbestos Found					
Eaves Linings	Flat AC Sheeting 4529/B00D/Eaves Linings/S15					No Asbestos Detected

Interior

B00F - R0001 - Practical Activities - 1hb

Floor Coverings Res/Textile	Vinyl Tiles 4529/B00F/R0001/Floor Coverings Res/Textile/S13					No Asbestos Detected
-----------------------------	--	--	--	--	--	-----------------------------

B00F - R0002 - General Storeroom

Floor Coverings Res/Textile	Vinyl Tiles 4529/B00F/R0001/Floor Coverings Res/Textile/S13					No Asbestos Detected
-----------------------------	--	--	--	--	--	-----------------------------

B00F - R0003 - Home Base

No Asbestos

B00F - R0004 - Home Base Store

No Asbestos

B00F - R0005 - Withdrawal Space - 1hb

No Asbestos

B00F - R0006 - Home Base

No Asbestos

B00F - R0007 - Home Base Store

No Asbestos

B00F - R0008 - Special Programs Room

No Asbestos

B00F - R0009 - Movement

Floor Coverings Res/Textile	Vinyl Tiles 4529/B00F/R0001/Floor Coverings Res/Textile/S13					No Asbestos Detected
-----------------------------	--	--	--	--	--	-----------------------------

B00F - R0010 - Distribution Board

Note: No inspection of live electrical installation.

No Asbestos

B00F - R0011 - Cleaning Distributed Store

Floor Coverings Res/Textile	Vinyl Tiles 4529/B00F/R0001/Floor Coverings Res/Textile/S13					No Asbestos Detected
-----------------------------	--	--	--	--	--	-----------------------------

B00F - R0012 - Toilets - Boys

No Asbestos

B00F - R0013 - Toilets - Girls

No Asbestos

B00F - R0014 - Movement

Ceiling Structures/Linings	Flat AC Sheeting	24m2	South	Good Condition (1)	Low (1)	Low Priority (2-3)
	4529/B00F/R0014/Ceiling Structures/Linings/S7					Chrysotile (white asbestos)

B00F - R0015 - Movement

Ceiling Structures/Linings	Flat AC Sheeting	10m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4529/B00F/R0014/Ceiling Structures/Linings/S7					Chrysotile (white asbestos)

B00F - R0016 - Movement

Ceiling Structures/Linings	Flat AC Sheeting	10m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	4529/B00F/R0014/Ceiling Structures/Linings/S7					Chrysotile (white asbestos)

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00F - R0017 - General Storeroom

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00G - General Learning - 2010 - Brick/Veneer (Brick/Veneer)

Exterior

Underfloor Voids - Slab on Ground	No Asbestos Found
Ceiling Voids	No Asbestos Found

Interior

B00G - R0001 - Practical Activities - 1hb

No Asbestos

B00G - R0002 - Home Base

No Asbestos

B00G - R0003 - Home Base Store

No Asbestos

B00G - R0004 - Withdrawal Space - 2hb

No Asbestos

B00G - R0005 - Practical Activities - 1hb

No Asbestos

B00G - R0006 - Home Base

No Asbestos

B00G - R0007 - Home Base Store

No Asbestos

B00G - R0008 - Practical Activities - 1hb

No Asbestos

B00G - R0009 - Home Base

No Asbestos

B00G - R0010 - Home Base Store

No Asbestos

B00G - R0011 - Withdrawal Space - 2hb

No Asbestos

B00G - R0012 - Practical Activities - 1hb

No Asbestos

B00G - R0013 - Home Base

No Asbestos

B00G - R0014 - Home Base Store

No Asbestos

B00G - R0015 - External Movement

No Asbestos

B00G - R0016 - Distribution Board

Note: No inspection of live electrical installation.

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

Demountables

Demountable details as per the AMS records as of 15 Feb 2017.

OS 602 - D10149 - Learning Unit - Standard With P.A.A. : Placement Date - 31/12/2013

Note: This refurbished demountable may have asbestos present in remnant mastic in window frames.

Exterior

No Asbestos Found.

Interior

R1 - Learning space/withdrawal/entry

No Asbestos Found.

R2 - Home Base Store

No Asbestos Found.

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

Listing of Electronic Attachments as of 22/03/2017

There are no asbestos related file attachment(s) for this school.

2017