


# Asbestos Register

(Hazardous Materials and Risk Assessment)

**School :** Prairiewood High School (8560)  
**Region :** South Western Sydney  
**State Electorate :** Prospect  
**Local Government Area :** Fairfield

**Initial Survey :** Noel Arnold & Associates : 07 - Mar - 2008  
**Reviewed By :** Parsons Brinckerhoff : 11 - Sep - 2015



2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B00D - Science Learning/Technological & Applied Studies - 1985 - Brick/Block (Brick/Block)**

**Exterior**

Ceiling Voids	No Asbestos Found
Underfloor Voids	No Asbestos Found

**Interior**

**B00D - R0001 - Staff Lounge**

No Asbestos

**B00D - R0002 - Main Switchroom**

Non Accessible

**B00D - R0003 - External Movement**

Ceiling Structures/Linings	Flat AC Sheeting								
	8560/B00D/R0003/Ceiling Structures/Linings/S16								<b>No Asbestos Detected</b>
In-fill-panel	Compressed AC Sheet	3m	West, Lower portion	Good Condition (1)	Low (1)	Low Priority (2-3)			
	8560/B00D/R0003/In-fill-panel/S11								<b>Chrysotile (white asbestos)</b>

**B00D - R0005 - Laboratory L.S.**

No Asbestos

**B00D - R0006 - Preparation - Science**

No Asbestos

**B00D - R0007 - Laboratory L.S.**

No Asbestos

**B00D - R0008 - Apparatus Storage**

No Asbestos

**B00D - R0009 - Chemical Store**

No Asbestos

**B00D - R0010 - Laboratory L.S.**

No Asbestos

**B00D - R0011 - Seminar**

No Asbestos

**B00D - R0012 - Laboratory L.S.**

No Asbestos

**B00D - R0013 - Toilets-Disabled**

No Asbestos

**B00D - R0014 - Distribution Board Cupboard**

Note: No inspection of live electrical installation.

No Asbestos

**B00D - R0015 - Cleaning Store - Distributed**

Non Accessible

**B00D - R0016 - Laboratory L.S.**

No Asbestos

**B00D - R0017 - Preparation - Science**

No Asbestos

**B00D - R0018 - Laboratory L.S.**

No Asbestos

**B00D - R0019 - Movement**

No Asbestos

**B00D - R0020 - External Stairs**

No Asbestos

**B00D - R0021 - Staff Study**

No Asbestos

**B00D - R0022 - Tea Room**

No Asbestos

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
<b>B00D - R1001 - Resources Store</b>						
No Asbestos						
<b>B00D - R1002 - Distribution Board Cupboard</b>					Note: No inspection of live electrical installation.	
No Asbestos						
<b>B00D - R1003 - Food Technology L.S.</b>						
No Asbestos						
<b>B00D - R1004 - Preparation - Materials</b>						
No Asbestos						
<b>B00D - R1005 - Resources Store</b>						
No Asbestos						
<b>B00D - R1006 - Food Technology L.S.</b>						
No Asbestos						
<b>B00D - R1007 - Textiles Technology L.S.</b>						
No Asbestos						
<b>B00D - R1008 - Laundry</b>						
No Asbestos						
<b>B00D - R1009 - Computer Learning Space</b>						
No Asbestos						
<b>B00D - R1011 - Movement</b>						
No Asbestos						
<b>B00D - R1012 - External Movement</b>						
In-fill-panel	Compressed AC Sheet	3m	North, Lower portion	Good Condition (1)	Low (1)	Low Priority (2-3)
	8560/B00D/R0003/In-fill-panel/S11					<b>Chrysotile (white asbestos)</b>
<b>B00D - R1013 - External Stairs</b>						
No Asbestos						
<b>B00D - R1014 - Staff Study</b>						
No Asbestos						
<b>B00D - R1015 - Tea Room</b>						
No Asbestos						

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B00E - Administration - 1985 - Brick/Block (Brick/Block)**

**Exterior**

Ceiling Voids	No Asbestos Found
Underfloor Voids	No Asbestos Found

**Interior**

**B00E - R0001 - Leading Teacher**

No Asbestos

**B00E - R0002 - Deputy Principal Office**

No Asbestos

**B00E - R0003 - Toilets-Boys**

Partition Walls (Cubicles)	Compressed AC Sheet					
	8560/B00E/R1001/Partition Walls (Cubicles)/S10					<b>No Asbestos Detected</b>

**B00E - R0004 - Toilets-Girls**

Partition Walls (Cubicles)	Compressed AC Sheet					
	8560/B00E/R1001/Partition Walls (Cubicles)/S10					<b>No Asbestos Detected</b>

**B00E - R0005 - First Aid**

No Asbestos

**B00E - R0006 - Secure Storeroom**

No Asbestos

**B00E - R0007 - Distribution Board Cupboard**

Note: No inspection of live electrical installation.

No Asbestos

**B00E - R0008 - Principal Office**

No Asbestos

**B00E - R0009 - External Movement**

In-fill-panel	Compressed AC Sheet	5m	North, Lower portion	Good Condition (1)	Low (1)	Low Priority (2-3)
	8560/B00E/R0009/In-fill-panel/S17					<b>Chrysotile (white asbestos)</b>

**B00E - R0010 - Interview/Office - Type 1**

No Asbestos

**B00E - R0011 - Administration - Clerical**

No Asbestos

**B00E - R0012 - Administration - Clerical**

No Asbestos

**B00E - R0013 - Printing/Photocopying**

No Asbestos

**B00E - R0014 - Staff - Toilet**

Partition Walls (Cubicles)	Compressed AC Sheet					
	8560/B00E/R1001/Partition Walls (Cubicles)/S10					<b>No Asbestos Detected</b>

**B00E - R0015 - Movement**

No Asbestos

**B00E - R0016 - Stairs**

No Asbestos

**B00E - R1001 - Staff - Toilet**

Partition Walls (Cubicles)	Compressed AC Sheet					
	8560/B00E/R1001/Partition Walls (Cubicles)/S10					<b>No Asbestos Detected</b>

**B00E - R1002 - Staff - Toilet**

Partition Walls (Cubicles)	Compressed AC Sheet					
	8560/B00E/R1001/Partition Walls (Cubicles)/S10					<b>No Asbestos Detected</b>

**B00E - R1003 - Deputy Principal Office**

No Asbestos

**B00E - R1006 - General Storeroom**

Non Accessible

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
<b>B00E - R1007 - Movement</b>						
No Asbestos						
<b>B00E - R1008 - Stairs</b>						
No Asbestos						
<b>B00E - R1011 - Interview/Office - Type 1</b>						
No Asbestos						
<b>B00E - R1012 - Tea Room</b>						
No Asbestos						
<b>B00E - R1013 - Interview/Office - Type 1</b>						
No Asbestos						
<b>B00E - R1014 - Interview/Office - Type 2</b>						
No Asbestos						
<b>B00E - R1015 - Staff Kitchen</b>						
No Asbestos						
<b>B00E - R1016 - Commonroom</b>						
No Asbestos						

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B00F - Art/Music/Performance Learning - 1985 - Brick/Block (Brick/Block)**

**Exterior**

Ceiling Voids	No Asbestos Found
Underfloor Voids	No Asbestos Found

**Interior**

**B00F - R0001 - Multi Media Workshop**

No Asbestos

**B00F - R0002 - Multi Media Workshop**

No Asbestos

**B00F - R0003 - Resources Store**

No Asbestos

**B00F - R0005 - Art Learning Space**

No Asbestos

**B00F - R0006 - Workshop**

No Asbestos

**B00F - R0007 - Kiln Space**

No Asbestos

**B00F - R0008 - Art Learning Space**

No Asbestos

**B00F - R0009 - External Movement**

Ceiling Structures/Linings	Flat AC Sheeting 8560/B00F/R0009/Ceiling Structures/Linings/S8	<b>No Asbestos Detected</b>
In-fill-panel	Compressed AC Sheet 8560/B00F/R0009/In-fill-panel/S9	<b>No Asbestos Detected</b>

**B00F - R0010 - Art Learning Space**

No Asbestos

**B00F - R0011 - Resources Store**

No Asbestos

**B00F - R0012 - Distribution Board Cupboard**

Note: No inspection of live electrical installation.

No Asbestos

**B00F - R0014 - External Stairs**

No Asbestos

**B00F - R0015 - Tea Room**

No Asbestos

**B00F - R0016 - Staff Study**

No Asbestos

**B00F - R0017 - Movement**

No Asbestos

**B00F - R0018 - Workshop**

No Asbestos

**B00F - R1001 - Staff Study**

No Asbestos

**B00F - R1003 - Music Store**

No Asbestos

**B00F - R1004 - Performance Workshop**

No Asbestos

**B00F - R1005 - Staff Study**

No Asbestos

**B00F - R1006 - Music Learning Space**

No Asbestos

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
<b>B00F - R1007 - Music Learning Space</b>						
No Asbestos						
<b>B00F - R1008 - Practice/Seminar</b>						
No Asbestos						
<b>B00F - R1009 - Cleaning Store - Distributed</b>						
No Asbestos						
<b>B00F - R1010 - Distribution Board Cupboard</b>				Note: No inspection of live electrical installation.		
No Asbestos						
<b>B00F - R1012 - Performance Store</b>						
No Asbestos						
<b>B00F - R1013 - Performance Store</b>						
No Asbestos						
<b>B00F - R1014 - Movement</b>						
No Asbestos						
<b>B00F - R1015 - Movement</b>						
In-fill-panel	Compressed AC Sheet					No Asbestos Detected
	8560/B00F/R0009/In-fill-panel/S9					
<b>B00F - R1016 - External Movement</b>						
In-fill-panel	Compressed AC Sheet					No Asbestos Detected
	8560/B00F/R0009/In-fill-panel/S9					
<b>B00F - R1017 - External Stairs</b>						
No Asbestos						
<b>B00F - R1018 - Student Lounge</b>						
No Asbestos						
<b>B00F - R1019 - Handwashing Facilities</b>						
No Asbestos						
<b>B00F - R1020 - Darkroom Space</b>						
No Asbestos						
<b>B00F - R1021 - Dark Room</b>						
No Asbestos						
<b>B00F - R1022 - General Storeroom</b>						
No Asbestos						

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B00G - Technological & Applied Studies - 1985 - Brick/Block (Brick/Block)**

**Exterior**

Ceiling Voids	No Asbestos Found
Underfloor Voids	No Asbestos Found

**Interior**

**B00G - R0001 - General Storeroom**

No Asbestos

**B00G - R0002 - Class Tools Storage**

No Asbestos

**B00G - R0003 - Metal Technology L.S.**

Floor Coverings Res/Textile	Vinyl Sheet	8560/B00G/R0013/Floor Coverings Res/Textile/S7	No Asbestos Detected
-----------------------------	-------------	--	----------------------

**B00G - R0004 - Metal Technology Bay**

Floor Coverings Res/Textile	Vinyl Sheet	8560/B00G/R0013/Floor Coverings Res/Textile/S7	No Asbestos Detected
-----------------------------	-------------	--	----------------------

**B00G - R0005 - Metal Technology L.S.**

Floor Coverings Res/Textile	Vinyl Sheet	8560/B00G/R0013/Floor Coverings Res/Textile/S7	No Asbestos Detected
-----------------------------	-------------	--	----------------------

**B00G - R0006 - Wood Technology L.S.**

Floor Coverings Res/Textile	Vinyl Sheet	8560/B00G/R0013/Floor Coverings Res/Textile/S7	No Asbestos Detected
-----------------------------	-------------	--	----------------------

**B00G - R0007 - Wood Technology Bay**

Floor Coverings Res/Textile	Vinyl Sheet	8560/B00G/R0013/Floor Coverings Res/Textile/S7	No Asbestos Detected
-----------------------------	-------------	--	----------------------

**B00G - R0008 - Wood Technology L.S.**

Floor Coverings Res/Textile	Vinyl Sheet	8560/B00G/R0013/Floor Coverings Res/Textile/S7	No Asbestos Detected
-----------------------------	-------------	--	----------------------

**B00G - R0009 - Materials Store**

No Asbestos

**B00G - R0010 - Cleaning Store - Distributed**

Non Accessible

**B00G - R0011 - Materials Store**

No Asbestos

**B00G - R0012 - Distribution Board Cupboard**

Note: No inspection of live electrical installation.

No Asbestos

**B00G - R0013 - Movement**

Floor Coverings Res/Textile	Vinyl Sheet	8560/B00G/R0013/Floor Coverings Res/Textile/S7	No Asbestos Detected
-----------------------------	-------------	--	----------------------

**B00G - R0014 - External Movement**

No Asbestos

**B00G - R0015 - Staff - Toilet**

Partition Walls (Cubicles)	Compressed AC Sheet	8560/B00G/R0015/Partition Walls (Cubicles)/S6	No Asbestos Detected
----------------------------	---------------------	---	----------------------

**B00G - R0016 - Dust Extraction Space**

No Asbestos

**B00G - R0017 - External Movement**

No Asbestos



Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
<b>B00G - R0019 - L.P.G. Store</b>						
No Asbestos						
<b>B00G - R0020 - Stairs</b>						
No Asbestos						
<b>B00G - R1003 - General Storeroom</b>						
No Asbestos						
<b>B00G - R1004 - Computer Learning Space</b>						
No Asbestos						
<b>B00G - R1005 - Movement</b>						
No Asbestos						
<b>B00G - R1006 - Stairs</b>						
No Asbestos						
<b>B00G - R1007 - Staff Study</b>						
No Asbestos						
<b>B00G - R1008 - Tea Room</b>						
No Asbestos						
<b>B00G - R1009 - Design/Technology L.S.</b>						
No Asbestos						
<b>B00G - R1010 - Handwashing Facilities</b>						
No Asbestos						

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B00H - Pupil Facilities - 1985 - Brick/Block (Brick/Block)**

**Exterior**

Ceiling Voids	No Asbestos Found
Underfloor Voids	No Asbestos Found

**Interior**

**B00H - R0001 - Toilets-Boys**

Partition Walls (Cubicles)	Compressed AC Sheet 8560/B00H/R0001/Partition Walls (Cubicles)/S5	No Asbestos Detected
----------------------------	--	----------------------

**B00H - R0002 - Student Drinking Facilities**

Ceiling Structures/Linings	Flat AC Sheeting 8560/B00H/R0002/Ceiling Structures/Linings/S18	No Asbestos Detected
----------------------------	--	----------------------

**B00H - R0003 - Toilets-Girls**

Partition Walls (Cubicles)	Compressed AC Sheet 8560/B00H/R0001/Partition Walls (Cubicles)/S5	No Asbestos Detected
----------------------------	--	----------------------

**B00H - R0004 - Student Canteen**

No Asbestos

**B00H - R0005 - Office/Store**

No Asbestos

**B00H - R0007 - Vending Machines**

No Asbestos

**B00H - R0008 - External Movement**

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B00J - Multi Purpose Facilities/Physical Education - 1985 - Brick/Block (Brick/Block)**

**Exterior**

Ceiling Voids	No Asbestos Found
Underfloor Voids	No Asbestos Found

**Interior**

**B00J - M0001 - Movement**

No Asbestos

**B00J - M0002 - Control Room**

No Asbestos

**B00J - M0003 - General Storeroom**

No Asbestos

**B00J - M0004 - General Storeroom**

No Asbestos

**B00J - M0005 - Stairs**

No Asbestos

**B00J - M0006 - Stairs**

No Asbestos

**B00J - M0007 - Stairs**

No Asbestos

**B00J - R0001 - General Assistants**

Floor Coverings Res/Textile	Vinyl Sheet					
		8560/B00J/R0015/Floor Coverings Res/Textile/S2				<b>No Asbestos Detected</b>

**B00J - R0002 - Garden Store Room**

No Asbestos

**B00J - R0003 - Multi-Purpose Space**

No Asbestos

**B00J - R0005 - Movement**

No Asbestos

**B00J - R0006 - Stage**

No Asbestos

**B00J - R0007 - External Movement**

No Asbestos

**B00J - R0008 - Movement**

No Asbestos

**B00J - R0009 - General Storeroom**

No Asbestos

**B00J - R0010 - Movement**

No Asbestos

**B00J - R0011 - External Movement**

No Asbestos

**B00J - R0012 - Movement**

No Asbestos

**B00J - R0014 - Sport Equipment Store**

Floor Coverings Res/Textile	Vinyl Sheet					
		8560/B00J/R0015/Floor Coverings Res/Textile/S2				<b>No Asbestos Detected</b>

**B00J - R0015 - Staff Kitchen**

Floor Coverings Res/Textile	Vinyl Sheet					
		8560/B00J/R0015/Floor Coverings Res/Textile/S2				<b>No Asbestos Detected</b>

**B00J - R0016 - Movement**

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
No Asbestos						
<b>B00J - R0018 - External Movement</b>						
No Asbestos						
<b>B00J - R0019 - Toilets-Boys</b>						
Partition Walls (Cubicles)	Compressed AC Sheet					
	8560/B00J/R0020/Partition Walls (Cubicles)/S1					<b>No Asbestos Detected</b>
<b>B00J - R0020 - Toilets-Girls</b>						
Partition Walls (Cubicles)	Compressed AC Sheet					
	8560/B00J/R0020/Partition Walls (Cubicles)/S1					<b>No Asbestos Detected</b>
<b>B00J - R0021 - Movement</b>						
No Asbestos						
<b>B00J - R0023 - Fitness Laboratory</b>						
No Asbestos						
<b>B00J - R0024 - Movement</b>						
No Asbestos						
<b>B00J - R0025 - Distribution Board Cupboard</b>					Note: No inspection of live electrical installation.	
Ceiling Structures/Linings	Flat AC Sheeting					
	8560/B00J/R0025/Ceiling Structures/Linings/S4					<b>No Asbestos Detected</b>
<b>B00J - R0026 - Sport Equipment Store</b>						
No Asbestos						
<b>B00J - R0028 - Toilets-Disabled</b>						
No Asbestos						
<b>B00J - R0029 - Cleaning Store - Distributed</b>						
No Asbestos						
<b>B00J - R0030 - Sport Equipment Store</b>						
No Asbestos						
<b>B00J - R0031 - Movement</b>						
No Asbestos						
<b>B00J - R0032 - L.P.G. Store</b>						
No Asbestos						
<b>B00J - R0033 - Resources Store</b>						
Floor Coverings Res/Textile	Vinyl Sheet					
	8560/B00J/R0015/Floor Coverings Res/Textile/S2					<b>No Asbestos Detected</b>
<b>B00J - R0034 - Cleaning Supplies Store</b>						
Floor Coverings Res/Textile	Vinyl Sheet					
	8560/B00J/R0015/Floor Coverings Res/Textile/S2					<b>No Asbestos Detected</b>
<b>B00J - R0035 - Sport Equipment Store</b>						
No Asbestos						
<b>B00J - R0036 - Plant</b>						
Ceiling Structures/Linings	Flat AC Sheeting					
	8560/B00J/R0036/Ceiling Structures/Linings/S3					<b>No Asbestos Detected</b>
<b>B00J - R0037 - Other-Vacant</b>						
No Asbestos						
<b>B00J - R0038 - Stairs</b>						
No Asbestos						
<b>B00J - R0039 - Stairs</b>						
No Asbestos						
<b>B00J - R0040 - Stairs</b>						
No Asbestos						
<b>B00J - R0043 - Covered Area</b>						

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
	<b>Sample No</b>					<b>Test Result</b>

No Asbestos

**B00J - R0044 - External Movement**

No Asbestos

**B00J - R0045 - Student Drinking Facilities**

No Asbestos

**B00J - R0046 - Student Drinking Facilities**

No Asbestos

**B00J - R0047 - Movement**

No Asbestos

**B00J - R0048 - Movement**

No Asbestos

**B00J - R0049 - Plant**

No Asbestos

**B00J - R0050 - Staff Study**

No Asbestos

**B00J - R0051 - Tea Room**

No Asbestos

**B00J - R0052 - Change**

No Asbestos

**B00J - R0053 - Plant**

No Asbestos

**B00J - R0054 - Change**

No Asbestos

**B00J - R0055 - Plant**

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B00K - Agricultural Science - 1985 - Brick/Veneer (Brick/Veneer)**

**Exterior**

Eaves Linings	Flat AC Sheeting	15m2	North, South	Good Condition (1)	Low (1)	Low Priority (2-3)
---------------	------------------	------	--------------	--------------------	---------	--------------------

**Assumed Asbestos - No Access**

Ceiling Voids	No Asbestos Found
---------------	-------------------

Underfloor Voids	No Asbestos Found
------------------	-------------------

**Interior**

**B00K - R0001 - Chemical Store**

Wall Linings Internal	Flat AC Sheeting					<b>No Asbestos Detected</b>
	8560/B00K/R0003/Wall Linings Internal/S15					

**B00K - R0002 - Movement**

Wall Linings Internal	Flat AC Sheeting					<b>No Asbestos Detected</b>
	8560/B00K/R0003/Wall Linings Internal/S15					

**B00K - R0003 - General Storeroom**

Wall Linings Internal	Flat AC Sheeting					<b>No Asbestos Detected</b>
	8560/B00K/R0003/Wall Linings Internal/S15					

**B00K - R0004 - Animal Space**

Wall Linings Internal	Flat AC Sheeting					<b>No Asbestos Detected</b>
	8560/B00K/R0003/Wall Linings Internal/S15					

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B00L - Other - 1983 - Brick/Block (Brick/Block)**

**Exterior**

No Asbestos

**Interior**

**B00L - R0001 - Plant**

No Asbestos

**B00L - R0002 - No Access**

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B00M - Movement Complex - 2009 - Brick/Veneer (Brick/Veneer)**

**Exterior**

No Asbestos

**Interior**

**B00M - R0001 - Movement Studio**

No Asbestos

**B00M - R0002 - General Storeroom**

No Asbestos

**B00M - R0003 - Cleaning Store - Distributed**

No Asbestos

**B00M - R0004 - Toilets-Boys**

No Asbestos

**B00M - R0005 - Toilets-Girls**

No Asbestos

**B00M - R0006 - Toilets-Girls**

No Asbestos

**B00M - R0007 - External Movement**

No Asbestos

2017



Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B00N - Agricultural Science - 2007 - Brick/Veneer (Brick/Veneer)**

**Exterior**

No Asbestos

**Interior**

**B00N - R0001 - Staff - Toilet**

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B000 - Science Learning - 2010 - Fibre Cement Clad (Fibre Cement Clad)**

**Exterior**

No Asbestos

**Interior**

**B000 - R0001 - Science Laboratory**

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B00P - Agricultural Science - 2007 - Metal Shed (Metal Shed)**

**Exterior**

No Asbestos

**Interior**

**B00P - R0001 - Machine Storage**

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B00Q - Agricultural Science - 2007 - Metal Shed (Metal Shed)**

**Exterior**

No Asbestos

**Interior**

**B00Q - R0001 - Class Tools Storage**

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**BABC - General Learning/Library/Student Services - 1985 - Brick/Block (Brick/Block)**

**Exterior**

Eaves Linings	Flat AC Sheeting	130m2	North	Good Condition (1)	Low (1)	Low Priority (2-3)
<b>Assumed Asbestos - No Access Due to Height Restrictions</b>						
In-fill-panel	Compressed AC Sheet 8560/BABC/In-fill-panel/S19					<b>No Asbestos Detected</b>
Ceiling Voids	No Asbestos Found					
Underfloor Voids	No Asbestos Found					

**Interior**

**BABC - R0A01 - General Learning Space**

In-fill-panel	Compressed AC Sheet 8560/BABC/R1A09/In-fill-panel/S12					<b>No Asbestos Detected</b>
---------------	--	--	--	--	--	-----------------------------

**BABC - R0A02 - General Learning Space**

In-fill-panel	Compressed AC Sheet 8560/BABC/R1A09/In-fill-panel/S12					<b>No Asbestos Detected</b>
---------------	--	--	--	--	--	-----------------------------

**BABC - R0A03 - General Learning Space**

In-fill-panel	Compressed AC Sheet 8560/BABC/R1A09/In-fill-panel/S12					<b>No Asbestos Detected</b>
---------------	--	--	--	--	--	-----------------------------

**BABC - R0A04 - General Learning Space**

In-fill-panel	Compressed AC Sheet 8560/BABC/R1A09/In-fill-panel/S12					<b>No Asbestos Detected</b>
---------------	--	--	--	--	--	-----------------------------

**BABC - R0A05 - General Learning Space**

In-fill-panel	Compressed AC Sheet 8560/BABC/R1A09/In-fill-panel/S12					<b>No Asbestos Detected</b>
---------------	--	--	--	--	--	-----------------------------

**BABC - R0A06 - General Learning Space**

In-fill-panel	Compressed AC Sheet 8560/BABC/R1A09/In-fill-panel/S12					<b>No Asbestos Detected</b>
---------------	--	--	--	--	--	-----------------------------

**BABC - R0A07 - General Learning Space**

In-fill-panel	Compressed AC Sheet 8560/BABC/R1A09/In-fill-panel/S12					<b>No Asbestos Detected</b>
---------------	--	--	--	--	--	-----------------------------

**BABC - R0A08 - General Learning Space**

No Asbestos

**BABC - R0A10 - Secure Storeroom**

No Asbestos

**BABC - R0A11 - Resources Store**

No Asbestos

**BABC - R0A13 - Cleaning Store - Distributed**

No Asbestos

**BABC - R0A14 - External Movement**

No Asbestos

**BABC - R0A15 - Stairs**

No Asbestos

**BABC - R0A16 - Staff Study**

No Asbestos

**BABC - R0A17 - Tea Room**

No Asbestos

**BABC - R0A18 - Movement**

No Asbestos

**BABC - R0A19 - Movement**

No Asbestos

**BABC - R0B02 - Staff - Toilet**

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
Wall Linings Internal	Flat AC Sheeting					No Asbestos Detected
	8560/BABC/R0B02/Wall Linings Internal/S14					
Partition Walls (Cubicles)	Compressed AC Sheet					No Asbestos Detected
	8560/BABC/R1B06/Partition Walls (Cubicles)/S13					
<b>BABC - R0B03 - Staff Study</b>						
No Asbestos						
<b>BABC - R0B04 - Toilets-Girls</b>						
Partition Walls (Cubicles)	Compressed AC Sheet					No Asbestos Detected
	8560/BABC/R1B06/Partition Walls (Cubicles)/S13					
<b>BABC - R0B05 - Distribution Board Cupboard</b>				Note: No inspection of live electrical installation.		
No Asbestos						
<b>BABC - R0B06 - Audio Visual Workroom</b>						
No Asbestos						
<b>BABC - R0B07 - Seminar</b>						
No Asbestos						
<b>BABC - R0B08 - Seminar</b>						
No Asbestos						
<b>BABC - R0B12 - Resources Store</b>						
No Asbestos						
<b>BABC - R0B14 - Cleaning Supplies Store</b>						
Non Accessible						
<b>BABC - R0B15 - Staff - Toilet</b>						
Partition Walls (Cubicles)	Compressed AC Sheet					No Asbestos Detected
	8560/BABC/R1B06/Partition Walls (Cubicles)/S13					
<b>BABC - R0B16 - Interview/Office - Type 1</b>						
No Asbestos						
<b>BABC - R0B17 - Staff - Toilet</b>						
Partition Walls (Cubicles)	Compressed AC Sheet					No Asbestos Detected
	8560/BABC/R1B06/Partition Walls (Cubicles)/S13					
<b>BABC - R0B18 - Distribution Board Cupboard</b>				Note: No inspection of live electrical installation.		
No Asbestos						
<b>BABC - R0B20 - External Movement</b>						
In-fill-panel	Compressed AC Sheet					No Asbestos Detected
	8560/BABC/R1A09/In-fill-panel/S12					
<b>BABC - R0B21 - External Movement</b>						
In-fill-panel	Compressed AC Sheet					No Asbestos Detected
	8560/BABC/R1A09/In-fill-panel/S12					
<b>BABC - R0B22 - External Movement</b>						
In-fill-panel	Compressed AC Sheet					No Asbestos Detected
	8560/BABC/R1A09/In-fill-panel/S12					
<b>BABC - R0B23 - Stairs</b>						
No Asbestos						
<b>BABC - R0B24 - Movement</b>						
No Asbestos						
<b>BABC - R0B25 - Student Drinking Facilities</b>						
No Asbestos						
<b>BABC - R0B26 - Student Drinking Facilities</b>						
No Asbestos						
<b>BABC - R0B27 - Movement</b>						
No Asbestos						
<b>BABC - R0B28 - Ramp</b>						
No Asbestos						

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
<b>BABC - R0B29 - Tiered Learning Area</b>						
No Asbestos						
<b>BABC - R0B30 - Main Area</b>						
No Asbestos						
<b>BABC - R0B31 - Library Administration</b>						
No Asbestos						
<b>BABC - R0B32 - Tea Room</b>						
No Asbestos						
<b>BABC - R0C01 - Special Learning Space</b>						
In-fill-panel	Compressed AC Sheet					No Asbestos Detected
	8560/BABC/R1A09/In-fill-panel/S12					
<b>BABC - R0C02 - Special Learning Space</b>						
In-fill-panel	Compressed AC Sheet					No Asbestos Detected
	8560/BABC/R1A09/In-fill-panel/S12					
<b>BABC - R0C03 - General Learning Space</b>						
In-fill-panel	Compressed AC Sheet					No Asbestos Detected
	8560/BABC/R1A09/In-fill-panel/S12					
<b>BABC - R0C04 - General Learning Space</b>						
In-fill-panel	Compressed AC Sheet					No Asbestos Detected
	8560/BABC/R1A09/In-fill-panel/S12					
<b>BABC - R0C05 - General Learning Space</b>						
In-fill-panel	Compressed AC Sheet					No Asbestos Detected
	8560/BABC/R1A09/In-fill-panel/S12					
<b>BABC - R0C06 - General Learning Space</b>						
In-fill-panel	Compressed AC Sheet					No Asbestos Detected
	8560/BABC/R1A09/In-fill-panel/S12					
<b>BABC - R0C07 - General Learning Space</b>						
In-fill-panel	Compressed AC Sheet					No Asbestos Detected
	8560/BABC/R1A09/In-fill-panel/S12					
<b>BABC - R0C08 - General Learning Space</b>						
In-fill-panel	Compressed AC Sheet					No Asbestos Detected
	8560/BABC/R1A09/In-fill-panel/S12					
<b>BABC - R0C09 - Movement</b>						
In-fill-panel	Compressed AC Sheet					No Asbestos Detected
	8560/BABC/R1A09/In-fill-panel/S12					
<b>BABC - R0C10 - Cleaning Store - Distributed</b>						
Non Accessible						
<b>BABC - R0C12 - Senior Study</b>						
No Asbestos						
<b>BABC - R0C13 - Distribution Board Cupboard</b>						
					Note: No inspection of live electrical installation.	
No Asbestos						
<b>BABC - R0C14 - Archive Store</b>						
No Asbestos						
<b>BABC - R0C15 - Office/Store</b>						
No Asbestos						
<b>BABC - R0C16 - Secure Storeroom</b>						
No Asbestos						
<b>BABC - R0C17 - Stairs</b>						
No Asbestos						
<b>BABC - R0C18 - External Movement</b>						
In-fill-panel	Compressed AC Sheet					No Asbestos Detected
	8560/BABC/R1A09/In-fill-panel/S12					
<b>BABC - R0C19 - Movement</b>						

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
No Asbestos						
<b>BABC - R0C20 - Staff Study</b>						
No Asbestos						
<b>BABC - R0C21 - Tea Room</b>						
No Asbestos						
<b>BABC - R1A01 - General Learning Space</b>						
No Asbestos						
<b>BABC - R1A02 - General Learning Space</b>						
No Asbestos						
<b>BABC - R1A03 - General Learning Space</b>						
No Asbestos						
<b>BABC - R1A04 - General Learning Space</b>						
No Asbestos						
<b>BABC - R1A05 - General Learning Space</b>						
No Asbestos						
<b>BABC - R1A06 - General Learning Space</b>						
No Asbestos						
<b>BABC - R1A07 - General Learning Space</b>						
No Asbestos						
<b>BABC - R1A08 - Computer Learning Space</b>						
No Asbestos						
<b>BABC - R1A09 - Movement</b>						
In-fill-panel	Compressed AC Sheet					
	8560/BABC/R1A09/In-fill-panel/S12					<b>No Asbestos Detected</b>
<b>BABC - R1A10 - Secure Storeroom</b>						
No Asbestos						
<b>BABC - R1A11 - Resources Store</b>						
No Asbestos						
<b>BABC - R1A13 - Cleaning Store - Distributed</b>						
Non Accessible						
<b>BABC - R1A14 - Staff Study</b>						
No Asbestos						
<b>BABC - R1A15 - Tea Room</b>						
No Asbestos						
<b>BABC - R1A16 - Stairs</b>						
No Asbestos						
<b>BABC - R1B01 - Careers Advisers Office</b>						
No Asbestos						
<b>BABC - R1B02 - Toilets-Girls</b>						
Partition Walls (Cubicles)	Compressed AC Sheet					
	8560/BABC/R1B06/Partition Walls (Cubicles)/S13					<b>No Asbestos Detected</b>
<b>BABC - R1B03 - Distribution Board Cupboard</b>						
					Note: No inspection of live electrical installation.	
No Asbestos						
<b>BABC - R1B04 - Movement</b>						
No Asbestos						
<b>BABC - R1B05 - Distribution Board Cupboard</b>						
					Note: No inspection of live electrical installation.	
No Asbestos						
<b>BABC - R1B06 - Staff - Toilet</b>						
Partition Walls (Cubicles)	Compressed AC Sheet					
	8560/BABC/R1B06/Partition Walls (Cubicles)/S13					<b>No Asbestos Detected</b>
<b>BABC - R1B07 - Interview/Office - Type 1</b>						



Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
	<b>Sample No</b>					<b>Test Result</b>
						No Asbestos
	<b>BABC - R1B08 - Stairs</b>					No Asbestos
	<b>BABC - R1B10 - Stairs</b>					No Asbestos
	<b>BABC - R1B11 - Ramp</b>					No Asbestos
	<b>BABC - R1C01 - General Learning Space</b>					No Asbestos
	<b>BABC - R1C02 - General Learning Space</b>					No Asbestos
	<b>BABC - R1C03 - General Learning Space</b>					No Asbestos
	<b>BABC - R1C04 - Computer Learning Space</b>					No Asbestos
	<b>BABC - R1C05 - General Learning Space</b>					No Asbestos
	<b>BABC - R1C06 - General Learning Space</b>					No Asbestos
	<b>BABC - R1C07 - General Learning Space</b>					No Asbestos
	<b>BABC - R1C08 - General Learning Space</b>					No Asbestos
	<b>BABC - R1C09 - Movement</b>					No Asbestos
	<b>BABC - R1C10 - Cleaning Store - Distributed</b>					Non Accessible
	<b>BABC - R1C12 - Resources Store</b>					No Asbestos
	<b>BABC - R1C13 - Secure Storeroom</b>					No Asbestos
	<b>BABC - R1C14 - General Storeroom</b>					No Asbestos
	<b>BABC - R1C15 - Interview/Office - Type 1</b>					No Asbestos
	<b>BABC - R1C16 - Staff Study</b>					No Asbestos
	<b>BABC - R1C17 - Tea Room</b>					No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

## Demountables

**Demountable details as per the AMS records as of 15 Feb 2017.**

**OS 601 - D11792 - Learning Unit - Standard/Withdrawal : Placement Date - 30/06/1995**

### Exterior

Step Treads	Compressed AC Sheet	Assumed Asbestos	1.08 m2
Landing	Compressed AC Sheet	Assumed Asbestos	1.2 m2
Eave Lining	Flat AC Sheet	Assumed Asbestos	11.52 m2

### Interior

#### R1 - Entry

End wall panel	Flat AC Sheet	Assumed Asbestos	18 m2
Ceiling	Flat AC Sheet	Assumed Asbestos	8 m2

#### R2 - General Learning Space

End wall panel	Flat AC Sheet	Assumed Asbestos	18 m2
Ceiling	Flat AC Sheet	Assumed Asbestos	55 m2

#### R3 - Store

Ceiling	Flat AC Sheet	Assumed Asbestos	10 m2
---------	---------------	------------------	-------

**OS 601 - D13300 - Learning Unit - Standard/Withdrawal : Placement Date - 19/03/2015**

### Exterior

Step Treads	Compressed AC Sheet	Assumed Asbestos	1.08 m2
Landing	Compressed AC Sheet	Assumed Asbestos	1.2 m2
Eave Lining	Flat AC Sheet	Assumed Asbestos	11.52 m2

### Interior

#### R1 - Entry

End wall panel	Flat AC Sheet	Assumed Asbestos	18 m2
Ceiling	Flat AC Sheet	Assumed Asbestos	8 m2

#### R2 - General Learning Space

End wall panel	Flat AC Sheet	Assumed Asbestos	18 m2
Ceiling	Flat AC Sheet	Assumed Asbestos	55 m2

#### R3 - Store

Ceiling	Flat AC Sheet	Assumed Asbestos	10 m2
---------	---------------	------------------	-------

**OS 601 - D13678 - Learning Unit - Standard/Withdrawal : Placement Date - 9/10/2015**

### Exterior

No Asbestos Found.

### Interior

#### R1 - Entry

No Asbestos Found.

#### R2 - General Learning Space

No Asbestos Found.

#### R3 - Store

No Asbestos Found.

**OS 601 - D14531 - Learning Unit - Standard/Withdrawal : Placement Date - 19/03/2015**

### Exterior

Step Treads	Compressed AC Sheet	Assumed Asbestos	1.08 m2
Landing	Compressed AC Sheet	Assumed Asbestos	1.2 m2
Eave Lining	Flat AC Sheet	Assumed Asbestos	11.52 m2

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**Interior**

**R1 - Entry**

End wall panel	Flat AC Sheet	Assumed Asbestos				18 m2
Ceiling	Flat AC Sheet	Assumed Asbestos				8 m2

**R2 - General Learning Space**

End wall panel	Flat AC Sheet	Assumed Asbestos				18 m2
Ceiling	Flat AC Sheet	Assumed Asbestos				55 m2

**R3 - Store**

Ceiling	Flat AC Sheet	Assumed Asbestos				10 m2
---------	---------------	------------------	--	--	--	-------

**OS 601 - D16629 - Learning Unit - Standard/Withdrawal : Placement Date - 10/03/2016**

Note: This refurbished demountable may have asbestos present in remnant mastic in window frames.

**Exterior**

No Asbestos Found.

**Interior**

**R1 - Entry**

No Asbestos Found.

**R2 - General Learning Space**

No Asbestos Found.

**R3 - Store**

No Asbestos Found.

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

***Listing of Electronic Attachments as of 22/03/2017***

**Available Asbestos Related Electronic Files**

8560\_ASB\_221112\_AMP.pdf

\* Note : Refer to AMS for details of the attachment(s).

2017