

Asbestos Register

(Hazardous Materials and Risk Assessment)

School : Windang Public School (1992)
Region : Illawarra and South East
State Electorate : Wollongong
Local Government Area : Wollongong

Initial Survey : Noel Arnold & Associates : 23 - Apr - 2008
Reviewed By : AECOM : 18 - Jun - 2015



2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00A - General Learning/Staff Facilities - 1961 - Brick/Veneer (Brick/Veneer)**Exterior**

Eaves Linings	Flat AC Sheeting	50m2	North, South	Good Condition (1)	Low (1)	Low Priority (2-3)
	1992/B00A/R0024/Ceiling Structures/Linings/S5			Chrysotile (white asbestos) , Amosite (brown asbestos)		
Gable Verge Lining	Flat AC Sheeting	15m2	East, West	Good Condition (1)	Low (1)	Low Priority (2-3)
	1992/B00A/R0024/Ceiling Structures/Linings/S5			Chrysotile (white asbestos) , Amosite (brown asbestos)		
Ceiling Voids	No Asbestos Found					
Underfloor Voids	Non Accessible Area - Height Restriction					

Interior**B00A - R0001 - Staff Room Annexe**

No Asbestos

B00A - R0002 - Staff Toilet

Ceiling Structures/Linings	Flat AC Sheeting	4m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	1992/B00A/R0024/Ceiling Structures/Linings/S5			Chrysotile (white asbestos) , Amosite (brown asbestos)		

B00A - R0003 - Seminar/Study

Ceiling Structures/Linings	Flat AC Sheeting	12m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	1992/B00A/R0024/Ceiling Structures/Linings/S5			Chrysotile (white asbestos) , Amosite (brown asbestos)		

Wall Linings Internal	Flat AC Sheeting	12m2	South, East, West	Good Condition (1)	Low (1)	Low Priority (2-3)
	1992/B00A/R0003/Wall Linings Internal/S4			Chrysotile (white asbestos) , Amosite (brown asbestos)		

B00A - R0004 - Security Store

No Asbestos

B00A - R0005 - Movement

No Asbestos

B00A - R0006 - Cleaning Distributed Store

No Asbestos

B00A - R0007 - Home Base

No Asbestos

B00A - R0008 - Home Base Store

No Asbestos

B00A - R0009 - Personal Effects Storage

No Asbestos

B00A - R0010 - Personal Effects Storage

No Asbestos

B00A - R0011 - Movement

No Asbestos

B00A - R0012 - Home Base Store

No Asbestos

B00A - R0013 - Home Base

No Asbestos

B00A - R0014 - General Storeroom

No Asbestos

B00A - R0015 - Movement

No Asbestos

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
B00A - R0016 - Home Base Store						
No Asbestos						
B00A - R0017 - Home Base						
No Asbestos						
B00A - R0018 - Home Base						
No Asbestos						
B00A - R0019 - Home Base Store						
No Asbestos						
B00A - R0020 - Personal Effects Storage						
No Asbestos						
B00A - R0021 - Movement						
No Asbestos						
B00A - R0022 - Special Programs Room						
No Asbestos						
B00A - R0023 - Staff Toilet						
No Asbestos						
B00A - R0024 - Movement						
Ceiling Structures/Linings	Flat AC Sheeting	5m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
1992/B00A/R0024/Ceiling Structures/Linings/S5				Chrysotile (white asbestos) , Amosite (brown asbestos)		
B00A - R0025 - Movement						
Ceiling Structures/Linings	Flat AC Sheeting	5m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
1992/B00A/R0024/Ceiling Structures/Linings/S5				Chrysotile (white asbestos) , Amosite (brown asbestos)		
B00A - R0026 - Movement						
Ceiling Structures/Linings	Flat AC Sheeting	5m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
1992/B00A/R0024/Ceiling Structures/Linings/S5				Chrysotile (white asbestos) , Amosite (brown asbestos)		
B00A - R0027 - Movement						
Ceiling Structures/Linings	Flat AC Sheeting	5m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
1992/B00A/R0024/Ceiling Structures/Linings/S5				Chrysotile (white asbestos) , Amosite (brown asbestos)		

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00B - Library - 1978 - Brick/Veneer (Brick/Veneer)

Exterior

Eaves Linings	Flat AC Sheeting	50m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	1992/B00B/Eaves Linings/S11					Chrysotile (white asbestos)
Gable Verge Lining	Flat AC Sheeting	15m2	North, South	Good Condition (1)	Low (1)	Low Priority (2-3)
	1992/B00B/Eaves Linings/S11					Chrysotile (white asbestos)
Ceiling Voids	No Asbestos Found					
Underfloor Voids	Non Accessible Area - Height Restriction					

Interior

B00B - R0001 - Reading Area

No Asbestos

B00B - R0002 - Library Office/Workroom

No Asbestos

B00B - R0003 - Reading Area

No Asbestos

B00B - R0004 - Reading Area

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00C - General Learning/Administration - 1962 - Brick/Veneer (Brick/Veneer)**Exterior**

Eaves Linings	Flat AC Sheeting	80m2	North, South	Good Condition (1)	Low (1)	Low Priority (2-3)
	1992/B00C/Gable Verge Lining/S8					Chrysotile (white asbestos)
Gable Verge Lining	Flat AC Sheeting	15m2	East, West	Good Condition (1)	Low (1)	Low Priority (2-3)
	1992/B00C/Gable Verge Lining/S8					Chrysotile (white asbestos)
Ceiling Voids	No Asbestos Found					
Underfloor Voids - Slab on Ground	No Asbestos Found					

Interior**B00C - R0001 - Home Base**

No Asbestos

B00C - R0002 - Home Base Store

No Asbestos

B00C - R0003 - Personal Effects Storage

No Asbestos

B00C - R0004 - Movement

No Asbestos

B00C - R0005 - Sports Store

No Asbestos

B00C - R0006 - Uniform Shop

No Asbestos

B00C - R0008 - Cleaning Distributed Store

No Asbestos

B00C - R0009 - General Storeroom

No Asbestos

B00C - R0010 - Clerical Office/Workroom

No Asbestos

B00C - R0011 - Clerical Office

No Asbestos

B00C - R0012 - Staff Toilet

No Asbestos

B00C - R0013 - Staff Toilet

No Asbestos

B00C - R0014 - Principal

No Asbestos

B00C - R0015 - General Storeroom

No Asbestos

B00C - R0016 - Entry Vestibule

No Asbestos

B00C - R0017 - Personal Effects Storage

No Asbestos

B00C - R0018 - Home Base Store

No Asbestos

B00C - R0019 - Home Base

No Asbestos

B00C - R0020 - Home Base

No Asbestos

B00C - R0021 - Toilets - Boys/Girls

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
Ceiling Structures/Linings	Flat AC Sheeting	6m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
1992/B00C/R0021/Ceiling Structures/Linings/S10					Chrysotile (white asbestos)	
B00C - R0022 - Home Base Store						
No Asbestos						
B00C - R0023 - Personal Effects Storage						
No Asbestos						
B00C - R0024 - Home Base Store						
Ceiling Structures/Linings	Flat AC Sheeting	1m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
1992/B00C/R0021/Ceiling Structures/Linings/S10					Chrysotile (white asbestos)	
B00C - R0025 - Movement						
Ceiling Structures/Linings	Flat AC Sheeting					No Asbestos Detected
1992/B00C/R0028/Ceiling Structures/Linings/S9						
Wall Linings Internal	Flat AC Sheeting	6m2	West	Good Condition (1)	Low (1)	Low Priority (2-3)
1992/B00C/R0025/Wall Linings Internal/S1					Chrysotile (white asbestos)	
B00C - R0026 - Movement						
Ceiling Structures/Linings	Flat AC Sheeting					No Asbestos Detected
1992/B00C/R0028/Ceiling Structures/Linings/S9						
B00C - R0027 - Movement						
Ceiling Structures/Linings	Flat AC Sheeting					No Asbestos Detected
1992/B00C/R0028/Ceiling Structures/Linings/S9						
B00C - R0028 - Movement						
Ceiling Structures/Linings	Flat AC Sheeting					No Asbestos Detected
1992/B00C/R0028/Ceiling Structures/Linings/S9						
B00C - R0029 - General Storeroom						
Floor Coverings Res/Textile	Vinyl Tiles (Under Floor Covering/Carpet)					No Asbestos Detected
1992/B00C/R0007/Floor Coverings Res/Textile/S2						
B00C - R0030 - Clerical Office						
Floor Coverings Res/Textile	Vinyl Tiles (Under Floor Covering/Carpet)					No Asbestos Detected
1992/B00C/R0007/Floor Coverings Res/Textile/S2						

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00D - Pupil Facilities - 1964 - Timber (Timber)

Exterior

Eaves Linings	Flat AC Sheeting	20m2	North, South	Good Condition (1)	Low (1)	Low Priority (2-3)
	1992/B00D/Eaves Linings/S7					Chrysotile (white asbestos)
Gable Verge Lining	Flat AC Sheeting	10m2	East, West	Good Condition (1)	Low (1)	Low Priority (2-3)
	1992/B00D/Eaves Linings/S7					Chrysotile (white asbestos)
Ceiling Voids	No Asbestos Found					
Underfloor Voids - Slab on Ground	No Asbestos Found					

Interior

B00D - R0001 - Movement

Ceiling Structures/Linings	Flat AC Sheeting	20m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	1992/B00D/Eaves Linings/S7					Chrysotile (white asbestos)

B00D - R0002 - Canteen Office/Store

No Asbestos

B00D - R0003 - Staff Toilet

No Asbestos

B00D - R0004 - Movement

No Asbestos

B00D - R0005 - Canteen

No Asbestos

B00D - R0006 - Sports Store

Wall Linings Internal	Flat AC Sheeting					
	1992/B00D/R0006/Wall Linings Internal/S3					No Asbestos Detected

B00D - R0007 - Main Switch Board

Non Accessible

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
B00E - Pupil Facilities/Other-Commercial - 1960 - Brick/Block (Brick/Block)						
Exterior						
Eaves Linings	Flat AC Sheeting	40m2	North, South	Good Condition (1)	Low (1)	Low Priority (2-3)
	1992/B00E/Gable Verge Lining/S12					Chrysotile (white asbestos)
Gable Verge Lining	Flat AC Sheeting	15m2	East, West	Good Condition (1)	Low (1)	Low Priority (2-3)
	1992/B00E/Gable Verge Lining/S12					Chrysotile (white asbestos)
Wall Cladding	Flat AC Sheeting					No Asbestos Detected
	1992/B00E/Wall Cladding/S14					
Underfloor Voids - Slab on Ground	No Asbestos Found					
Ceiling Voids	No Asbestos Found					
Interior						
B00E - R0002 - Cleaning Supplies						
Ceiling Structures/Linings	Flat AC Sheeting	4m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	1992/B00E/R0005/Ceiling Structures/Linings/S13					Chrysotile (white asbestos) , Amosite (brown asbestos) , Crocidolite (blue asbestos)
B00E - R0003 - Cleaning Distributed Store						
Ceiling Structures/Linings	Flat AC Sheeting	1m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	1992/B00E/R0005/Ceiling Structures/Linings/S13					Chrysotile (white asbestos) , Amosite (brown asbestos) , Crocidolite (blue asbestos)
B00E - R0004 - Toilets - Girls						
Ceiling Structures/Linings	Flat AC Sheeting	52m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	1992/B00E/R0005/Ceiling Structures/Linings/S13					Chrysotile (white asbestos) , Amosite (brown asbestos) , Crocidolite (blue asbestos)
B00E - R0005 - Toilets - Boys						
Ceiling Structures/Linings	Flat AC Sheeting	53m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	1992/B00E/R0005/Ceiling Structures/Linings/S13					Chrysotile (white asbestos) , Amosite (brown asbestos) , Crocidolite (blue asbestos)
B00E - R0006 - Cleaning Distributed Store						
Ceiling Structures/Linings	Flat AC Sheeting	1.4m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	1992/B00E/R0005/Ceiling Structures/Linings/S13					Chrysotile (white asbestos) , Amosite (brown asbestos) , Crocidolite (blue asbestos)
B00E - R0007 - Staff Toilet						
Ceiling Structures/Linings	Flat AC Sheeting	3m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	1992/B00E/R0005/Ceiling Structures/Linings/S13					Chrysotile (white asbestos) , Amosite (brown asbestos) , Crocidolite (blue asbestos)
B00E - R0008 - Movement						
No Asbestos						
B00E - R0009 - Other-Commercial						
No Asbestos						
B00E - R0010 - Sports Store						
Ceiling Structures/Linings	Flat AC Sheeting	8m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	1992/B00E/R0005/Ceiling Structures/Linings/S13					Chrysotile (white asbestos) , Amosite (brown asbestos) , Crocidolite (blue asbestos)
B00E - R0011 - Movement						
Wall Linings Internal	Flat AC Sheeting					No Asbestos Detected
	1992/B00E/R0011/Wall Linings Internal/S15					
B00E - R0012 - General Storeroom						
No Asbestos						

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00F - Building Services - 1975 - Metal Shed (Metal Shed)

Exterior

No Asbestos

Interior

B00F - R0001 - General Assistant/Bulk Store

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
	Sample No					Test Result

B00G - Communal Facilities - 2010 - Brick/Veneer (Brick/Veneer)**Exterior**

Ceiling Voids	No Asbestos Found
Underfloor Voids	No Asbestos Found

Interior**B00G - R0001 - Communal Space**

No Asbestos

B00G - R0002 - Raised Platform

No Asbestos

B00G - R0003 - Chair Storeroom

No Asbestos

B00G - R0004 - Communal/Performance Store

No Asbestos

B00G - R0005 - P.E. Store

No Asbestos

B00G - R0006 - Toilet - Lobby

No Asbestos

B00G - R0007 - Toilets - Girls

No Asbestos

B00G - R0008 - Sound Cupboard

No Asbestos

B00G - R0009 - Toilet - Lobby

No Asbestos

B00G - R0010 - Toilets - Boys

No Asbestos

B00G - R0011 - Cleaning Distributed Store

No Asbestos

B00G - R0012 - Plant

No Asbestos

B00G - R0013 - Main Switch Board

No Asbestos

B00G - R0014 - Access Shower/Toilet

No Asbestos

B00G - R0015 - External Movement

No Asbestos

B00G - R0016 - Movement

No Asbestos

B00G - R0017 - Movement

No Asbestos

B00G - R0018 - Movement

No Asbestos

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

Demountables

Demountable details as per the AMS records as of 15 Feb 2017.

OS 520 - D10682 - Staff Study : Placement Date - 22/10/1998

Exterior

Step Treads	Compressed AC Sheet	Assumed Asbestos			1.08 m2
Landing	Compressed AC Sheet	Assumed Asbestos			1.2 m2
Eave Lining	Flat AC Sheet	Assumed Asbestos			8.64 m2

Interior

R1 - Staff Room

End wall panel	Flat AC Sheet	Assumed Asbestos			50 m2
Ceiling	Flat AC Sheet	Assumed Asbestos			55 m2

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

Listing of Electronic Attachments as of 22/03/2017

Available Asbestos Related Electronic Files

1992_ASB_030113_AMP.pdf

* Note : Refer to AMS for details of the attachment(s).

2017