



Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B00A - Administration - 1950 - Timber (Timber)****Exterior**

Wall Cladding	Flat AC Sheeting 5667/B00A/Wall Cladding/S2					<b>No Asbestos Detected</b>
Underfloor Voids	No Asbestos Found					
Ceiling Void	No Asbestos Found					

**Interior****B00A - R0001 - Staff Room**

Wall Linings Internal	Flat AC Sheeting 5667/B00A/R0001/Wall Linings Internal/S7					<b>No Asbestos Detected</b>
Ceiling Structures/Linings	Flat AC Sheeting 5667/B00A/R0001/Ceiling Structures/Linings/S8					<b>No Asbestos Detected</b>

**B00A - R0002 - Clerical Office/Workroom**

No Asbestos

**B00A - R0003 - External Movement**

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B00B - Staff Facilities - 1972 - Brick/Block (Brick/Block)**

**Exterior**

Underfloor Voids - Slab on Ground	No Asbestos Found
Ceiling Void	No Asbestos Found

**Interior**

**B00B - R0001 - Staff Toilet**

No Asbestos

**B00B - R0002 - Staff Toilet**

No Asbestos

**B00B - R0003 - External Movement**

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B00C - Mechanical Services - 1972 - Fibre Cement Clad (Fibre Cement Clad)**

**Exterior**

Underfloor Voids - Slab on Ground	No Asbestos Found
Ceiling Void	No Asbestos Found

**Interior**

**B00C - R0001 - Plant**

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B00D - Building Services - 1972 - Fibre Cement Clad (Fibre Cement Clad)**

**Exterior**

Underfloor Voids - Slab on Ground	No Asbestos Found					
Wall Cladding	Flat AC Sheeting 5667/B00D/Wall Cladding/S3					<b>No Asbestos Detected</b>
Eaves Linings	Flat AC Sheeting 5667/B00D/Eaves Linings/S1	7m2	East	Good Condition (1)	Low (1)	Low Priority (2-3) <b>Chrysotile (white asbestos)</b>
Ceiling Void	No Asbestos Found					

**Interior**

**B00D - R0001 - General Assistants**

No Asbestos

**B00D - R0002 - Garage/Carport**

Wall Linings Internal	Flat AC Sheeting 5667/B00D/R0002/Wall Linings Internal/S5	20m2	North	Minimal Damage (2)	Low (1)	Low Priority (2-3) <b>Chrysotile (white asbestos)</b>
-----------------------	--	------	-------	--------------------	---------	--

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B00E - General Learning - 2000 - Sandstone (Sandstone)**

**Exterior**

Underfloor Voids - Slab on Ground      No Asbestos Found

Ceiling Voids      No Asbestos Found

**Interior**

**B00E - R0001 - Home Base**

No Asbestos

**B00E - R0002 - General Storeroom**

No Asbestos

**B00E - R0003 - General Storeroom**

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

**B00F - Building Services - 1973 - Fibre Cement Clad (Fibre Cement Clad)**

**Exterior**

Underfloor Voids - Slab on Ground	No Asbestos Found					
Wall Cladding	Flat AC Sheeting	40m2	Throughout	Minimal Damage (2)	Low (1)	Low Priority (2-3)
	5667/B00F/Wall Cladding/S4			<b>Chrysotile (white asbestos) , Amosite (brown asbestos)</b>		

**Interior**

**B00F - R0001 - General Storeroom**

Wall Linings Internal	Flat AC Sheeting	40m2	Throughout	Some Damage - Unsealed (3)	Low (1)	Medium Priority (4-5)
	5667/B00F/R0001/Wall Linings Internal/S9			<b>Chrysotile (white asbestos)</b>		
Ceiling Void	No Asbestos Found					

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

***Demountables***

**There are no Demountable(s) located at this school as per the AMS records as of 15 Feb 2017.**

2017



Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

*Listing of Electronic Attachments as of 22/03/2017*

**There are no asbestos related file attachment(s) for this school.**

2017