


Asbestos Register

(Hazardous Materials and Risk Assessment)

School : Bankstown Public School (7405)
Region : South Western Sydney
State Electorate : Bankstown
Local Government Area : Bankstown

Initial Survey : Noel Arnold & Associates : 22 - Apr - 2008
Reviewed By : Parsons Brinckerhoff : 13 - Oct - 2015



2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No				Test Result		

B001 - Administration/General Learning - 1915 - Brick/Block (Brick/Block)**Exterior**

Eaves Linings	Flat AC Sheeting	22m2	North, South, East, West, Variable positions	Good Condition (1)	Low (1)	Low Priority (2-3)
	7405/B001/Eaves Linings/S13					Chrysotile (white asbestos)
Ceiling Voids	No Asbestos Found					
Underfloor Voids	No Asbestos Found					

Interior**B001 - R0001 - Home Base**

No Asbestos

B001 - R0002 - Home Base

No Asbestos

B001 - R0003 - Home Base

No Asbestos

B001 - R0004 - Home Base

No Asbestos

B001 - R0005 - Clerical Office

No Asbestos

B001 - R0006 - Movement

No Asbestos

B001 - R0007 - Sick Bay

No Asbestos

B001 - R0008 - General Storeroom

No Asbestos

B001 - R0009 - Entry Vestibule

No Asbestos

B001 - R0012 - Community Clinic

No Asbestos

B001 - R0013 - Movement

No Asbestos

B001 - R0014 - General Storeroom

No Asbestos

B001 - R0015 - Home Base

No Asbestos

B001 - R0016 - General Storeroom

Floor Coverings Res/Textile	Vinyl Tiles					
	7405/B001/R0022/Floor Coverings Res/Textile/S7					No Asbestos Detected

B001 - R0017 - Movement

Floor Coverings Res/Textile	Vinyl Tiles					
	7405/B001/R0022/Floor Coverings Res/Textile/S7					No Asbestos Detected

B001 - R0018 - Movement

No Asbestos

B001 - R0019 - Cleaning Distributed Store

No Asbestos

B001 - R0020 - Sports Store

Floor Coverings Res/Textile	Vinyl Tiles					
	7405/B001/R0022/Floor Coverings Res/Textile/S7					No Asbestos Detected

B001 - R0021 - General Storeroom

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
	Sample No				Test Result	
Floor Coverings Res/Textile	Vinyl Tiles					
	7405/B001/R0022/Floor Coverings Res/Textile/S7				No Asbestos Detected	
B001 - R0022 - General Storeroom						
Floor Coverings Res/Textile	Vinyl Tiles					
	7405/B001/R0022/Floor Coverings Res/Textile/S7				No Asbestos Detected	
B001 - R0023 - Movement						
No Asbestos						
B001 - R0024 - General Storeroom						
No Asbestos						
B001 - R0025 - Principal						
No Asbestos						
B001 - R0026 - Movement						
No Asbestos						
B001 - R0027 - Home Base						
No Asbestos						
B001 - R0028 - Home Base						
No Asbestos						
B001 - R0029 - Home Base						
No Asbestos						
B001 - R0030 - Home Base						
No Asbestos						
B001 - R0031 - Movement						
No Asbestos						
B001 - R0032 - Movement						
No Asbestos						
B001 - R0033 - General Assistant/Bulk Store						
No Asbestos						
B001 - R0034 - Staff Toilet						
Wall Linings Internal	Flat AC Sheeting	4m2	North, South	Good Condition (1)	Low (1)	Low Priority (2-3)
	7405/B001/R0034/Wall Linings Internal/S6				Chrysotile (white asbestos)	
B001 - R0035 - Staff Toilet						
Wall Linings Internal	Flat AC Sheeting	4m2	North, East, Variable positions	Good Condition (1)	Low (1)	Low Priority (2-3)
	7405/B001/R0034/Wall Linings Internal/S6				Chrysotile (white asbestos)	
B001 - R0036 - Movement						
No Asbestos						
B001 - R0037 - Movement						
Ceiling Structures/Linings	Flat AC Sheeting	16m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	7405/B001/R0037/Ceiling Structures/Linings/S16				Chrysotile (white asbestos)	
B001 - R0038 - Movement						
Ceiling Structures/Linings	Flat AC Sheeting	20m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	7405/B001/R0038/Ceiling Structures/Linings/S17				Chrysotile (white asbestos)	
B001 - R0039 - Handwashing Facilities						
Ceiling Structures/Linings	Flat AC Sheeting	16m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	7405/B001/R0039/Ceiling Structures/Linings/S18				Chrysotile (white asbestos)	
B001 - R0040 - Toilets - Boys						

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No				Test Result		
Ceiling Structures/Linings	Flat AC Sheeting	38m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
7405/B001/R0040/Ceiling Structures/Linings/S19				Chrysotile (white asbestos)		
Partition Walls (Cubicles)	Compressed AC Sheet	13m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
7405/B007/R0002/Partition Walls (Cubicles)/S5				Chrysotile (white asbestos)		

B001 - R0042 - Movement

No Asbestos

B001 - R0043 - Movement

Ceiling Structures/Linings Flat AC Sheeting

7405/B001/R0043/Ceiling Structures/Linings/S8

No Asbestos Detected**B001 - R0044 - Stairs**

No Asbestos

B001 - R0045 - Stairs

No Asbestos

B001 - R0046 - Stairs

No Asbestos

B001 - R0047 - Home Base Store

No Asbestos

B001 - R0048 - General Storeroom

No Asbestos

B001 - R0049 - Uniform Shop

No Asbestos

B001 - R1001 - Toilets - Boys/Girls

No Asbestos

B001 - R1002 - Movement

No Asbestos

B001 - R1003 - Practical Activities - 1hbFloor Coverings Vinyl Tiles
Res/Textile

7405/B001/R0022/Floor Coverings Res/Textile/S7

No Asbestos Detected**B001 - R1004 - Home Base**

No Asbestos

B001 - R1005 - Home Base

No Asbestos

B001 - R1006 - Home Base

No Asbestos

B001 - R1007 - Home Base

No Asbestos

B001 - R1008 - Movement

No Asbestos

B001 - R1010 - Withdrawal Space - 1hb

No Asbestos

B001 - R1011 - Staff Room Annexe

No Asbestos

B001 - R1012 - Movement

No Asbestos

B001 - R1013 - Withdrawal Space - 1hb

No Asbestos

B001 - R1014 - General Storeroom

No Asbestos

B001 - R1015 - Home Base

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
	Sample No	Test Result				
No Asbestos						
B001 - R1016 - Special Programs Room						
No Asbestos						
B001 - R1017 - Deputy Principal						
No Asbestos						
B001 - R1018 - Home Base						
No Asbestos						
B001 - R1019 - General Storeroom						
Floor Coverings Res/Textile	Vinyl Tiles					
	7405/B001/R0022/Floor Coverings Res/Textile/S7					No Asbestos Detected
B001 - R1020 - Movement						
No Asbestos						
B001 - R1021 - Movement						
No Asbestos						
B001 - R1022 - Home Base						
No Asbestos						
B001 - R1023 - Home Base						
No Asbestos						
B001 - R1024 - Home Base						
No Asbestos						
B001 - R1025 - Home Base						
No Asbestos						
B001 - R1026 - Home Base						
No Asbestos						
B001 - R1027 - Movement						
No Asbestos						
B001 - R1028 - Stairs						
No Asbestos						
B001 - R1029 - Stairs						
No Asbestos						
B001 - R1030 - Stairs						
No Asbestos						

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No				Test Result		

B002 - General Learning - 1923 - Brick/Block (Brick/Block)**Exterior**

Ceiling Voids	No Asbestos Found					
Underfloor Voids	Packing 7405/B002/Underfloor Voids/S14					No Asbestos Detected

Interior**B002 - R0001 - Movement**

No Asbestos

B002 - R0002 - Toilets - Boys/Girls

No Asbestos

B002 - R0003 - Movement

No Asbestos

B002 - R0009 - General Storeroom

Floor Coverings Res/Textile	Vinyl Tiles 7405/B001/R0022/Floor Coverings Res/Textile/S7					No Asbestos Detected
Ceiling Structures/Linings	Vermiculite 7405/B002/R0028/Ceiling Structures/Linings/S9					No Asbestos Detected

B002 - R0010 - Movement

No Asbestos

B002 - R0011 - Personal Effects Storage

No Asbestos

B002 - R0022 - Movement

No Asbestos

B002 - R0023 - Movement

Ceiling Structures/Linings	Vermiculite 7405/B002/R0028/Ceiling Structures/Linings/S9					No Asbestos Detected
----------------------------	--	--	--	--	--	----------------------

B002 - R0024 - Movement

No Asbestos

B002 - R0026 - Staff Room Annexe

Ceiling Structures/Linings	Vermiculite 7405/B002/R0028/Ceiling Structures/Linings/S9					No Asbestos Detected
----------------------------	--	--	--	--	--	----------------------

B002 - R0027 - Movement

Ceiling Structures/Linings	Vermiculite 7405/B002/R0028/Ceiling Structures/Linings/S9					No Asbestos Detected
----------------------------	--	--	--	--	--	----------------------

B002 - R0029 - Stairs

Ceiling Structures/Linings	Vermiculite 7405/B002/R0029/Ceiling Structures/Linings/S20					No Asbestos Detected
----------------------------	---	--	--	--	--	----------------------

B002 - R0030 - Stairs

Ceiling Structures/Linings	Vermiculite 7405/B002/R0030/Ceiling Structures/Linings/S21					No Asbestos Detected
----------------------------	---	--	--	--	--	----------------------

B002 - R0031 - Entry Vestibule

No Asbestos

B002 - R0032 - Clerical Office

No Asbestos

B002 - R0033 - Duplicating Workroom

No Asbestos

B002 - R0034 - Principal

No Asbestos

B002 - R0035 - Access Shower/Toilet

No Asbestos

B002 - R0036 - Staff Room

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
	Sample No	Test Result				
No Asbestos						
B002 - R0037 - Staff Room Annexe						
No Asbestos						
B002 - R0038 - Home Base Store						
No Asbestos						
B002 - R0039 - Withdrawal - M						
No Asbestos						
B002 - R0040 - Home Base						
No Asbestos						
B002 - R0041 - Movement						
No Asbestos						
B002 - R0042 - Interview						
No Asbestos						
B002 - R0043 - Interview/Office - Type 3						
No Asbestos						
B002 - R0044 - Staff Toilet						
No Asbestos						
B002 - R0045 - Staff Toilet						
No Asbestos						
B002 - R0046 - Staff Toilet						
No Asbestos						
B002 - R0047 - Sick Bay						
No Asbestos						
B002 - R0048 - Handwashing Facilities						
No Asbestos						
B002 - R0049 - Handwashing Facilities						
No Asbestos						
B002 - R0050 - Handwashing Facilities						
No Asbestos						
B002 - R0051 - Interview/Office - Type 3						
No Asbestos						
B002 - R0052 - Interview/Office - Type 3						
No Asbestos						
B002 - R0053 - Movement						
No Asbestos						
B002 - R1001 - Toilets - Boys/Girls						
Wall Linings Internal	Flat AC Sheeting					
	7405/B002/R0028/Ceiling Structures/Linings/S9					No Asbestos Detected
B002 - R1002 - Movement						
No Asbestos						
B002 - R1003 - Withdrawal Space - 1hb						
No Asbestos						
B002 - R1004 - Home Base Store						
No Asbestos						
B002 - R1005 - Home Base						
No Asbestos						
B002 - R1006 - Home Base						
No Asbestos						
B002 - R1007 - Home Base						
No Asbestos						
B002 - R1008 - Home Base						

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
	Sample No				Test Result	
No Asbestos						
B002 - R1009 - Home Base						
No Asbestos						
B002 - R1010 - Withdrawal Space - 1hb						
No Asbestos						
B002 - R1011 - Movement						
No Asbestos						
B002 - R1012 - Cleaning Distributed Store						
Wall Linings Internal	Flat AC Sheeting					
	7405/B002/R0028/Ceiling Structures/Linings/S9					No Asbestos Detected
B002 - R1013 - Home Base						
No Asbestos						
B002 - R1014 - Home Base						
No Asbestos						
B002 - R1015 - Movement						
No Asbestos						
B002 - R1016 - Stairs						
Wall Linings Internal	Flat AC Sheeting					
	7405/B002/R1016/Wall Linings Internal/S22					No Asbestos Detected
B002 - R1017 - Stairs						
Wall Linings Internal	Flat AC Sheeting					
	7405/B002/R1017/Wall Linings Internal/S23					No Asbestos Detected

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
	Sample No	Test Result				

B003 - General Learning - 1975 - Brick/Block (Brick/Block)**Exterior**

Ceiling Voids	No Asbestos Found
Underfloor Voids	No Asbestos Found

Interior**B003 - R0001 - Communal Space**

No Asbestos

B003 - R0002 - Communal Space

No Asbestos

B003 - R0003 - Movement

No Asbestos

B003 - R0004 - Movement

No Asbestos

B003 - R0005 - Cleaning Distributed Store

No Asbestos

B003 - R0006 - Cleaning Supplies

No Asbestos

B003 - R0007 - General Storeroom

No Asbestos

B003 - R0008 - Home Base

No Asbestos

B003 - R0009 - Staff Room Annexe

No Asbestos

B003 - R0010 - Movement

No Asbestos

B003 - R0011 - Home Base

No Asbestos

B003 - R0012 - Home Base

No Asbestos

B003 - R0013 - Home Base

No Asbestos

B003 - R0014 - Staff Room Annexe

No Asbestos

B003 - R0015 - Home Base

No Asbestos

B003 - R0017 - Movement

No Asbestos

B003 - R0018 - Sports Store

No Asbestos

B003 - R0019 - Hall Chair Store

No Asbestos

B003 - R0021 - Movement

No Asbestos

B003 - R0022 - Movement

No Asbestos

B003 - R0023 - Movement

No Asbestos

B003 - R0024 - Movement

No Asbestos

B003 - R0025 - Movement

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	
No Asbestos						
B003 - R0026 - Movement						
No Asbestos						
B003 - R0027 - Movement						
No Asbestos						
B003 - R0028 - Movement						
No Asbestos						
B003 - R0029 - Movement						
No Asbestos						
B003 - R0030 - Stairs						
No Asbestos						
B003 - R0031 - Movement						
No Asbestos						
B003 - R0032 - Sports Store						
No Asbestos						
B003 - R0033 - Stairs						
No Asbestos						
B003 - R0034 - General Storeroom						
No Asbestos						
B003 - R1001 - Staff Toilet						
Floor Coverings Res/Textile	Vinyl Tiles					
	7405/B003/R1001/Floor Coverings Res/Textile/S11				No Asbestos Detected	
Ceiling Structures/Linings	Flat AC Sheeting	7m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	7405/B003/R1001/Ceiling Structures/Linings/S24				Chrysotile (white asbestos)	
B003 - R1002 - General Storeroom						
Ceiling Structures/Linings	Flat AC Sheeting	4m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
	7405/B003/R1002/Ceiling Structures/Linings/S25				Chrysotile (white asbestos)	
B003 - R1003 - Staff Room						
No Asbestos						
B003 - R1005 - Home Base						
No Asbestos						
B003 - R1006 - Shower/Change						
Wall Linings Internal	Flat AC Sheeting	2m2	Lower portion	Good Condition (1)	Low (1)	Low Priority (2-3)
	7405/B003/R1006/Wall Linings Internal/S10				Chrysotile (white asbestos)	
B003 - R1007 - Staff Toilet						
No Asbestos						
B003 - R1008 - Handwashing Facilities						
No Asbestos						
B003 - R1009 - Movement						
No Asbestos						
B003 - R1010 - Special Programs Room						
No Asbestos						
B003 - R1011 - Home Base						
No Asbestos						
B003 - R1012 - Staff Room Annexe						
No Asbestos						
B003 - R1013 - Movement						

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
	Sample No			Test Result		
Ceiling Structures/Linings	Flat AC Sheeting	40m2	East	Good Condition (1)	Low (1)	Low Priority (2-3)

7405/B003/R1013/Ceiling Structures/Linings/S26

Chrysotile (white asbestos)

B003 - R1014 - Home Base

No Asbestos

B003 - R1015 - Home Base

No Asbestos

B003 - R1017 - Home Base

No Asbestos

B003 - R1018 - Movement

No Asbestos

B003 - R1019 - Movement

No Asbestos

B003 - R1020 - Staff Room Annexe

No Asbestos

B003 - R1021 - Home Base

No Asbestos

B003 - R1022 - General Storeroom

No Asbestos

B003 - R1023 - Movement

No Asbestos

B003 - R1024 - Stairs

No Asbestos

B003 - R1025 - Stairs

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B004 - Other-After School Care - 1930 - Brick/Block (Brick/Block)**Exterior**

Ceiling Voids	No Asbestos Found
Underfloor Voids	No Asbestos Found

Interior**B004 - R0001 - Movement**

Ceiling Structures/Linings	Flat AC Sheeting	3m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
7405/B004/R0001/Ceiling Structures/Linings/S36				Chrysotile (white asbestos) , Amosite (brown asbestos)		

B004 - R0002 - Practical Activities - 1hb

Ceiling Structures/Linings	Flat AC Sheeting	7m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
7405/B004/R0002/Ceiling Structures/Linings/S37				Chrysotile (white asbestos) , Amosite (brown asbestos)		

B004 - R0003 - General Storeroom

Wall Linings Internal	Flat AC Sheeting	50m2	North, west	Good Condition (1)	Low (1)	Low Priority (2-3)
7405/B004/R0003/Wall Linings Internal/S38				Chrysotile (white asbestos)		

B004 - R0005 - Communal Space

Ceiling Structures/Linings	Flat AC Sheeting	102m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
7405/B004/R0005/Ceiling Structures/Linings/S39				Chrysotile (white asbestos) , Amosite (brown asbestos)		

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B005 - Pupil Facilities - 1975 - Brick/Block (Brick/Block)**Exterior**

Wall Cladding	Flat AC Sheeting 7405/B005/Wall Cladding/S1	No Asbestos Detected				
Ceiling Voids	No Asbestos Found					
Underfloor Voids	No Asbestos Found					

Interior**B005 - R0001 - Staff Toilet**

No Asbestos

B005 - R0003 - General Storeroom

No Asbestos

B005 - R0004 - General Storeroom

No Asbestos

B005 - R0005 - Canteen

No Asbestos

B005 - R0006 - Movement

Ceiling Structures/Linings	Flat AC Sheeting	51m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
7405/B005/R0006/Ceiling Structures/Linings/S31					Chrysotile (white asbestos)	

B005 - R0007 - Kiln Room

Ceiling Structures/Linings	Flat AC Sheeting	2m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
7405/B005/R0007/Ceiling Structures/Linings/S32					Chrysotile (white asbestos)	

B005 - R0008 - Special Programs Room

Ceiling Structures/Linings	Flat AC Sheeting	58m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
7405/B005/R0008/Ceiling Structures/Linings/S33					Chrysotile (white asbestos)	

B005 - R0009 - Garden Store

Ceiling Structures/Linings	Flat AC Sheeting	14m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
7405/B005/R0009/Ceiling Structures/Linings/S34					Chrysotile (white asbestos)	

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
	Sample No	Test Result				

B006 - Pupil Facilities - 1975 - Brick/Block (Brick/Block)**Exterior**

Ceiling Voids	No Asbestos Found
Underfloor Voids	No Asbestos Found

Interior**B006 - R0001 - Movement**

No Asbestos

B006 - R0002 - Toilets - Boys

No Asbestos

B006 - R0003 - Toilets - Girls

No Asbestos

B006 - R0004 - Movement

No Asbestos

B006 - R0005 - Movement

No Asbestos

B006 - R0006 - Movement

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
	Sample No	Test Result				

B007 - Pupil Facilities - 1975 - Brick/Block (Brick/Block)**Exterior**

Eaves Linings	Flat AC Sheeting 7405/B007/Eaves Linings/S15	No Asbestos Detected				
Ceiling Voids	No Asbestos Found					
Underfloor Voids	No Asbestos Found					

Interior**B007 - R0001 - Drinking Facilities**

No Asbestos

B007 - R0002 - Toilets - Girls

Partition Walls (Cubicles)	Compressed AC Sheet	26m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)
7405/B007/R0002/Partition Walls (Cubicles)/S5						Chrysotile (white asbestos)

B007 - R0003 - Cleaning Distributed Store

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
	Sample No	Test Result				

B008 - Pupil Facilities - 1975 - Brick/Block (Brick/Block)**Exterior**

Ceiling Voids No Asbestos Found

Underfloor Voids No Asbestos Found

Interior**B008 - R0001 - Movement**

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
	Sample No	Test Result				

B009 - General Learning - 2004 - Fibre Cement Clad (Fibre Cement Clad)**Exterior**

Ceiling Voids	No Asbestos Found
Underfloor Voids	No Asbestos Found

Interior**B009 - R0001 - Movement**

No Asbestos

B009 - R0002 - Practical Activities - 1hb

No Asbestos

B009 - R0003 - Home Base Store

Vinyl Tiles (Under Floor No Asbestos Found
Covering/Carpet)

B009 - R0004 - Home Base

Vinyl Tiles (Under Floor No Asbestos Found
Covering/Carpet)

B009 - R0005 - Withdrawal Space - 2hb

Vinyl Tiles (Under Floor No Asbestos Found
Covering/Carpet)

B009 - R0006 - Home Base

Vinyl Tiles (Under Floor No Asbestos Found
Covering/Carpet)

B009 - R0007 - Home Base Store

Vinyl Tiles (Under Floor No Asbestos Found
Covering/Carpet)

B009 - R0008 - Practical Activities - 1hb

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

B00L - Library - 1984 - Brick/Veneer (Brick/Veneer)**Exterior**

Wall Cladding	Flat AC Sheeting 7405/B00L/Wall Cladding/S2					No Asbestos Detected
Ceiling Voids	No Asbestos Found					
Underfloor Voids	No Asbestos Found					

Interior**B00L - R0001 - Movement**

No Asbestos

B00L - R0002 - Reading Area

No Asbestos

B00L - R0003 - Library Office/Workroom

No Asbestos

B00L - R0004 - Library Office/Workroom

No Asbestos

B00L - R0005 - Communications Room

No Asbestos

B00L - R0006 - General Storeroom

No Asbestos

B00L - R0007 - Cleaning Distributed Store

No Asbestos

B00L - R0008 - Movement

Wall Linings Internal	Flat AC Sheeting 7405/B00L/Wall Cladding/S2					No Asbestos Detected
Door Lining	Flat AC Sheeting 7405/B00L/R0008/In-fill-panel/S4	2m2	On Door	Good Condition (1)	Low (1) Low Priority (2-3)	Chrysotile (white asbestos)

B00L - R0009 - Cleaning Distributed Store

Wall Linings Internal	Flat AC Sheeting 7405/B00L/R0009/Wall Linings Internal/S3					No Asbestos Detected
-----------------------	--	--	--	--	--	----------------------

B00L - R0010 - Movement

No Asbestos

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
	Sample No	Test Result				

B010 - Communal Facilities - 2005 - Brick/Veneer (Brick/Veneer)**Exterior**

Ceiling Voids	No Asbestos Found
Underfloor Voids	No Asbestos Found

Interior**B010 - R0001 - Communal Space**

No Asbestos

B010 - R0002 - Disabled Shower/Toilet

No Asbestos

B010 - R0003 - Toilets - Boys

No Asbestos

B010 - R0004 - Communications Room

No Asbestos

B010 - R0005 - General Assistant/Bulk Store

No Asbestos

B010 - R0006 - Garden Store

No Asbestos

B010 - R0007 - Performance Store

No Asbestos

B010 - R0008 - Cleaning Distributed Store

No Asbestos

B010 - R0009 - Movement

No Asbestos

B010 - R0010 - Canteen Office/Store

No Asbestos

B010 - R0011 - Movement

No Asbestos

B010 - R0012 - Raised Platform

No Asbestos

B010 - R0013 - Chair Store

No Asbestos

B010 - R0014 - Cleaning Distributed Store

No Asbestos

B010 - R0015 - Main Switch Board

No Asbestos

B010 - R0016 - P.E. Store

No Asbestos

B010 - R0017 - Sports Store

No Asbestos

B010 - R0018 - Toilets - Girls

No Asbestos

B010 - R0019 - Stairs

No Asbestos

B010 - R0020 - Movement

No Asbestos

B010 - R0021 - Movement

No Asbestos

B010 - R0022 - Canteen

No Asbestos

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No				Test Result		

Demountables**Demountable details as per the AMS records as of 15 Feb 2017.****OS 602 - D14279 - Learning Unit - Standard With P.A.A. : Placement Date - 12/12/2011****Exterior**

Step Treads	Compressed AC Sheet	Assumed Asbestos	1.08 m2
Landing	Compressed AC Sheet	Assumed Asbestos	1.2 m2
Eave Lining	Flat AC Sheet	Assumed Asbestos	11.52 m2

Interior**R1 - Learning space/withdrawal/entry**

Ceiling	Flat AC Sheet	Assumed Asbestos	70 m2
---------	---------------	------------------	-------

R2 - Home Base Store

End wall panel	Flat AC Sheet	Assumed Asbestos	18 m2
Ceiling	Flat AC Sheet	Assumed Asbestos	3 m2

OS 601 - D14749 - Learning Unit - Standard/Withdrawal : Placement Date - 5/04/2002**Exterior**

Step Treads	Compressed AC Sheet	Assumed Asbestos	1.08 m2
Landing	Compressed AC Sheet	Assumed Asbestos	1.2 m2
Eave Lining	Flat AC Sheet	Assumed Asbestos	11.52 m2

Interior**R1 - Entry**

End wall panel	Flat AC Sheet	Assumed Asbestos	18 m2
Ceiling	Flat AC Sheet	Assumed Asbestos	8 m2

R2 - General Learning Space

End wall panel	Flat AC Sheet	Assumed Asbestos	18 m2
Ceiling	Flat AC Sheet	Assumed Asbestos	55 m2

R3 - Store

Ceiling	Flat AC Sheet	Assumed Asbestos	10 m2
---------	---------------	------------------	-------

OS 601 - D14946 - Learning Unit - Standard/Withdrawal : Placement Date - 30/12/2004**Exterior**

Step Treads	Compressed AC Sheet	Assumed Asbestos	1.08 m2
Landing	Compressed AC Sheet	Assumed Asbestos	1.2 m2
Eave Lining	Flat AC Sheet	Assumed Asbestos	11.52 m2

Interior**R1 - Entry**

End wall panel	Flat AC Sheet	Assumed Asbestos	18 m2
Ceiling	Flat AC Sheet	Assumed Asbestos	8 m2

R2 - General Learning Space

End wall panel	Flat AC Sheet	Assumed Asbestos	18 m2
Ceiling	Flat AC Sheet	Assumed Asbestos	55 m2

R3 - Store

Ceiling	Flat AC Sheet	Assumed Asbestos	10 m2
---------	---------------	------------------	-------

OS 603 - D16627 - Learning Unit - Standard With P.A.A. A/C : Placement Date - 12/12/2011

Note: This refurbished demountable may have asbestos present in remnant mastic in window frames.

Exterior

No Asbestos Found.

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
	Sample No				Test Result	
Interior						
R1 - Learning space/withdrawal/entry						
No Asbestos Found.						
R2 - Home Base Store						
No Asbestos Found.						

2017

Product	Material Description	Extent	Location Reference	Material Condition	Risk Status	Control Priority
Sample No					Test Result	

Listing of Electronic Attachments as of 22/03/2017

There are no asbestos related file attachment(s) for this school.

2017